Date Received 3-12-84

RECEIVED
MAR 15 '84
[illegible]

SIR No. 20760

T.C. No. 037-203-14

Map Date _____

Call 1st she wants to meet you there

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER BALLARD (LAST) WALTER (FIRST) H. (MIDDLE)

2) ADDRESS OF OWNER 7601 Old Statesville Rd ZIP 28213

3) PHONE NO Home 596-4764 Office 597-1798


4) LOCATION OF PROPERTY 5217 Henderson Ct. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Katy Ballard
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 5575

SIR No. 20760

T. C. No. PO 037-203-14

Date Issued 4-6-84

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Ballard, (LAST) Walter (FIRST) H. (MIDDLE)

ADDRESS OF OWNER 7601 Old Statesville Rd., Charlotte, NC ZIP 28213

LOCATION OF PROPERTY 5217 Henderson Circle (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a soil investigation and site evaluation was made by the Mecklenburg County Department of Environmental Health on the above described lot. The said investigation was conducted on that portion of the lot as indicated on the above plot. **PROVISIONALLY SUITABLE**

The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit and construction authorization must be obtained from the Mecklenburg County Department of Environmental Health prior to the installation of the wastewater treatment system on the said lot.
2. The location of the system must be approved by the Mecklenburg County Department of Environmental Health prior to the installation of the system and on the actual lot.
3. This approval is for the system installation on the above plot.
4. The approval is granted only for the type of system specified and the [illegible] indicated as acceptable for the [illegible]

This approval is granted only in the laws of the State of North Carolina, the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Richard Ramsey
Soil Scientist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20760

T.C. NO. PO 037-203-14

(Ground Absorption Sewage Disposal)

OWNER: Walter H. BALLARD
ADDRESS: 7601 Statesville Rd 28213
LOCATION OF SITE: 5317 Henderson Cr.

PLAT NO:
LOT SIZE: 1.2H

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-10	S (PS) U — 0-5	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U — Clayey	S PS (U) — Mixed Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S PS (U) — Weak Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U — 36-48	S PS (U) — 20-36	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S (PS) U — None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — Adequate	S PS (U) — Slow	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVa	IIIa		
9. SITE CLASSIFICATION	Suitable	Unsuitable		
10. SOIL SERIES	Cecil	Helena		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 4-4-84

A

Survey is Approximate - Back Corners Not Located.



Henderson Circle -

Life Station Required if unit is Set on Henderson Circle