MOORE'S Environmental Services

Operators Responsible for Care (O.R.C.'s):
Jack Moore - Certified Operator #985357
David Lynch - Certified Operator #996383

J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Phone (704) 873-2171
Fax (704) 873-9928
Mobile (704) 902-1122

MAINTENANCE REPORT FORM

Name and Location of System
Jeffrey Dabkowski
12728 Westmoreland Rd
Huntersville, NC. 28078

Date of Inspection
12 Aug 2019

Permit Number
30007785

System Classification
Type IV-A

Phone (413) 387-5357
Phone

Alternate Mailing Address

Subdivision

County
Mecklenburg

Phone
Phone

SEPTIC TANK AND PUMP TANK

Risers accessible?	[U] Unsatisfactory
Signs of infiltration?	[S] Satisfactory
Structurally sound?	[S] Satisfactory
Landscape position?	[S] Satisfactory
Septic tank filter cleaned?	NO*
Pump tank filter cleaned?	[N/A] Not Applicable

SOLIDS ACCUMULATION

Approximate Quantity of Solid Waste in Septic Tank

INLET Scum: ~_____ in. Sludge: ~_____ in.
OUTLET Scum: ~_____ in. Sludge: ~_____ in.

Approximate Percentage of Solids to Liquid Waste in Tank

~ %

DRAIN FIELD

No effluent surfacing?	[S] Satisfactory
Surface water diverted?	[S] Satisfactory
Line cover maintained properly?	[S] Satisfactory
Protected from traffic?	[S] Satisfactory
Distribution devices operating properly?	[S] Satisfactory
Repair area reserved?	[S] Satisfactory

PUMP

Pump present and operating?

Design GPM	37
Actual GPM	37
Efficiency	100%

High water alarm operating properly?	[S] Satisfactory
Pipework in good condition?	[S] Satisfactory
Control panel in good condition?	[S] Satisfactory
Control floats operating properly?	[S] Satisfactory
Straps / float tree in good condition?	[S] Satisfactory
Effluent free and clear of solids?	[S] Satisfactory

LOW PRESSURE PIPE SYSTEM

Turnups, cleanouts, valves located and protected?	[S] Satisfactory
Laterals free of excess solids?	[S] Satisfactory
Laterals flushed?	YES

PRESSURE HEADS

	DESIGN HEAD	ADJUSTED HEAD
Line 1	2	2
Line 2	2	2
Line 3	2	2

COMMENTS

[Septic tank has no access risers. Lids are ~10-12" below surface]

We did not dig up the septic tank this trip.