

6421 LAKE RD

13709918

4/14/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Log No.: 1987 Section: JWWS Hazard? [ ] Yes [ ] No

Date: 07-01-94 Parcel: 137-099-18 <60 Days? [ ] Yes [ ] No

REQUESTING PERSON: Lynn Lathan Phone

Address City Zip


PROPERTY CONCERNED: Facility Name J.W. Green Residence

Address 6421 Lake Road City Zip 28227

SERVICE REQUESTED: PLEASE ADVISE WHETHER OR NOT THE WASTE WATER DISPOSAL SYSTEM OR REPAIR SPACE WILL BE AFFECTED ADVERSELY BY ADDITION OF A SWIMMING POOL AS PROPOSED IN ATTACHED PLAN

ASSIGNED TO: Susan Bateman TAKEN BY: Lynn Lathan

DATE	ACTIVITY REPORT
	Cartridge filter to be installed / Lathan
	File 831A
7-7	Site visit for pool location moved to be 15' from septic tank system (It was ± 5' from system before). Approved for new site location.
	Above ground pool.



COPY

NOTIFICATION TO REQUESTING PERSON: (✓) Written ( ) Verbal ( ) Not Applicable

COMPLETED BY: S. Bateman, RS , 7-7-94

REVIEWED BY: T. Walter for S. Daniel , 7/14/94

c:/original/serreqpl.frm 03/19/91

* Posted on 7/5/94 (out on Friday)