

4309 BELLWOOD LN

23120216

1/3/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

FEE: N/A
DATE: 10-25-95

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE

[ ] CRT

TYPE APPLICATION: ___ NEW SYSTEM ___ EXPANSION OF EXISTING SYSTEM ✓ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 3794B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 231-201-33

STREET ADDRESS: 4309 Bellwood Lane

SUBDIVISION OR MOBILE HOME PARK NAME: Bellwood

LOT NUMBER:

TOWNSHIP (CHECK ONE):

- ___ 0 MECKLENBURG
- X 1 CHARLOTTE
- ___ 2 DAVIDSON
- ___ 3 CORNELIUS
- ___ 4 PINEVILLE
- ___ 5 MATTHEWS
- ___ 6 HUNTERSVILLE
- ___ 7 MINT HILL

TYPE OF BUILDING, (CHECK ONE)

- ___ SINGLE MOBILE HOME(S)
- ___ DOUBLE WIDE (D)
- ✓ HOUSE (H)
- ___ MODULAR HOME (M)
- ___ MULTIPLE FAMILY (U)
- ___ OTHER (O)

HEATED SQUARE FOOTAGE: 2400

NUMBER OF BEDROOMS: 4

NUMBER OF OCCUPANTS:

FOUNDATION FOR RESIDENCE:

- ___ WITHOUT BASEMENT ON SLAB
- X CRAWL SPACE
- ___ WITH BASEMENT /PLUMBING
- ___ WITH BASEMENT /NO PLUMBING

IF EXPANSION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: ___ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):

- ___ COMMUNITY (C)
- ✓ MUNICIPAL (M)
- ___ PRIVATE WELL (P)
- ___ SHARED WELL (S)
- ___ OTHER 'SPRINGS' (O)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES	✓ YES ___ NO	WELL SPRINGS OR WATERLINES	___ YES ✓ NO
EXISTING WASTE WATER SYSTEMS	✓ YES ___ NO	DESIGNATED WETLANDS	___ YES ✓ NO
EASEMENTS OR RIGHT-OF-WAYS	___ YES ✓ NO		

PROPERTY OWNER:

NAME: Kennedy (LAST) Kevin (FIRST) M (MI)

ADDRESS: 4309 Bellwood lane

CITY: Charlotte STATE: NC ZIP 28270

DAYTIME PHONE: 212-683-0010

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: Homoly (LAST) Carolyn (FIRST) (MI)

DAYTIME PHONE: 704 542-1100

(Jan Kennedy 843-21214)

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? _____

THE UNDERSIGNED, OWNER, OR LEGAL AGENT FOR THE OWNER, OF THE PROPERTY DESCRIBED ABOVE AS THE "JOB LOCATION" HAS READ THE FOREGOING APPLICATION, ACKNOWLEDGES THAT THE CONTENTS OF SAME ARE TRUE, AND AUTHORIZES AGENTS OF THE MECKLENBURG COUNTY HEALTH DEPARTMENT TO ENTER ONTO THE PROPERTY FOR THE PURPOSE OF PROCESSING THIS REQUEST.

SIGNED: JKennedy DATE: 10/25/95

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102

FEE: ~~N/A~~ 0460

DATE: 10-25-95

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE

| CRT

TYPE APPLICATION: ___ NEW SYSTEM ___ EXPANSION OF EXISTING SYSTEM ✓ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 3794B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 231-201-33

STREET ADDRESS: 4309 Bellwood Lane

SUBDIVISION OR MOBILE HOME PARK NAME: Bellwood

LOT NUMBER:

TOWNSHIP (CHECK ONE):

0 MECKLENBURG	4 PINEVILLE
X 1 CHARLOTTE	5 MATTHEWS
2 DAVIDSON	6 HUNTERSVILLE
3 CORNELIUS	7 MINT HILL

TYPE OF BUILDING, (CHECK ONE)

___ SINGLE MOBILE HOME(S)	___ MODULAR HOME (M)
___ DOUBLE WIDE (D)	___ MULTIPLE FAMILY (U)
✓ HOUSE (H)	___ OTHER (O)

HEATED SQUARE FOOTAGE: 2400

NUMBER OF BEDROOMS: 4 NUMBER OF OCCUPANTS:

FOUNDATION FOR RESIDENCE:

___ WITHOUT BASEMENT ON SLAB	___ WITH BASEMENT /PLUMBING
X CRAWL SPACE	___ WITH BASEMENT /NO PLUMBING

IF EXPANSION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: ___ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):

___ COMMUNITY (C)	✓ MUNICIPAL (M)	___ PRIVATE WELL (P)
___ SHARED WELL (S)	___ OTHER 'SPRINGS' (O)	

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES	✓ YES ___ NO	WELL SPRINGS OR WATERLINES	___ YES ✓ NO
EXISTING WASTE WATER SYSTEMS	✓ YES ___ NO	DESIGNATED WETLANDS	___ YES ✓ NO
EASEMENTS OR RIGHT-OF-WAYS	___ YES ✓ NO		

PROPERTY OWNER:	LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:
NAME: Kennedy (LAST) Kevin (FIRST) M (MI)	NAME: Hamby (LAST) Carolyn (FIRST) N (MI)
ADDRESS: 4309 Bellwood Lane	DAYTIME PHONE: 704 542-1100
CITY: Charlotte STATE: NC ZIP: 28270	(Jan Kennedy 843-2124)
DAYTIME PHONE: 912-683-0010	

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? _____

THE UNDERSIGNED, OWNER, OR LEGAL AGENT FOR THE OWNER, OF THE PROPERTY DESCRIBED ABOVE AS THE "JOB LOCATION" HAS READ THE FOREGOING APPLICATION, ACKNOWLEDGES THAT THE CONTENTS OF SAME ARE TRUE, AND AUTHORIZES AGENTS OF THE MECKLENBURG COUNTY HEALTH DEPARTMENT TO ENTER ONTO THE PROPERTY FOR THE PURPOSE OF PROCESSING THIS REQUEST.

SIGNED: JKennedy DATE: 10/25/95

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102

Permit Number: 3794B

CONDITIONS OF IMPROVEMENT PERMIT

$460

Tax Number: 231-201-33

- The IMPROVEMENT PERMIT is subject to revocation if site plans or the intended use change. There is to be **NO** grading, filling or disturbance of th in the area of the septic tank system or repair area.
- CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is **NOT** transferable not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.
- Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement	___ Yes	✓ No	___ Partial Basement
Type Primary Wastewater System Type (circle one): I (II) III IV V VI	___ Conventional ___ Prefabricated, permeable block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experiment ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1
___ Long-term acceptance rate	___ Max gallons/day wastewater flow	___ Absorption Area (sq ft)	___ Trench spacing (min. on centers)
___ Serviced by private well	___ Gallon septic tank	___ Total trench length (ft)	___ Maximum trench depth (At least 12" of provisionally suitable must remain between trench bottom an unsuitable soil conditions)
___ Bedrooms in residence	___ Gallon pump tank	___ Depth of stone	
Any surface waters present:	Type:	Minimum separation distance:	
Site modifications required:			
Additional Conditions:	Repair to existing wastewater system > 30 years old. (1) 7'W x 85'L x 24"D x 12"S		
Repair Area System Type Type (circle one): I (II) III IV V VI	✓ Conventional ___ Prefabricated, permeable block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimer ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1
600 Absorption Area (Sq ft) 200 Total Trench Length (Ft)	12" Depth of Stone Trench	N/A Trench spacing (min. on centers)	24" Maximum Trench De
For existing system, enter the year originally installed:	1960		

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Reques Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules For Sewage, Treatment and Disposal at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Dep
- This Improvement permit is transferable.

Larry B Thompson Jr. L.S. 10-25-95

DEHNR Authorized Agent — Date

J Kondatchy 10-25-95

Owner/Agent Signature — Date

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR.
SUITE 211
700 N. TRYON ST.
CHARLOTTE, N.C. 28202.
(704) 336-5102

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENTAL, HEALTH,
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

D460

FEE: _____ **AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION**
DATE: _____ **VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE**

DATE: 10-27-95 **PERMIT NO:** 3794 B
PARCEL NO: 231-201-33

PROPERTY OWNER: Kevin M. Kennedy
BUILDING CONTRACTOR: N/A
JOB LOCATION ADDRESS: 4309 Bellwood Lane
SUBDIVISION NAME: Bellwood
AUTHORIZATION ISSUED BY: Ramy B. Thompson Jr. L.S. **DATE:** 10-27-95
DEHNR/AUTHORIZED AGENT

AUTHORIZATION CONDITIONS

1. WASTEWATER SYSTEM CONSTRUCTION AND INSTALLATION MUST MEET ALL CONDITIONS AND SPECIFICATIONS AS SET FORTH IN IMPROVEMENT PERMIT NO. 3794 B, AND THE ATTACHED SITE PLAN WITH SYSTEM DETAILS. CONSTRUCTION AND INSTALLATION MUST ALSO MEET ALL REQUIREMENTS SET FORTH IN THE RULES GOVERNING SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL AND ANY OTHER APPLICABLE RULES AND LAWS.

2. AN INSTALLATION, CONSTRUCTION, ALTERATION AND/OR REPAIR APPROVAL MUST BE SECURED PRIOR TO INSTALLATION OF THE SEPTIC TANK SYSTEM. THE INSTALLER OF THE SYSTEM SHALL BE A REGISTERED SEPTIC TANK CONTRACTOR WITH MECKLENBURG COUNTY HEALTH DEPARTMENT.

3. ANY ALTERATION IN SITE OR SOIL CONDITIONS (INCLUDING LOCATION OF STRUCTURES AND APPURTENANCES) OR MODIFICATION IN USE, DESIGN WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS AS SPECIFIED IN THE ASSOCIATED IMPROVEMENT PERMIT AND APPLICATION, MAY SUBJECT THIS AUTHORIZATION AND ASSOCIATED PERMIT(S) TO REVOCATION.

4. OTHER CONDITIONS: _____

OWNER CERTIFICATION

I CERTIFY THAT THERE HAVE BEEN NO ALTERATIONS IN SITE OR SOIL CONDITIONS OR MODIFICATIONS TO FACILITY, WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS FROM THOSE SPECIFIED IN THE ORIGINAL APPLICATION OR ASSOCIATED IMPROVEMENT PERMIT UNLESS AUTHORIZED IN WRITING BY THE MECKLENBURG COUNTY HEALTH DEPARTMENT. I ALSO UNDERSTAND THAT ANY SUCH ALTERATIONS, MODIFICATIONS, OR FALSE INFORMATION ARE GROUNDS FOR REVOCATION OF PERMITS AND AUTHORIZATION TO CONSTRUCT.

Carolyn Homoly 10/27/95
SIGNATURE OF OWNER/OWNER'S REPRESENTATIVE DATE

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3794 B DATE: 10-27-95

TC: 231-201-33 ☐ L

SERIAL Nº 16281

Permission is hereby given to _____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 10-25-95. All work shall be completed on or before 11-25-95, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank Existing gallons

Liquid Capacity of Dosing Tank Existing gallons

Tank Construction Existing

Trench Depth as shallow as possible

Absorption and/or Nitrification Lines:

Trench Width 9' feet

Trench Walls Scored and Porous Yes

Total Line Length 200 feet

Number of Lines 3 in 1

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well N/A feet
Municipal

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Kevin M. Kennedy

LOCATION OF PROPERTY 4309 Bellwood Lane

Comments: Repair to existing system >20 years old
Type II a (1) 9'w x 65'L x 12"G

Larry B. Thompson, J., L.S.
Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT 0460

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3794 B DATE: 10-27-95

TC: 231-201-33 ☐ L ☐ CRT

SERIAL Nº 16282

Name of Owner Kevin M. Kennedy Juris.:

Address of Property 4309 Bellwood Lane

Inspection Data:

Tank Material Existing

Total Length of Drainfield 200'

Number of Lines 3 in 1 @ 65'

Cover Depth 12"

Water Supply Source Municipal

Distance to Water Source 750'

Excavation Inspected 10-27

Tank(s) Inspected N/A

Wash Line Inspected N/A

High Water Alarm Inspected N/A

PLOT

Design 1995 CON repair, 600SF, B, 12G, cecil-like CTR# 82 NOCWOOD

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Repair to existing system >20 years old
Type II a (1) 9'W x 65'L x 12"G

Larry B. Thompson, Jr. R.S.
Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.