SEE INSTRUCTIONS ON BACK

Date Received 3-5-82

ICAR(S) Application No. 18911

T. C. No. 001-382-41


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____ Yes X No
Residence X Yes ____ No

4) No. of Bedrooms 3
5) Business Use — Max (No) Employees _____
6) Washing Machine X Yes ____ No
7) Garbage Disposal ____ Yes X No
8) Dishwasher ____ Yes X No
9) Water Supply:
A) Individual Well ✓
B) Governmental System _____
C) Community System:
1 Well source _____
2 Governmental source _____
10) Sewage System:
House located within 200 feet of public sewer ____ Yes ✓ No
House located within 200 feet of community sewer ____ Yes X No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER WILSON (LAST) ROBERT (FIRST) EARL (MIDDLE)

14) ADDRESS OF OWNER 1625 BALLANTREE DR

15) PHONE NO. Home 704 563-7619 Office 704 525-9475

16) LOCATION OF SYSTEM 1625 BALLANTREE DR (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

3/5/82
DATE OF APPLICATION

Robert E. Wilson Jr.
OWNER

EHD-5-76 ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 8-8-82

Serial No. 5621


ICAR(S) Permit No. 18911

T. C. No. 001-382-41

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18911, dated 8-6-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 8-22-82, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate ___

Liquid Capacity of Tank 1500 gallons

Tank Construction precast concrete

Absorption and or Nitrification Lines

Total Line Length 100'

Number of Lines 2

Distance from House >5'

Distance from Property Line >10'

Distance from Well >50'

NAME OF OWNER Nelson, Robert Earl

LOCATION OF PROPERTY 16125 Balmoral Drive

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: pump old tank + backfill replace with a 1500 gallon tank + install a drainfield 6' wide × 25' long × 34" of stone + overflow to connect to the existing drainfield.

Division or Section Head

Mike Sexton
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 18911 /

Date Issued 8/19/82 Serial 5300 T. C. No. 001-382-41

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner NELSON (LAST) ROBERT (FIRST) E. (MIDDLE)

Location of Property 16125 BALMORAL DRIVE

Application Number 18911 Permit Number 18911

Inspection Data:

Liquid Capacity of Tank 1500 GAL Tank Material PRECAST

Total Length of Drain Tile 100' Number of Lines 2

Depth of Filter Material 34" Cover Depth 20"

Water Supply Source well Distance from Water Source >50'

Excavation Inspected — Tank Inspected 8/13/82 (DATE)

Nitrification Field Inspected 8/13/82 (DATE)

Washing Machine Line Inspected, If Applicable 8/13/82 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: OLD TANK backfilled - 8/19/82

Adam Wipfield
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY