Date Received 11/16/79

NOV 1 . 1979

APT No. 16321

T. C. No. 113-197-06

Map Date 5/23/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Chipley, J (LAST, FIRST) G (MIDDLE)

2) ADDRESS OF OWNER 5532 Wilkinson Blvd. ZIP 28208

3) PHONE NO Home ____ Office 399-7765

4) LOCATION OF PROPERTY Mt Olive Church Road (STREET OR COUNTY ROAD)

5) SUBDIVISION ____ LOT NO 15 BLOCK NO B

MAP BOOK NO 7 PAGE NO 749

6) DEED REFERENCE DEED BOOK ____ PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

J. G. Chipley
OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16321

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 113-197-06

(Ground Absorption Sewage Disposal)

OWNER: F.G. CHIPLEY
ADDRESS: 5532 WILKINSON BLVD
COUNTY: CHARLOTTE 28208
LOCATION OF SITE: Mt. OLIVE CHURCH RD

DATE REQUESTED: 11-16-79
PLAT NO.:
LOT SIZE: 25,000+

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-15	S PS (U) — Complex Slopes	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy loamy, clayey, Note 2:1 Clay)	S (PS) U — Clayey	S (PS) U — Clayey	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S (PS) U — Blocky	S (PS) U — Blocky	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U — 48	S PS (U) — <48	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S (PS) U — NONE	S PS (U) — Clays	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S (PS) U — ADEQUATE	S (PS) U — ADEQUATE	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U — MODERATE	S PS (U) — SLOW	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	P. Suitable	Unsuited		
SOIL SERIES	Cecil	ERODED Cecil		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments:

Described By: W. B. Ramsey

Title: Soil Scientist Date: 11-23-79

DHS Form 2601
Sanitation
EHD 539 (3/79)


N
225
MT. OLIVE CHURCH RD
Cecil
2-15
115
127
200

Serial No. 3218

PTR No. 16321

T C No 113-197-06

Date Issued Nov. 27, 1979

Map Date 5/23/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER LAST Chipley, FIRST F. G. MIDDLE

ADDRESS OF OWNER 5532 Wilkinson Blve., Charlotte ZIP 28208

LOCATION OF PROPERTY Mt. Olive Church Road STREET OR COUNTY ROAD

SUBDIVISION LOT NO #15 BLOCK NO "B"



PLOT PLAN

[illegible] investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted [illegible] indicated on the above plot.

Provisionally Suitable

The [illegible] determined by the investigation was [illegible] The said lot is approved [illegible] system with subsurface, soil ab- [illegible]

[illegible] the Mecklenburg County Depart- [illegible] wastewater treatment [illegible]

[illegible] the Mecklenburg [illegible] above, and [illegible]

[illegible] acceptable for system installation [illegible]

[illegible] performed in the lot which [illegible] indicated as acceptable for [illegible] system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W. B. Ramsey
Soil Scientist

John R Atkinson
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy