

LEMLEY TOWNSHIP LOT 1731

5/17/2007

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

June 22nd, 1988

Crescent Land and Timber Corp.
2305 Randolph Road
Charlotte, NC 28207

RE: Property located at Tuskarora Trail 1731
FILE: 4331A
PARCEL: 00137214

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 11818) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

Enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11818

File: 4331A Action 1

Parcel: PO 001-372-14 ☐ PC

Location: Tuskarora Trial

Subdivision:


Lot: Block: Acres: 1.14

Owner: Crescent Land & Timber
Address: 2305 Randolph Road
Charlotte, N. C. 28207

Comments: system may need lift pump

Described by: William A. Martin

Date: 6-22-88



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS (U) complex slopes	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 7-36" to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 7-36"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 7-36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IUA Cecil-1.1%	complex slopes				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

#45 - P - 2/29/88 Rec'd cc#265

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 4331A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Tuskarora Trail / Chestnut Tree Rd.

② SUBDIVISION: Lemley Township ③ LOT: 1731 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 001 PAGE NO.: 372 PARCEL NO.: 14

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Crescent Land and Timber Corporation (Miles Boyer)
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: c/o LandCraft Properties, Inc., 2305 Randolph Road

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28207

⑫ PHONE: (WORK) 332-9340 (HOME) 892-9811 (Lana Hathaway)

⑬ *Accurately diagram and dimension lot.*



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Miles Boyer

Date: 26 FEB 88

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 4831A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Tuskarora Trail at Chestnut Tree

② SUBDIVISION: Lemley Township ③ LOT: 1731 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 001 PAGE NO.: 372 PARCEL NO.: 14

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Crescent Land & Timber Corporation (Miles Boyer)
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: c/o LandCraft Properties, Inc. 2305 Randolph Road

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28207

⑫ PHONE: (WORK) 332-9340 (HOME) 892-9811 (Lana Hathaway)

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Ethelene B Williams

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 5-27-88

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY

Department of Environmental Health

March 28th, 1988

Crescent Land and Timber Corp.
2305 Randolph Road
Charlotte, NC 28207

RE: Property located at Tuskarora Trail 1731
FILE: 4331A
PARCEL: 00137214

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 15048) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 15048

File: 4331A Action 4

Parcel: 00137214 ☐ PC

Location: Tuskarora Trail

Subdivision:


Lot: 1731 Block: Acres: 1.39

Owner: Crescent Land and Timber Corp.
Address: 2305 Randolph Road
Charlotte, NC 28207

Comments: _____

Described by: William R. Marks

Date: 3-25-88



*** EVALUATION KEY ***

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS (U) complex slopes	S PS (U) Depression	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 30" to 36" water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36"+	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVA Cecil-Hills	complex Slopes (Terraces)	Depression			
Area Classification	S (PS) U	S PS (U)	S PS (U)	S PS U	S PS U	S PS U