Date Issued 6-14-85

Serial No. 8623

SIR No. 21019

T. C. No. PO 001-201-05

Map Date L 6LT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Archer, (LAST) James (FIRST) M. (MIDDLE)

ADDRESS OF OWNER 3223 Mountain Brook Rd., Charlotte, NC ZIP 28210

LOCATION OF LOT 16116 Weatherly Way (STREET OR COUNTY ROAD)

SUBDIVISION Lookout Point LOT NO 8 BLOCK NO.

MAP BOOK NO. PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 21019. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Issued 6-21-85

Serial No. 08271

ICAR(S) Permit No. 21019

T C No. 001-201-05

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21019, dated 6-11-85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 7-21-85, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate IVa

Liquid Capacity of Tank 1500 gal 1000 st

Tank Construction PCC

Absorption and or Nitrification Lines

Total Line Length 270'

Number of Lines Three

Distance from House 5'

Distance from Property Line 10'

Distance from Well Comm Well

NAME OF OWNER Archer, James

LOCATION OF PROPERTY 16116 Weatherly Way lot 9

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Three Trenches 90' x 3' x 12" Stone; lift station required

Comments:

B. Hartleth
Division or Section Head

Jim Emm
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

C of A (s) No. 21019

Date Issued 7-1-85 **Serial** 7650 T.C. No. 001-201-05

L CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
OPERATION PERMIT

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner ARCHER (LAST) JAMES (FIRST) (MIDDLE)

Location of Property 16116 WEATHERLY WAY

Application Number 21019 Permit Number 21019

Inspection Data:

Liquid Capacity of Tank 1500 ST + 1000 FT Tank Material PCC

Total Length of Drain Tile 270' Number of Lines 3

Depth of Filter Material 12" Cover Depth 2'

Water Supply Source ~~Not in yet~~ COMM. WELL Distance from Water Source 50 ft

Excavation Inspected 7-1-85 (DATE) Tank Inspected 7-1-85 (DATE)

Nitrification Field Inspected 7-1-85 (DATE)

Washing Machine Line Inspected If Applicable (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 1500 ST, 1000 FT, [illegible], 710 SFT, RG CECIL

Kelly Randall
Environmentalist

EHD-5-76