2164:

Serial No. 07856

ICAR (S) Permit No. 21620


Date Issued 1/11/85

T. C. No. 215-171-38 215-171-42

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21620 2164S dated 1/9/85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 2/11/85, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS

Liquid Capacity of Tank 1500 gal

Tank Construction PCC

Absorption and/or Nitrification Lines

Total Line Length 400'

Number of Lines 4 X 100'

Distance from House 5'

Distance from Property Line 10'

Distance from Well >100'

NAME OF OWNER Summey Building Systems 2624

LOCATION OF PROPERTY 2825 Katie Court

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

4 Trenches x 3'x100' x 12 stone with gradeboards and straw as cover

Comments: Stay out of gulley

Division or Section Head

Cynthia G. Bass
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

WMR

C of A (s) No. 21645

Date Issued 3/1/85 Serial 7313 T. C. No. 215-171-38

& CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Summey Building Systems (LAST / FIRST / MIDDLE)

Location of Property 2824 Katie Court

Application Number 21645 Permit Number 21645

Inspection Data:

Liquid Capacity of Tank 1500 gal (DF / WL) Tank Material PCC

Total Length of Drain Tile 300' (+) 130' Number of Lines 3X100'; 65'X2

Depth of Filter Material 12" Cover Depth 18"-24"

Water Supply Source Community Distance from Water Source >100'

Excavation Inspected 3/1/85 (DATE) Tank Inspected 3/1/85 (DATE)

Nitrification Field Inspected 3/1/85 (DATE)

Washing Machine Line Inspected, If Applicable 3/1/85 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Due to limited area, a washline was installed 3/22/85

Cynthia G. Ross
Environmentalist

EHD-5-76

Date Issued 1-9-85

Serial No. 8102

SIR No. 21645 172-03

T. C. No. PO 215-163-06 121-38

Map Date L CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Summey Building Systems, Inc. (LAST / FIRST / MIDDLE)

ADDRESS OF OWNER P.O. Box 497, Dallas, NC ZIP 28034

LOCATION OF LOT 2824 Katie Court (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 4 BLOCK NO. C

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 21645 This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed,altered, and/or repaired and that the system be installed in accordance with same
3. House will be moved back to 52 feet.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation Construction Alteration, and/or Repair Permit.

*** LIFT STATION MAY BE REQUIRED ***

Cynthia C Bass
Environmentalist

Bill D. Hartsoe
Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department Copy

Date Received 11-27-84

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
NOV 27 1984
DIVISION OF HEALTH

ICAR (S) Application No. 21645

T. C. No. PS 205-163-06


Map Date 1

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No
4) No of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A) Individual Well ___
B) Governmental System ___
C) Community System
1 Well source ✓
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER SUMMEY BUILDING SYSTEMS INC. (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER P.O. Box 487, DALLAS, N.C.

15) PHONE NO. Home ___ Office 922-7883

16) LOCATION OF SYSTEM 2824 KATIE COURT (STREET OR COUNTY ROAD)

17) SUBDIVISION SADDLEBROOK Lot No 4 Block No C

Map Book No. 20 Page No. 713

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

SUMMEY BUILDING SYSTEMS INC.
By: Phillip H. Helms

DATE OF APPLICATION ___ OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY


THIS IS TO CERTIFY THAT ON THE DAY OF 19 , I SURVEYED THE PERTY SHOWN ON THIS PLAT, AND THAT THE PROPERTY LINES, WALLS AND BUILDINGS ARE AS SHOWN HEREON; THAT THE BUILDINGS LOCATES ON SAID LOT DO NOT ENCROACH OR PROJECT ON ADJACENT STREETS PROPERTY; AND THAT NO ADJACENT BUILDINGS OR WALLS ENCROACH OR PROJECT ON SAID PREMISES.

PRELIMINARY---NO EXISTING BUILDINGS

12-20-84

SIGNED John R. Yarbrough

NORTH CAROLINA REGISTERED L 1009 LAND SURVEYOR JOHN R YARBROUGH



21645

Serial No. 07856

ICAR(S) Permit No. ~~21620~~


Date Issued 1/11/85

T. C. No. ~~215-171-38~~ 215-171-42

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application ~~21620~~ 21645 dated 1/9/85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 2/11/85, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS

Liquid Capacity of Tank 1500 gal

Tank Construction PCC

Absorption and/or Nitrification Lines

Total Line Length 400'

Number of Lines 4 x 100'

Distance from House 5'

Distance from Property Line 10'

Distance from Well >100'

NAME OF OWNER Summey Building Systems

LOCATION OF PROPERTY 2825 Katie Court

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

4 Trenches x 3' x 100' x 12" stone with gradebeards and straw as cover

Comments: Stay out of gulley

Division or Section Head

Cynthia G Bass
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

BHD-5-76

Environmental Health Department's Copy

WAR

C of A (s) No. 21645

Date Issued 3/1/85 Serial 7313 T. C No. 215-171-38

& CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Summey Building Systems (LAST / FIRST / MIDDLE)

Location of Property 2824 Katie Court

Application Number 21645 Permit Number 21645

Inspection Data:

Liquid Capacity of Tank 1500 gal (DF / WL) Tank Material PCC

Total Length of Drain Tile 300' (+) 130' Number of Lines 3X100'; 65'X2

Depth of Filter Material 12" Cover Depth 18"-24"

Water Supply Source community Distance from Water Source >100'

Excavation Inspected 3/1/85 (DATE) Tank Inspected 3/1/85 (DATE)

Nitrification Field Inspected 3/1/85 (DATE)

Washing Machine Line Inspected, If Applicable 3/1/85 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Due to limited area, a washline was installed. ≥ 4/22/86

Cynthia G. Bass
Environmentalist

EHD-5-76

Date Issued 1-9-35

Serial No. 8102

SIR No. 21645 172-03

T. C. No. PO 215-163-06 121-34

Map Date L CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Summey Building Systems, Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER P.O. Box 497, Dallas, NC ZIP 28034

LOCATION OF LOT 2824 Katie Court
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 4 BLOCK NO. C

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 21645. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same
3. House will be moved back to 52 feet.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

*** LIFT STATION MAY BE REQUIRED ***

Cynthia C Bass
Environmentalist

Bill D. Hawkins
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 11-27-84

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
NOV 27 1984
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 21645

T. C. No. PE 215-163-06


Map Date 1

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No
4) No. of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A) Individual Well ___
B) Governmental System ___
C) Community System
1 Well source ✓
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER SUMMEY BUILDING SYSTEMS INC.
LAST FIRST MIDDLE

14) ADDRESS OF OWNER P.O. BOX 497, DALLAS, N.C.

15) PHONE NO. Home ___ Office 922-7883

16) LOCATION OF SYSTEM 2824 KATIE COURT
STREET OR COUNTY ROAD

17) SUBDIVISION SADDLEBROOK Lot No 4 Block No. C

Map Book No 20 Page No. 713

18) DEED REFERENCE DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? YES NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

SUMMEY BUILDING SYSTEMS INC.
By: Phillip M. Helms

DATE OF APPLICATION

OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY


THIS IS TO CERTIFY THAT ON THE DAY OF 19 . I SURVEYED THE PROPERTY SHOWN ON THIS PLAT, AND THAT THE PROPERTY LINES, WALLS AND BUILDINGS ARE AS SHOWN HEREON, THAT THE BUILDINGS LOCATED ON SAID LOT DO NOT ENCROACH OR PROJECT ON ADJACENT STREETS OR PROPERTY; AND THAT NO ADJACENT BUILDINGS OR WALLS ENCROACH OR PROJECT ON SAID PREMISES.

SIGNED John R. Yarbrough

PRELIMINARY---NO EXISTING BUILDINGS

12-20-84

NORTH CAROLINA REGISTERED L 1009 LAND SURVEYOR JOHN R. YARBROUGH



PLOT PLAN

CHARLOTTE

SUNNY BUILDING SYSTEMS

SCALE 1" = RECORDED MAP RECORDED

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SIR. NO. 21645
T.C. NO. PO 215-163-06
DATE: 12-7-84

Surmey Building Systems, Inc.
Post Office Box 497
Dallas, North Carolina 28034

RE: Property located at 2824 Katie Court

Gentlemen:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21645

T.C. NO. CO 215-M86

(Ground Absorption Sewage Disposal)

OWNER: Lummy Building Systems Rev.
ADDRESS: PO Box 497 Dallas N.C. 28034
LOCATION OF SITE: 3824 Ball Court

PLAT NO: 46
LOT SIZE: Block 3 Lot 20

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2 to 6%	S PS (complex slopes) U	S PS 2 to 6% U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S (PS) clay U	S PS 2-1 (U) Clay	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S (PS) Blocky U	S (PS) Blocky U	S PS U
4. SOIL DEPTH (inches)	S (PS) 24 to 40" U	S PS >36" (U)	S (PS) 30-36" U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S >36" (PS) U	S PS >36" (U)	S (PS) >36" U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S >36" to (PS) ground U water	S Rapid PS internal (U) runoff	S Perched (PS) water table U 12-24"	S PS U
7. OTHER (Specify)	S Limited PS Rock U Slopes	S PS U	S PS U	S PS U
8. SOIL GROUP	IIB	IIA	IIB	
9. SITE CLASSIFICATION	Provisionally Suitable	unsuitable	unsuitable	
10. SOIL SERIES	Cecil Appling	complex slopes	Helena Ashlar	

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas wells, water bodies, slopes)

Recommendations/Comments: Suitable area - system will probably require lift pump. Recommend plans for house & system location be submitted

Described by: William R. Marlin
Title: Soil Scientist

Date: 12-9-84

DEPARTMENT OF
ENVIRONMENTAL HEALTH



Note- Curtain drain installed above drainfield would be helpful

Date Received 11-27-84

MECK COUNTY DEPARTMENT OF
RECEIVED
NOV 27 1984
ENVIRONMENTAL HEALTH

SIR No. 21645
T. C. No. PB 215-163-06
Map Date 1

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Summey Building Systems Inc.
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER P.O. Box 497, Dallas, N.C. ZIP 28034

3) PHONE NO. Home _____ Office 922-7883


4) LOCATION OF PROPERTY 2824 Katie Court
(STREET OR COUNTY ROAD)

5) SUBDIVISION Shoddlebrook LOT NO. 4 BLOCK NO. C

MAP BOOK NO 20 PAGE NO. 713

6) DEED REFERENCE DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Summey Building Systems Inc.
By: Daniel N. Helms
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 12-3-84

Serial No. 8033

SIR No. 21646

T. C. No. 199-401-25

Map Date L, 12T

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

INSTALLATION PERMIT

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Beam, (LAST) James (FIRST) W. (MIDDLE)

ADDRESS OF OWNER 225 N. Caldwell St., Charlotte, NC ZIP 28202

LOCATION OF LOT 9909 Saw Mill Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO._____ BLOCK NO._____

MAP BOOK NO._____ PAGE NO._____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 21646. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

*** USE EXISTING SYSTEM ***

B. R. Ferguson
Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy