Date Received 6-14-83

RECEIVED
JUN 14 1983
ENVIRONMENTAL HEALTH

2

SIR No. 15138

T. C. No. 111-124-22, 23

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER McCorkle (LAST) H. (FIRST) H. (MIDDLE)

2) ADDRESS OF OWNER Rt. 1 Box 90, Indian Trail, N.C. ZIP 28079

3) PHONE NO. Home _____ Office 882-1246


4) LOCATION OF PROPERTY Cedarbrook Road (Cedarbrook Acres) (STREET OR COUNTY ROAD)

5) SUBDIVISION Cedarbrook Acres LOT NO. 26 & 27 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____ 111-124-22/111-124-23

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

H.H. McCorkle
OWNER

Please send the results to Margie Reighard, Touchberry & Assoc. 3509 Matthews Mint Hill Rd., Matthews, N.C. 28105

EHD-5-7

Environmental Health Department's Copy

Date Received 5/9/79

APT No. ~~[illegible]~~

T. C. No. 111-124-22 23

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER McCorkle (LAST) Henry (FIRST) Heath (MIDDLE)

2) ADDRESS OF OWNER Rt 1 Box 316E Indian Trail ZIP 28079

3) PHONE NO. Home 882-1246 Office 882-1246


4) LOCATION OF PROPERTY Cedarbrook Drive (STREET OR COUNTY ROAD) as revised 22+23

5) SUBDIVISION Cedarbrook LOT NO 26 + 27 BLOCK NO. A

MAP BOOK NO 7 PAGE NO 641

6) DEED REFERENCE DEED BOOK 4181 PAGE NO. 0155

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

H Heath McCorkle
OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 15138

T.C. NO. III-124-22,23

(Ground Absorption Sewage Disposal)

OWNER: H. H. Mackie
ADDRESS: Rt. 1 Box 20
LOCATION OF SITE: Arabian Trail Rd 2 Rt 1 Cedarbrook Rd

PLAT NO: Lot 3 of 2727
LOT SIZE: Approx 136' x

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-8%	S (PS) U 2-10%	S (PS) U 10-20%	S (PS) U 2-10%
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) 2-1 Clay	S PS (U) 2-1 Clay	S PS (U) 2-1 Clay	S PS (U) 2-1 Clay
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Weak Blocky	S (PS) U Weak Blocky	S (PS) U Weak Blocky	S (PS) U Weak Blocky
4. SOIL DEPTH (inches)	S (PS) U 30-48"	S PS (U) 24-30"	S PS (U) 20-30"	S (PS) U 30-48"
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U 36+ To saprolite	S PS (U) ∠30" To saprolite	S PS (U) ∠30" To saprolite	S (PS) U 30"+ To saprolite
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS (U) perched water table 24-36"	S (PS) U ~36" To ground water	S (PS) U ~36" To ground water	S (PS) U ~30" To saprolite
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVB	IVB	IVB	IVB
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	unsuitable
10. SOIL SERIES	Helena Lic	Enon Lic	Wilkes Lic	Cecil/Madison Lic

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: William F. Maples
Title: Soil Scientist

Date: 6-17-83

EHD 539 (Revised: 6/82)

2B


110'
65'
110'
200'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

SIR. No. 15138

T.C. No. 111-124-22,23

DATE: June 24, 1983

Mr. C. H. McCorkle
Route 1, Box 90
Indian Trail, NC 28079

RE: Property located at: **Cedarbrook Road, Lots 26 & 27**

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a gravity actuated sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Soils classified as unsuitable may be utilized for soil absorption systems if sufficient engineering, hydrogeologic, soil and environmental information indicates that a suitable septic tank system or a suitable alternate system of approved design will function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications, in the form of plans and specifications, to be prepared by a registered engineer, must be reviewed and if it is found that the system may be expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreement Form" provided by this office.

If I may be of further assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH:ADS

Enclosure

Date Received 2/22/79

MECK COUNTY DEPARTMENT OF
RECEIVED
FEB 22 1979
ENVIRONMENTAL HEALTH

APT No. 15139
T. C. No. 111-124-22
Map Date 3/22/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Myers (LAST) Neil (FIRST) F (MIDDLE)

2) ADDRESS OF OWNER 2233 Birkdale Circle, N.C. ZIP 28269

3) PHONE NO. Home 334-9871 Office 333-5000 Wycliffe Drive - Suzanne Phillips


4) LOCATION OF PROPERTY Cedarbrook Dr. Rd 71 2012 (STREET OR COUNTY ROAD)

5) SUBDIVISION Cedarbrook Acres LOT NO 27 BLOCK NO. A

MAP BOOK NO 7 PAGE NO 141

6) DEED REFERENCE: DEED BOOK 1791 PAGE NO. 445

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Neil F. Myers
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

15138

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15139
T.C.NO. 111-123-22
MAP DATE 3/22/78
DATE March 20, 1979

NAME OF OWNER Myers, Nell P.

ADDRESS OF OWNER 2933 Park Road, Charlotte, N.C.

LOCATION OF LOT Cedarbrook Drive, Lot 27, Block A

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive
Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R Adkisson

John R. Adkisson, Environmentalist

EHD 999 (1/79)

Date Received 2/22/79

RECEIVED
FEB 22 1979
ENVIRONMENTAL HEALTH

APT No. 15138
T. C. No. 111-124-23
Map Date 3/22/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Myers (LAST) Nell (FIRST) P. (MIDDLE)

2) ADDRESS OF OWNER 2933 Park Rd. Charlotte, NC ZIP 28209

3) PHONE NO. Home 334-9871 Office 535-5500 Faye Rawls - Ranson Realty


4) LOCATION OF PROPERTY Cedarbrook Drive Rt. # 2816 (STREET OR COUNTY ROAD)

5) SUBDIVISION Cedarbrook Acres LOT NO. 26 BLOCK NO. F.

MAP BOOK NO 7 PAGE NO. 641

6) DEED REFERENCE DEED BOOK 1791 PAGE NO 443

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Nell P. Myers
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. [illegible] 15 134

(Ground Absorption Sewage Disposal)

OWNER: Neil P. Myers
ADDRESS: 2433 Parkhill
COUNTY: Charlotte, N.C. 28209
LOCATION OF SITE: Adairwood Drive

DATE REQUESTED:
PLAT NO.: 111-124-23, Lot 26A
LOT SIZE: 12,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-8% U	(S) PS 2-8% U	(S) 10-20% PS U	(S) PS 2-10% U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2-1 (U) clay	S PS 2-1 (U) clay	S PS 2-1 clay (U)	S PS 2-1 clay (U)
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS Massive U	S Massive PS (U)	S Massive PS (U)	S PS Massive (U)
4. SOIL DEPTH (In.)	(S) 48" PS U	S 40" PS (U)	S 24" PS (U)	(S) 48" PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) None PS U	(S) None PS U	(S) None PS U	(S) None PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Seasonal PS perched (U) water table	(S) 7 to 12 PS ground U water	(S) 7 to 12 PS ground U water	(S) 7 to 12 PS ground water U
7. SOIL PERMEABILITY (Percolation Rate)	S PS Slow (U)	S PS V. slow (U)	S PS slow → V slow (U)	S PS slow → V slow (U)
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	unsuitable
SOIL SERIES	Helena	Enon	Wilkes	Marshbrook

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)

Recommendations/Comments:

Described By: William R. Marlin

Title: Soil Scientist Date: 3-19-79

dhs form 2601 (1/79)
Sanitation


100
654'
693'
Helena
Helena
Zedlow Brook

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 15-139

(Ground Absorption Sewage Disposal)

OWNER: W. C. P. Myers
ADDRESS: 933 Park Rd.
COUNTY: Asheville, N.C. 28804
LOCATION OF SITE: Cedarbrook

DATE REQUESTED:
PLAT NO.: 111-124-22, 10733, Dk-6
LOT SIZE: 69,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2 8%	(S) PS U 2-15%	(S) PS U 10-25%	(S) PS U 2-10%
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS (U) 2:1 clay	S PS (U) 2-1 clay	S PS (U) 2:1 clay	S PS (U) 2-1 clay
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS (U) massive	S PS (U) massive	S PS (U) massive	S PS (U) massive
4. SOIL DEPTH (In.)	(S) PS U 48"	S (PS) U 48"	S (PS) U 24"	(S) PS U 48"
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) PS U None	(S) PS U None	(S) PS U None	(S) PS U None
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Seasonal PS perched (U) water table	(S) 7b to PS ground U water	(S) 7b to PS ground U water	(S) 7b to PS ground U water
7. SOIL PERMEABILITY (Percolation Rate)	S PS (U) V. Slow	S PS (U) slow to V. slow	S PS (U) slow to V slow	S PS (U) slow to v. slow
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable	Unsuitable	unsuitable
SOIL SERIES	Roland	Evard	Wilkes	Mayhew

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)

Recommendations/Comments:

Described By: William R. Marlin

Title: Soil Scientist Date: 3-19-79

dhs form 2601 (1/79)
Sanitation


69'
Enon
Holmes

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15138
T.C.NO. 111-124-23
MAP DATE 3/22/78
DATE March 20, 1979

NAME OF OWNER Myers, Nell P.

ADDRESS OF OWNER 2933 Park Road, Charlotte, N.C.

LOCATION OF LOT Cedarbrook Drive, Lot 26, Block A

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive
Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R Adkisson

John R. Adkisson, Environmentalist

EHD 999 (1/79)

Date Issued 9 July 77

Serial No. 2949


ICAR(S) Permit No. 15138

T. C. No. 111-124-22,23

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15138, dated May 9, 1977 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 9 October, after which date this permit shall be null and void.



PLOT OF SYSTEM

Agreement Form

Permeability Rate Modified System

Liquid Capacity of Tank 1500

Tank Construction _____

Absorption and/or Nitrification Lines

Total Line Length 750' ; 167'

Number of Lines 5 ; 4

Distance from House 10'

Distance from Property Line 10'

Distance from Well to be 100'

NAME OF OWNER Henry Heath McCorkle

LOCATION OF PROPERTY Cedarbrook Dr. lot 26 & 27

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

THE ISSUANCE OF THIS PERMIT DOES NOT IN ANY WAY GUARANTEE THAT THE SYSTEM ANTICIPATED TO BE CONSTRUCTED WILL OPERATE PROPERLY OR RELIEVE ANY PERSON NOW OR HEREAFTER OWNING, CONTROLLING OR USING SUCH SYSTEM FROM ANY LIABILITY RESULTING FROM THE FAILURE OF THE SYSTEM TO OPERATE PROPERLY.

Comments:

15'X150' 17" stone 2" sand

12'X4' w.m.

Division or Section Head

Steve Wood
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Specialist's Copy

SEE INSTRUCTIONS ON BACK

15138 2 [redacted] 1-5656

Date Received May 9, 1979

ICAR(S) Application No.

T. C. No. 111-124-22+23


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No

4) No of Bedrooms 4

5) Business Use -- Max No Employees ___

6) Washing Machine ✓ Yes ___ No

7) Garbage Disposal ___ Yes ✓ No

8) Dishwasher ___ Yes ✓ No

9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___

10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No

11) FHA Case No ___

12) VA Case No ___

13) NAME OF OWNER McCorkle (LAST) Henry (FIRST) Heath (MIDDLE)

14) ADDRESS OF OWNER Rt. 1 Box 316E Indian Trail, N.C.

15) PHONE NO. Home 882-1246 Office Same

16) LOCATION OF SYSTEM ✓ (STREET OR COUNTY ROAD) or revised 22+23

17) SUBDIVISION Cedarbrook Lot No. 26 + 27 Block No. A

Map Book No. 9 Page No. 641

18) DEED REFERENCE — DEED BOOK 4181 AT PAGE 0155

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.


___ (DATE OF APPLICATION)

H H McCorkle (OWNER)


EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

1-128-15427



5 drain pipe 150 long 3' on center 2250 sq foot bottom area.



Submitted for consideration and approval:

Cedar Brook
Lot 26427 A Rd
Property Location

H H McCabe
Owner's Signature

Bed System

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

BOOK PAGE

4181 0288

3849 X008 '79 May 23 PM 1 07

The undersigned, Henry Heath McCorkle, owner of property known as ___ Cedarbrook Drive, Lots 26 and 27 (T.C. 111-124-22 & 23), ("the property") described in instrument recorded in Book 4181 at Page 0155, Mecklenburg Public Records, hereby acknowledges that he applied to the Department of Environmental Health for a permit to install a septic tank sewage disposal system on the site; the Department evaluated the site for suitability for such a system in accord with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1900 et seq; that the Department classified the site as UNSUITABLE and an appropriate permit was issued by the Department.

'78

The undersigned further acknowledges that the proper design, construction and maintenance of said septic tank system is his responsibility and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time, or that the Department, its officials, employees or agents assume any liability for damages, consequential or direct, which are caused, or which may be caused, by a malfunction of such system.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed as herein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

And the undersigned further agrees for himself, his heirs and assigns, that he shall indemnify and hold harmless the Department and its successors, as well as Mecklenburg County, for any claim or other claims of any person or persons whatsoever arising out of the installation, operation, or failure, of said septic tank system.

And the undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately, in the opinion of the Department, he will take whatever measures are required to correct same; or if such is not possible, discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This 22 day of May, 19 79

Henry Heath McCorkle (Seal)

_____ (Seal)

STATE OF NORTH CAROLINA,
COUNTY OF MECKLENBURG

I, Hyromia M. Lynch, a Notary Public for said County and State, do hereby certify that Henry Heath McCorkle, personally appeared before me this day and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 22 day of May, 19 79.

Hyromia M. Lynch
Notary Public

My Commission Expires: 2-2-82

STATE OF NORTH CAROLINA,
COUNTY OF _____

I, _____, a Notary Public for said County and State, do hereby certify that _____ personally came before me this day and acknowledged that he is _____ Secretary of _____, and that by authority duly given and as the act of said corporation, the foregoing instrument was signed in its name by its _____, sealed with its corporate seal and attested by _____ as its _____ Secretary.

WITNESS my hand and notarial seal, this _____ day of _____, 19 ___.

_____

PRESENTED FOR REGISTRATION
MAY 23 PM 1:07
REGISTER OF DEEDS
MECKLENBURG CO., N.C.

Return By Mail To:
City County Health Dept.
1200 Blythe Blvd.

BOOK PAGE

4181 0287

State of North Carolina, County of Mecklenburg
The foregoing certificate(s) of Wyvenaia M. Efird,

a Notary(~~Notaries~~) Public of Union County and State of N. C.
is ~~are~~ certified to be correct. This 23 day of May, 19 79
Charles E. Crowder, Register of Deeds, By: Wanda B. Adams
DEPUTY

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 31 1979
ENVIRONMENTAL HEALTH

1.00
3.00
4.00

Serial No. 3099

LA No. 15138

Date Issued May 29, 1979

T. C. No. 111-124-22 & 23

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER McCorkle, (LAST) Henry (FIRST) Heath (MIDDLE)

ADDRESS OF OWNER Route 1, Box 316-E, Indian Trail ZIP 28079

LOCATION OF LOT Cedarbrook Drive, Lots 26 and 27 (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 26 & 27 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 15138. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

******AGREEMENT FORMS SIGNED AND PLACED ON RECORD****

Environmentalist

John R. Hussar

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Issued 21 Jul 83

Serial No. 6466


ICAR(S) Permit No. 15138

T. C. No. 111-124-23/23

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15138, dated 7 Jul 83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 21 Aug 83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate _____

Liquid Capacity of Tank 1500

Tank Construction RC

Absorption and/or Nitrification Lines

Trench Length 250'

Number of Lines 6 (3 @ 3)

Distance from House >5'

Distance from Property Line >10'

Distance from Well >50'

NAME OF OWNER McCuddie, Henry Keith

LOCATION OF PROPERTY 8109 Tuckaseegee Rd. (Lot 26 #27)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly

6 trenches - 3 trenches - 3' X 125' X 12" rock + 2" sand

Comments: 3 trenches 3' X 125' X 12" rock + 2" sand
1 diversion valve

Division or Section Head

W. A. Kirby
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

BI 8-9-83
C of A (s) No. 15138

Date Issued 8 Aug 83 Serial 6027 T. C. No. 111-124-23/23

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner McCorkle, Henry H
LAST FIRST MIDDLE

Location of Property Cedarbrook Rd. (SR 2647)

Application Number 15138 Permit Number 15138

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 950' Number of Lines 6 (3 & 3)

Depth of Filter Material 12" + 2" sand Cover Depth 12-15"

Water Supply Source Well Distance from Water Source >100'

Excavation Inspected 8 Aug 83 DATE Tank Inspected 5 Aug 83 DATE

Nitrification Field Inspected 5 Aug 83 DATE

Washing Machine Line Inspected, If Applicable ____ DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: 6 trenches - 3' X 125' X 12" rock + 2" sand.
Set of 3 trenches divided by diversion valve

M. D. Busby
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY