

9411 BRENDA ANN RD

11316305

7/13/2007

duponbj


Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7867A DATE: 11/5/92
TC: 113-163.07 ☒ L
SERIAL Nº 13535

Permission is hereby given to ___ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 12/2/91. All work shall be completed on or before 2/5/92, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons
Liquid Capacity of Dosing Tank ___ gallons
Tank Construction PVC

Absorption and/or Nitrification Lines:
Trench Width 3 feet
Total Line Length 400 feet
Number of Lines WASHER (2) 3'x70' SEPTIC (3) 3'x90'
Depth of Stone 12 inches
Distance from House 5 feet
Distance from Property Line 10 feet
Distance from Well 150' feet

NAME OF OWNER John D. Warren
LOCATION OF PROPERTY 9411 Brenda Ann Road
Comments: Install (3) Trenches 3'x90', 12" Stone
(2) Trenches 3'x70', 12" Stone - (For WASHER)

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7867A DATE: 11/25/92

TC: 113-163-07 ☒ L ☐ CRT

SERIAL Nº 15603

Name of Owner John D. Warren Juris.:

Address of Property 1411 Brenda Ann Rd

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400

Number of Lines (2) 3 x 70' wash (3) 3 @ 90'

Cover Depth 24"

Water Supply Source well


Distance to Water Source ≥ 100'

Excavation Inspected 11/25/92

Tank(s) Inspected 11/25/92

Wash Line Inspected

High Water Alarm Inspected



Design: 1992, 1500ST, Cm. 1230SFT, 12"s, Cecil CTR# 57

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ Installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 3 bedroom home

Type II System

420SFT = Washer - 810SFT = Septic

Judy J. Kerr R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

SP · CRT · RC · DW #409 7867A 12/23/91 1587 # 200

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

[ ] CRT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

PERSON FILING APPLICATION:

NAME: WARREN (last) JOHN (first) D (mi)

ADDRESS: 520 E. TRADE PHONE: (704) 377-3637

CITY: CHARLOTTE, STATE: NC ZIPCODE: 28202

Date: 12-26-91

PROPERTY OWNER:

NAME: _____ (last) _____ (first) _____ (mi)

ADDRESS: _____ PHONE: (__) _____

CITY: _____ STATE: _____ ZIPCODE: _____

PROPERTY INFORMATION
(FROM ENGINEERING FORM):

TAX/PARCEL NUMBER: 113-163-06 PO

STREET ADDRESS: 9411 BRENDA LN MECKLENBURG CO

ZONING: R-12

SUBDIVISION OR MOBILE HOME PARK NAME:

Township (check one):
[X] 0 Mecklenburg County [ ] 2 Davidson [ ] 4 Pineville [ ] 6 Huntersville
[ ] 1 Charlotte [ ] 3 Cornelius [ ] 5 Matthews [ ] 7 Mint Hill

LOT NUMBER: 066 1/2 07 LOT SIZE (in acres): .52

TYPE APPLICATION (check one):

[ ] SOIL TEST - INDIVIDUAL LOT (D)
[X] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[ ] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[ ] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[ ] COMMERCIAL OR INDUSTRIAL (N)
[ ] SOIL TEST DEVELOPMENT (P)
[ ] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[ ] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[ ] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[ ] SINGLE MOBILE HOME (S) [X] HOUSE (H) [ ] MULTIPLE FAMILY (U)
[ ] DOUBLE WIDE (D) [ ] MODULAR HOME (M) [ ] OTHER _____ (O)

NUMBER BEDROOMS: 3 NUMBER OCCUPANTS:

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[ ] Community (C) [ ] Shared Well (S)
[ ] Municipal (M) [ ] Other 'spring' (O)
[X] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
[ ] Swimming Pool [ ] Jacuzzi [ ] Stable/Barn [ ] Workshop [ ] None
[ ] Garage [ ] Storage Building [ ] Deck/Patio [ ] Bedrooms [ ] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: [signature] Date: 12-26-91

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair permit is issued by this Department.

...This permit is not transferable.

...Approved per plot plan

[X] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[ ] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[ ] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

[signature] R.S. 1/28/92
Environmentalist Date

[signature] 1-29-92
Director or Authorized Section Head Date

WWATER : 112991

PROPOSED PLOT PLAN


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7867A

TC: 113-163-06

9411 BRENDA ANN RD

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



SITE PLAN
1" = 40'


1500 gallon Septic TANK
400' drain field
Septic = 750'
Water = 140'
Total = 890'

1/23/92

APPROVAL DATE

NEW DRAWING 1/21/92
L. HOBBS 559-8089

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy



Mecklenburg County
Health Department

November 29th, 1991

Daniel Hydrick Porter
8620 Wilkinson Boulevard
Charlotte, NC 28214

RE: Property located at 9411 Brenda Ann Road 6
FILE: 7867A
PARCEL: 113-163-06PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 12365) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Kelly Randall for Gene Vaughan

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure (2)


MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER [illegible]

File: 7867A Action _____

Parcel: PO 113-163-06 PC

Location: 7411 Brenda Lynn Rd
Subdivision: Berryhill's Park
Lot: 6 Block: Acres: .34
Owner: [illegible]
Address: [illegible] Whitehorn Blvd
Charlotte, N.C. 28214
Comments: Drilled septic well

Described by: William R. Martin
Date: 11-27-91



***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S PS U (S) 6-12%	S PS U (U) Depression	S PS U	S PS U	S PS U	S PS U
Texture	S PS U (PS) Sl. bri. y FA	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S PS U (PS) 2-3 Sub Inches	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	S PS U (S) Well drained	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	S PS U (S) 48"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S PS U (S) 48"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S PS U (U) Restricted	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-Lloyd	Depression				
Area Classification	S PS (U)	S PS (U)	S PS U	S PS U	S PS U	S PS U

Mecklenburg County
Health Department

November 29th, 1991

Daniel Hydrick Porter
8620 Wilkinson Boulevard
Charlotte, NC 28214

RE: Property located at 9403 Brenda Ann Road 7
FILE: 7868A
PARCEL: 113-163-05PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 12366) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Keely Randall for Gene Vaughan

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure (2)

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12330

File: 18 6817 Action _____

Parcel: 20113-16305 ☑ PC

Location: 4403 Brenda Ann Rd

Subdivision: Berryhill Park


Lot: 7 Block: Acres: .34

Owner: Daniel H. Porter
Address: 8620 Wilkinson Blvd
Charlotte, N.C. 28214

Comments: Private spring well

Described by: William R. Machin

Date: 11-27-91



*** EVALUATION KEY ***

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 6-15%	S PS (U) complex slopes	S PS (U) Depression	S PS U	S PS U	S PS U
Texture	S (PS) U slightly Expansive clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U slight	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	(S) PS U Fair to	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	(S) PS U 72"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	(S) PS U 72"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	III Cec. 1-1.4c	Complex slopes	Depression			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPO RT
SERIAL NUMBER

File: [illegible] Action _____

Parcel: [illegible] ☐ PC

Location: [illegible]

Subdivision: [illegible]


Lot: [illegible] Block: Acres: [illegible]

Owner: [illegible]
Address: [illegible]

Comments: [illegible]

Described by: [illegible]

Date: [illegible]



***** EVALUATIC N KEY *****

S = *Suitable* U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" belov indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	[illegible]	[illegible]	[illegible]			
Area Classification	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U

Mecklenburg County
Health Department

November 29th, 1991

Daniel Hydrick Porter
8620 Wilkinson Boulevard
Charlotte, NC 28214

RE: Property located at 9411 Brenda Ann Road 6
FILE: 7867A
PARCEL: 113-163-06PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 12365) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Kelly Kimball Per Gene Vaughan

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure (2)

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12365


File: 1867A Action 2

Parcel: 80 113-163-06 ☑ PC

Location: 9411 Brenda Ann Rd
Subdivision: Berryhill Park
Lot: 6 Block: Acres: .34
Owner: Daniel H. Porter
Address: 8620 Wilkinson Blvd
Charlotte, N.C. 28214

Comments: Would require well

Described by: William R. Martin
Date: 11-27-91



***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-12%	S PS (U) Depression	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Slight Expansive clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Slight Blocky	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	(S) PS U 48" to water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	(S) PS U 48"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	(S) PS U 48"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-Lilo	Depression				
Area Classification	S PS (U)	S PS (U)	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

Ck # 1547
$150.00
11/20/91

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)
FILE: 7867A
TC: 113-163-06
☑ PC ☐ REPT


JOB LOCATION

① ADDRESS: 9411 BRENDA ANN RD.
② SUBDIVISION: BERRY HILL PARK ③ LOT: 6 ④ BLOCK:
⑤ PARCEL REFERENCE: BOOK NO.: PAGE NO.: PARCEL NO.:
⑥ DEED REFERENCE: BOOK NO.: PAGE NO.:

OWNER

⑦ NAME: DANIEL (FIRST) HYDRICK (MIDDLE) PORTER (LAST)
⑧ MAILING ADDRESS: 8620 WILKINSON BLVD
⑨ CITY: CHARLOTTE ⑩ STATE: N.C. ⑪ ZIP: 28214
⑫ PHONE: (WORK) 394-6319 (HOME) 394-5066

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: [signature]

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 11-20-91

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE 11/20/91

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Meck

PARCEL NUMBER # 113-163-06

ASSIGNED ADDRESS 9411 Brenda Ann RD

EXISTING ADDRESS _____

PROJECT NAME NA

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	DISAPPROVED
1. SUBDIVISION REGULATIONS	/ /	/ /*
2. FLOODWAY REGULATIONS	/ /	/ /*
3. EROSION CONTROL REGULATIONS	/ /	/ /*
4. PUBLIC UTILITY EASEMENT	/ /	/ /*

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	/ /*	/ /
6. PROPERTY FRONTS ON THOROUGHFARE	/ /*	/ /
7. DRIVEWAY PERMIT REQUIRED	/ /*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: Pink Dest

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: Bill

OPWEAR 06-88

NEW ADDRESS / /*

FORM 100

LAWS AND RULES FOR SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL
10 NCAC 10A. 194B (c)

Sites originally classified as UNSUITABLE may be used for soil absorption disposal systems, provided engineering, hydrogeologic, and soil studies indicate to the local health department that a suitable septic tank system or a suitable alternate system can reasonably be expected to function satisfactorily. Such sites may be reclassified as PROVISIONALLY SUITABLE upon submission to the local health department and when requested by the local health department to the state agency of the following:

(1) Adequate substantiating data to indicate that a ground absorption system can be installed so that the effluent will receive adequate treatment;

(2) Adequate substantiating data to indicate that the effluent will not contaminate any drinking water supply, ground water used for drinking water, or any surface water;

(3) Adequate substantiating data to indicate that the effluent will not be exposed on the ground surface or be discharged to surface waters where it could come in contact with people, animals, or vectors.