Pre-preliminary letter dated 6/12/79

Date Received 7/16/79

APT No. 15877

T. C. No. P.O. 011-41-02

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Mady Construction Company
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 3549 N. Sharon Amity, Suite 303, Charlotte ZIP 28205

3) PHONE NO Home _____ Office 568-7740


4) LOCATION OF PROPERTY Westmoreland Rd. (S.R. 2430)
(STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 2 BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mady Construction E Shamberg
OWNER

EHD-5-76

Environmental Health Department's Copy

Pre-preliminary letter dated 6/12/79

Date Received 8/1/79

APT No. 15897

T. C. No. p.o. 011-41-02

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Mady Construction Company
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 3549 N. Sharon Amity, Suite 303, Charlotte 28205

3) PHONE NO Home _____ Office 568-7740


4) LOCATION OF PROPERTY Westmoreland Rd. (S.R. 2430)
(STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 2 BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mady Construction, Co.
Ronnie Schainberg
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

S. I. R. NO. 15897

T. C. # PO 011-41-02

(Ground Absorption Sewage Disposal)

OWNER: MADY Const. Co.
ADDRESS: 3549 N. Shamrock Mnty Suite 303
COUNTY: Charlotte 28205
LOCATION OF SITE: Westmoreland RD Lot #2

DATE REQUESTED: 8-1-78
PLAT NO.:
LOT SIZE: 1.58A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-10	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy clayey. Note 2 1 Clay)	S (PS) U — Clayey	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) U — Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U — 48	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata Rock)	(S) PS U — NONE	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S (PS) U — Adequate	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U — Moderate	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Provisionally Suitable			

SOIL SERIES: Cecil

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments:

Described By: W. B. Ramsey

Title: Soil Scientist Date: 8-7-79

DHS Form 2601
Sanitation
EHD 539 (3/79)


Westmoreland Rd
162
Cecil
2-10
240
237
110

Serial No. 3023

PTR No. 15897

T. C. No. po 011-041-02

Date Issued August 8, 1979

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Mady Construction Company (LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 3549 N. Sharon Amity, Suite 303 ZIP 28205

LOCATION OF PROPERTY Westmoreland Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO #2 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions

1. A permit to install, construct, alter or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank and treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction, including the drilling of a well, is performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

W. B. Ramsey
Soil Scientist

John P. Atkinson
Environmental Health Director or Authorized Section Head

EHD-5-7a

Environmental Health Department's Copy