Date Received 6-10-74

APT No 8090

T. C. No 001-231-04E

Map Date 4 19 74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Boyd, Eugene R
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 6200 Sharon Rd ZIP 28210

3) PHONE NO Home 366-3172 Office 525-4887


4) LOCATION OF PROPERTY SR 2154 - Lake Norman off Jetton RD.
(STREET OR COUNTY ROAD)

5) SUBDIVISION Duke Power Lease LOT NO 202 Section BLOCK NO 2

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER Eugene R Boyd

FORM No. [illegible]

HEALTH DEPARTMENTS [illegible]

Serial No. 4476

PTR No. ~~8090~~ 4543

Date Issued June 19, 1974

T C No. ~~001-331-030~~ 001-231-04e

Map Date 4-19-74

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Boyd (LAST) Eugene (FIRST) F. (MIDDLE)

ADDRESS OF OWNER 4209 Charon Road ZIP 28210

LOCATION OF PROPERTY off Jetton Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 302 BLOCK NO Section 2



PLOT PLAN

This is to certify that a percolation test has been run and an on site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 55 min/in. The said lot is approved for the installation of an individual septic tank sewage treatment system with subsurface final absorption effluent discharge subject to the following terms and conditions:

1. A permit to install the system applied for herein may be obtained from the Mecklenburg County Health Department provided the lot is in accordance with the site plan approved hereon and other on the said lot
2. The size of the system to be installed shall be determined by the Health Department on the basis of the number of bedrooms or living units and type of building constructed thereon.
3. The system shall be installed in the area(s) and within the limits indicated on the lot which was run.
4. The system shall be installed in accordance with the site plan approved hereon and on the lot which is in accordance with the rules and regulations governing the installation of such systems.

This approval is granted pursuant to the laws of the State of North Carolina and the rules and regulations of the Board of Health of the Mecklenburg County Board of Health which were in effect on the date of issuance of this approval. In the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Richard Forshee

John W. Hickman

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-9-1-72

H

Date Received 1-3 74

MECK. COUNTY HEALTH DEPT.
SEE INSTRUCTIONS ON BACK
RECEIVED
1974


ICAR(S) Application No 8090 [illegible]
T C No 001-231-04E
Map Date 4/9 74

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of the property described hereafter hereby applies to the Mecklenburg County Health Department for a permit t

1) [X] Install or Construct 2) [ ] Alter or Repair an individual septic tank wastewater treatment system with a sub-surface soil absorption, effluent discharge



3) PLOT PLAN AS ACCURATELY DIMENSIONED

4) Type of Building 28K Mobile Home
Bedrooms
Water Supply X Yes
Garbage Disp. Yes X No
Dishwasher Yes X No
Automatic Washer X
Yes X No
Yes X No

13) NAME OF OWNER Boyd, Eugene Kowland
14) ADDRESS OF OWNER 6600 Sharon Rd, Charlotte NC 28210
15) PHONE NO. Home 366-6277 Office 525-4687
16) LOCATION OF SYSTEM Sutton Ln (SR 2451) - LaLe Norman
STREET OR COUNTY R/W
17) SUBDIVISION Dutchtown Estates Lot No 302 Block No 2
Map Book No Page No
18) DEED REFERENCE - DEED BOOK AT PAGE PR 755
19) HAS A PERCOLATION TEST BEEN RUN? YES NO DATE RUN 6-13 74
20) PIN Number Section [illegible] 58 9C

The [illegible] hereby [illegible] that he has read the foregoing application and that the contents [illegible] are true to the best [illegible] that any permit applied for herein shall be void and of no effect if any of the above facts are not true

2 July 1974
DATE OF APPLICATION

E K Boyd
OWNER

E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 8-27-74 Serial No. 4394

LA No. ~~8090~~ 4543

T. C. No. 001-231-03P, 001-231-04C

Map Date 4-19-74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Boyd (LAST) Eugene (FIRST) R. (MIDDLE)

ADDRESS OF OWNER 6200 Sharon Road ZIP 28210

LOCATION OF LOT off Jetton Road (STREET OR COUNTY ROAD)

SUBDIVISION ____ LOT NO 302 BLOCK NO Section 2

MAP BOOK NO ____ PAGE NO ____

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 55 min/in and the inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" number 8090. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed altered, and/or repaired in the same area where the percolation test was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Environmentalist

Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 9 Aug 74

Serial No. 5567

ICAR(S) Permit No 8090

T C No 001-231-01C

Map Date 4-19-74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby granted to Install or Construct Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 8090 dated 7-3-74. If this permit is not used and is not effective the system shall be installed in the application as approved. All work shall be completed on or before 9 Sept 74, after which date this permit shall be considered void.



Septic Tank Size 5-5

Liquid Capacity of Tank 1000

Type of Material PC

Absorption Area Information

Total Length 450

Number of Lines 6 (15' x 75' x 17")

Distance Between Lines 10'

Distance from Lines 10'

Distance from Well 100'

NAME OF OWNER Boyd, Eugene K.

LOCATION OF PROPERTY Jetton Rd

This permit is issued subject to requirements as set forth in the Regulations of the Mecklenburg [illegible] eighty days from the date of the approval of the system. A certificate of op[illegible] Director before any system can be [illegible] otherwise rendered un[illegible]

Comments (Ballard Grading) aeration pit 2½' x 7' x 4½' Stone

Environmentalist

This permit is issued subject to the conditions set forth in the Regulations governing the division or o[illegible] Health Code. This permit is void unless signed by the signature of the Environ[illegible] existing system is being altered or replaced.

E-5-9-1-72

Serial No. 5174

C of A (s) No. 8090 14543

Date Issued 20 Aug 74

T C No. 001-231-046

Map Date 4-19-74

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Boyd, Eugene L (LAST, FIRST, MIDDLE)

Location of Property Jetton Rd

Application Number 8090 Permit Number 2020

Inspection Data:

Liquid Capacity of Tank 1000 gal Tank Material PC

Total Length of Drain Tile 450' Number of Lines 6 (15' x 75' x 17")

Depth of Filter Material 17" Cover Depth 5"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 20 Aug 74 (DATE) Tank Inspected 20 Aug 74 (DATE)

Nitrification Field Inspected 20 Aug 74 (DATE)

Washing Machine Line Inspected If Applicable _____ (DATE)

This is to certify that the Individual Septic Tank System with subsurface, soil absorption, effluent discharge has been installed and has been inspected and constructed in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health at the time of issuance of the permit. The issuance of this Certificate of Approval is not a guarantee that the system will operate properly or relieve any person now or hereafter owning or using such system from any liability resulting from the failure of the system to properly function. This Certificate of Approval is issued subject to the restrictions and conditions noted in the permit in addition to those listed below under comments. This Certificate of Approval is void and of no effect if information contained in the application is not correct or if any additions are made to the property which would increase the requirements for said system.

Comments Aeration pit 2½' x 4' x 7' 9" deep (Ballard Contractors)

Environmentalist

FORM NO E-6-9-1-72

SEE INSTRUCTIONS ON BACK

Date Received 9/28/84

ICAR (S) Application No. 14543

T. C. No 001-351-03B


Map Date 12-21-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to Changing from mobile home to residential residence

1) Install a Construct a 2 X Alter a Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN ACCURATELY DIMENSIONED

- Mobile Home Yes ___ No
- Residence X Yes ___ No
- 4) No. of Bedrooms 3
- 5) Water Use Min. No. Employees ___
- 6) Municipal Water X Yes ___ No
- 7) Public Sewer X Yes ___ No
- 8) Septic Tank X Yes ___ No
- 9) Water supply
  - Public Water ___ X
  - Community System ___
  - Individual System ___
  - Well ___
  - Spring ___
  - Cistern ___
- Any public water supply source within ___ feet Yes ___ X No
- Any well, spring or cistern within 75 feet of proposed system Yes ___ X No
- Any surface water within ___ feet ___
- Any other ___

10) NAME OF OWNER BOLD, LAURENT KOWLAND (LAST, FIRST, MIDDLE)

11) ADDRESS OF OWNER Lt 2 Griffith Huntersville NC 28078

12) PHONE NO. Home 892-6252 Office 525-4887

13) LOCATION OF SYSTEM Griffith Rd (SR 2151) Lake Norman (STREET OR STATE NO. ROAD)

14) SUBDIVISION Lot 2 Block No. 2

Map Book No. ___ Page No. ___

15) DEED REFERENCE DEED BOOK ___ AT PAGE ___

16) TAX MAP REFERENCE ___ PARCEL NO. ___ DATE RUN ___

17) PRESENT USE ___

The undersigned owner or authorized agent hereby states that he has read the foregoing application and that the contents of same are true to the best of his knowledge and belief and that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION ___ OWNER [signature]

Environmental Health Department's Copy

Date Issued September 18, 1978 Serial No. 2226

LA No. 14543

T. C. No. 001-331-03B

Map Date 12-21-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Boyd (LAST) Eugene (FIRST) Rowland (MIDDLE)

ADDRESS OF OWNER Route 2, Box 570C, Huntersville, NC ZIP 28078

LOCATION OF LOT Jetton Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 302 BLOCK NO. Section 2

MAP BOOK NO. _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 14543. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a said Installation, Construction, Alteration, and/or Repair Permit.

Marshall Edwards
Environmentalist

John R. Abusaion
Environmental Health Director, or Authorized Section Head

Rev. 5-78

Environmental Health Department's Copy


Date Issued 7-3-79 **Serial No. 2867** ICAR(S) Permit No. 14543

T. C. No. 001-331-03B

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 14543, Dated 9-18-78 and this permit shall be void and of no effect if the information provided in the application is not true and correct in all respects. All work shall be completed on or before 10-3-79, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate: PS

Type of Construction: —

Type of Operation: —

Absorption Area: Trench Type

Trench Length: 125'

Number of Lines: 4

Distance Between Lines: 10'

Distance From Lines: 10'

Distance From Well: 100'

NAME OF OWNER: Boyd, Eugene Rowland

LOCATION OF PROPERTY: Sutton Road

This permit is issued subject to compliance with Section 18 of the Regulations of the Mecklenburg County Board of Health governing the disposal of sewage. This permit authorizes construction only. A certificate of approval will be issued upon satisfactory completion of the work authorized by this permit. The system may not be covered up or otherwise rendered inaccessible for inspection until approved.

THE ISSUANCE OF THIS PERMIT DOES NOT IN ANY WAY GUARANTEE THAT THE SYSTEM AUTHORIZED HEREIN WILL BE CONSTRUCTED OR WILL OPERATE PROPERLY OR RELIEVE ANY PERSON NOW OR HEREAFTER OWNING, CONTROLLING OR USING THE SYSTEM FROM ANY LIABILITY RESULTING FROM THE FAILURE OF THE SYSTEM TO OPERATE PROPERLY.

Comments:

12" x 30" Trench

Date: 7-3-79 Environmentalist: Michael A Sexton

* If this permit is for the location or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required when an existing system is being altered or repaired.

EHD-1 76

Yellow - Applicant's Copy White - Department's Copy

Date Issued 7-5-79 Serial No. 2822 C of A (s) No. 14543 ✓

T C. No. 001-331-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION
CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Boyd (LAST) Eugene (FIRST) Rowland (MIDDLE)

Location of Property 16921 JeHon Road

Application Number 14543 Permit Number 14543

Inspection Data:

Liquid Capacity of Tank — Tank Material —

Total Length of Drain Tile 125' Number of Lines 4

Depth of Filter Material 17" Cover Depth 15"

Water Supply Source well Distance from Water Source 75'

Excavation Inspected — (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected — (DATE)

Washing Machine Line Inspected, If Applicable 7-5-79 (DATE)

The above signed has inspected the Individual Septic Tank System with subsurface, soil absorption/effluent discharge as described above and it has been installed or constructed, ✓ in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect at the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown in the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 92' from the lake

Michael O. Sexton
Environmentalist

EHD-S-76

Environmental Health Department's Copy