Date Received 6/25/79

APT No. 15832

T. C. No. 193-021-14

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER PAPPAMINIEL (LAST) STEVE (FIRST) C (MIDDLE)

2) ADDRESS OF OWNER 1040 REGENCY RD CHARLOTTE NC ZIP 28211

3) PHONE NO Home 364-3443 Office 536-4308

4) LOCATION OF PROPERTY MARGARET WALLACE RD NEXT TO BOLE BAPTIST CHURCH
(STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO 14 BLOCK NO 71

MAP BOOK NO 193 PAGE NO 7

6) DEED REFERENCE DEED BOOK PAGE NO

MR. PAPPAMINIEL IS OUT OF TOWN OFFER IF ANY QUESTION PLEASE CONTACT MR GEORGE HATTRICH OFFICE 545-9763 OR 875-1123 HOME.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the ... investigation of the lot hereinabove described for the purpose of ... the feasibility of the installation of ... septic tank sewage treatment ... and subsequent disposal.

Copy to: 9600 Idlewild Rd (28212)

7) ACCURATE DIAGRAM & DIMENSION

Steve C Pappaminiel
By George C. Hattrich
OWNER

EHD 3-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

15832
193-071-14

(Ground Absorption Sewage Disposal)

OWNER: STEVE PAPPAMINIEL DATE REQUESTED: 6-25-79
ADDRESS: 1040 Regency Rd PLAT NO.:
COUNTY: Mecklenburg 28211 LOT SIZE: 150,000
LOCATION OF SITE: MARGARET WALLACE RD

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-20 U	S (PS) 2-10 U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2-1 (U)	S PS 2-1 (U) Clay	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Massive (U)	S PS Massive (U)	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS >48 (U)	S PS >48 (U)	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S PS Rock (U)	S PS Rock (U)	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS Slow (U)	S PS Slow (U)	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS Slow (U)	S PS Slow (U)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	Unsuitable		
SOIL SERIES	ENON	ENON		


S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: This LAND IS Eroded Down To Within A Foot Of Hard Rock over most Of The surface.

Described By: W.B. Ramsey
Title: Soil Scientist Date: 7-6-79

DHS Form 2601 (2/77)
Sanitation


300
ENON
2-10
480
522
ENON
10-20
290
MARGARET WALLACE RD

#325

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15832
T.C.NO. 193-071-14
MAP DATE
DATE 7/10/79

NAME OF OWNER Pappaminiel, Steve C.

ADDRESS OF OWNER 1040 Regency Road Charlotte, NC 28211

LOCATION OF LOT Margaret Wallace Road Lot No. 14, Block No. 71

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Texture unsuitable	Restrictive Horizons unsuitable
Soil Structure unsuitable	Soil Drainage/Groundwater unsuitable
Soil Depth unsuitable	Soil Permeability unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R Adkisson

John R. Adkisson, Environmentalist

EHD 999 (1/79)

R