Date Received 3/6/79

APT No. 15177

2 T. C. No. PO 231-101-05

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Smith-Allen Company, Inc. (LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 5511 Monroe Road ZIP 28212

3) PHONE NO Home _____ Office 568-5517


4) LOCATION OF PROPERTY Quilting Road (STREET OR COUNTY ROAD)

5) SUBDIVISION Hearthstone LOT NO 8 BLOCK NO 3

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Wally L. Allen, Jr.
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 15177

(Ground Absorption Sewage Disposal)

OWNER: Smith Williamson Const.
ADDRESS: 5511 Monroe Rd.
COUNTY: Charlotte, N.C. 28212
LOCATION OF SITE: Building Road

DATE REQUESTED:
PLAT NO.: PC 231-101-C5, Lot 6, Block 3
LOT SIZE: 25,166

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	(S) PS U 2-6%	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S (PS) U Clay	S (PS) U Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS U 40"	(S) PS U 48"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) PS U None	(S) PS U None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS ground U water Zero To	S Depressed PS Drainage (U) Wet Area	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U Moderate	S (PS) U Moderate	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Provisionally Suitable	Unsuitable		
SOIL SERIES	Cor./	Cor./ Drainage way		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)

Recommendations/Comments:

Described By: William G. Travis

Title: Soil Scientist Date: 3-27-79

dhs form 2601 (1/79)
Sanitation

Serial No. 2656

PTR No. 15177

T. C. No. po 231-101-05

Date Issued April 2, 1979

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Smith-Allen Company
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 5511 Monroe Road, Charlotte ZIP 28212

LOCATION OF PROPERTY Quilting Road
(STREET OR COUNTY ROAD)

SUBDIVISION Hearthstone LOT NO 8 BLOCK NO 3



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plat. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well is performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.


William A. Mullen
Soil Scientist

John R. Adkinson
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

R


145'
Earth
2.0%
Drainageway
210'
95'
Earth 2:1
Existing
Grade
160'
Quitman Rd

SEE INSTRUCTIONS ON BACK

Date Received 4/13/79

ICAR(S) Application No 15177

T. C. No. PC 231-101-05

Map Date _____


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.

3) PLOT PLAN (ACCURATELY DIMENSIONED)



4) Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4. No. of Bedrooms 4
5. Business Use — Max No Employees ___
6. Washing Machine ✓ Yes ___ No
7. Garbage Disposal ✓ Yes ___ No
8. Dishwasher ✓ Yes ___ No
9. Water Supply
A. Individual Well ___
B. Governmental System ___
C. Community System
1. Well source ✓
2. Governmental source ___
10. Sewage System
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No
11. FHA Case No ___
12. VA Case No ___

13) NAME OF OWNER Sorrell Builders Co., Inc.
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 5511 McAree Rd. Charlotte N.C. 28212

15) PHONE NO Home _____ Office 568-5517

16) LOCATION OF SYSTEM 3119 Quilting Rd.
STREET OR COUNTY ROAD

17) SUBDIVISION Hearthstone Lot No. 8 Block No. 3

Map Book No. 19 Page No. 29

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES ___ NO DATE RUN 4/7/79

20) PTR NUMBER (See Instructions) 15177

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

April 12, 1979
DATE OF APPLICATION

Charles L. Allen Jr.
OWNER

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 2911

LA No. 15177

Date Issued April 13, 1979

T. C. No. po 231-101-05

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Smith-Allen Co.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 5511 Monroe Road Charlotte, N.C. ZIP

LOCATION OF LOT 3119 Quilting Road
(STREET OR COUNTY ROAD)

SUBDIVISION Hearthstone LOT NO. 8 BLOCK NO. 3

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 15177. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction Alteration, and/or Repair Permit

Sanitarian

John R Adkisson
Environmental Health Director or Authorized Section Head

EHD-5-78

Environmental Health Department's Copy

R


Date Issued 1 Oct 79 Serial 3263 ICAR (S) Permit No. 15177

T. C. No. 231-101-05

Map Date ____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15177, dated 4/13/79 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 1 Nov., after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate P.S.

Liquid Capacity of Tank 1500 gal

Tank Construction F.C. Conc.

Absorption and or Nitrification Lines

Total Line Length 660' & 167'

Number of Lines 4 & 4

Distance from House 10'

Distance from Property Line 10'

Distance from Well Conc.

NAME OF OWNER Smith Allen

LOCATION OF PROPERTY 3119 Quilting Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Division or Section Head

Environmentalist Steve Wood

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

SEE INSTRUCTIONS ON BACK

Date Received 3/16/83 MAR 18 1983

ICAR(S) Application No. 15177

T. C. No. 231-104-08


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) X Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence X Yes ___ No

4) No. of Bedrooms 4
5) Business Use — Max No Employees ___
6) Washing Machine X Yes ___ No
7) Garbage Disposal X Yes ___ No
8) Dishwasher X Yes ___ No
9) Water Supply
A) Individual Well ___
B) Governmental System ___
C) Community System:
1. Well source X
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes X No
House located within 200 feet of community sewer ___ Yes X No
11) FHA Case No ___
12) VA Case No. ___

13) NAME OF OWNER Brown Kenneth Richard
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 3119 Quiet Lake Rd Matthews NC 28105

15) PHONE NO. Home 847-1365 Office 588-2340

16) LOCATION OF SYSTEM Same
STREET OR COUNTY ROAD

17) SUBDIVISION Heathstone Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

3/16/83
DATE OF APPLICATION

K R Brown
OWNER

BHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial 3283

C of A (s) No. 15177

Date Issued Copy

T C. No. 231-101-05

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Smith Allen Company
LAST FIRST MIDDLE

Location of Property 3117 Quisling Rd

Application Number _____ Permit Number 15177

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material R.C. Conc.

Total Length of Drain Tile 66' 44' Number of Lines 4, 4, (4)

Depth of Filter Material 17" Cover Depth 12"

Water Supply Source Drilled Distance from Water Source 70'

Excavation Inspected — DATE Tank Inspected Oct DATE

Nitrification Field Inspected — DATE Oct

Washing Machine Line Inspected, If Applicable Oct DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ___ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments _____

Environmentalist

EHD-5-76

Environmental Health Department's Copy

SEE INSTRUCTIONS ON BACK

Date Received 5-3-82

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 03 1982
ENVIRONMENTAL HEALTH

ICAR (S) Application No. 15172

T. C. No. 231-164-08


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) X Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____ Yes ____ No
Residence X Yes ____ No

4) No of Bedrooms 4
5) Business Use Max No Employees _____
6) Washing Machine X Yes ____ No
7) Garbage Disposal X Yes ____ No
8) Dishwasher X Yes ____ No
9) Water Supply
A) Individual Well _____
B) Governmental System _____
C) Community System
1 Well source X
2 Governmental source _____
10) Sewage System
House located within 200 feet of public sewer ____ Yes X No
House located within 200 feet of community sewer ____ Yes X No
11) FHA Case No _____
12) VA Case No. _____

13) NAME OF OWNER Braun (LAST) Kenneth (FIRST) Richard (MIDDLE)

14) ADDRESS OF OWNER 3119 Quilting Road, Matthews NC 28105

15) PHONE NO. Home 847-4365 Office 588-2340

16) LOCATION OF SYSTEM 3119 Quilting Road (STREET OR COUNTY ROAD)

17) SUBDIVISION Heath Farms Lot No. 8 Block No. 3

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ____ YES ____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

4/30/82
DATE OF APPLICATION

K R Braun
OWNER

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 5474

ICAR(S) Permit No. 15177


Date Issued 5-13-82

T. C No. 231-164-01

Map Date ——

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to V Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15177, dated 5-3-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 6/15/82, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate N/A

Liquid Capacity of Tank Equiv

Tank Construction PC

Absorption and/or Nitrification Lines

Total Line Length 100' Repair

Number of Lines one

Distance from House 10

Distance from Property Line 10'

Distance from Well 50

NAME OF OWNER Kenneth Richard Dixon

LOCATION OF PROPERTY 3119 Quitter Road

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

3' x 15' + 10' Line Repair to washing Machine Drain

Comments.

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 15177

Date Issued 5-13-82 **Serial** 5127 T C No 231-104-01

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Brown (LAST) Jennell (FIRST) R. (MIDDLE)

Location of Property 3114 Coulter Road 28105

Application Number 15177 Permit Number 15177

Inspection Data:

Liquid Capacity of Tank Existing Tank Material P.C.

Total Length of Drain Tile 100' Repair Number of Lines One

Depth of Filter Material 12' Cover Depth 15"

Water Supply Source Town Well Distance from Water Source 120'+

Excavation Inspected 5-13-82 (DATE) Tank Inspected OK (DATE)

Nitrification Field Inspected 5-13-82 (DATE)

Washing Machine Line Inspected, If Applicable 5-13-82 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ___ installed or constructed, ___ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments _____

Environmentalist

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Received 6-5-82

MECK COUNTY DEPARTMENT OF HEALTH
RECEIVED
JUN 4 1982
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 15177

T. C. No. 231-104-08


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) _____ Alter or (Repair) an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home _____ Yes _____ No
Residence X Yes _____ No

4) No. of Bedrooms 4
5) Business Use — Max No Employees _____
6) Washing Machine _____ Yes _____ No
7) Garbage Disposal _____ Yes _____ No
8) Dishwasher _____ Yes _____ No
9) Water Supply:
A) Individual Well _____
B) Governmental System _____
C) Community System:
1. Well source X
2 Governmental source _____
10) Sewage System:
House located within 200 feet of public sewer _____ Yes X No
House located within 200 feet of community sewer _____ Yes X No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER Brown (LAST), ~~Barbara~~ Kenneth (FIRST) E. R. (MIDDLE)

14) ADDRESS OF OWNER 3119 Quilting Rd., Matthews 28105

15) PHONE NO. Home 847-1365 Office 588-2340

16) LOCATION OF SYSTEM 3119 Quilting Rd (STREET OR COUNTY ROAD)

17) SUBDIVISION Hearthstone Lot No. 8 Block No. 3

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

5/3/82
DATE OF APPLICATION

K R Brown
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY


Date Issued 7-20-82 Serial No. 5585 ICAR(S) Permit No. 15122

T. C. No. 231-104-08

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15122, dated 6-5-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 7/30/82 after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate N/A

Liquid Capacity of Tank Existing

Tank Construction pc

Absorption Area or Nitrification Lines

Total Line Length 100'

Number of Lines One

Distance from House 10'

Distance from Property Line 10'

Distance from Well 50'

NAME OF OWNER Kenneth K. Brown

LOCATION OF PROPERTY 3119 Gunstock Road

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

3' x 12' + 6' Stone or ~~Septic~~ Washing

Comments: Machine Drain Repair

Division or Section Head

Environmentalist Bob Wilson

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No 15177

Date Issued 7-20-82 Serial 5260 T C No 231-104-04

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Brown (LAST) Kenneth (FIRST) (MIDDLE)

Location of Property 3119 Quilting Road

Application Number 15177 Permit Number 15177

Inspection Data:

Liquid Capacity of Tank Existing Tank Material PC

Total Length of Drain Tile 100' Repair Number of Lines one

Depth of Filter Material 8' Cover Depth 15"

Water Supply Source Comm well Distance from Water Source 100'+

Excavation Inspected 7-20-82 (DATE) Tank Inspected N/A (DATE)

Nitrification Field Inspected 7-20-82 (DATE)

Washing Machine Line Inspected, If Applicable 7-20-82 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ___ installed or constructed, ___ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Bob Wilson
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY