

9100 DORCAS LN

14126182

7/11/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

MAINTENANCE INSPECTION STATEMENT

MECKLENBURG COUNTY HEALTH DEPARTMENT

Sampson A.D. & Nina P. Croft
P.O. Box 19671
Charlotte, NC 28219

Please Make Check Payable To:

Mecklenburg County Health Department
700 N. Tryon Street, Ste 211
Charlotte, NC 28202

Note: THIS COMPLETED FORM MUST ACCOMPANY PAYMENT!

DESCRIPTION OF PROPERTY

Name	Site Address	Tax Parcel	File #	# Bedroom	System Type
Sampson & Nina Croft	9100 Dorcas Lane	141-121-42	7745A	3	IIIB

Total Amount Due: $85.00

Please use the space below, to make any corrections to property information.

Name _____

Site Address _____

_____

Bedrooms _____

BILL INFORMATION

Billing Date	Payment Due Date
4/29/99	5/31/99

Direct Questions Concerning This Bill To ..... (704) 336-5102

☐ *Please check if you have a well.*

Make Check Payable To Mecklenburg County Health Department
Your Canceled Check Is Your Receipt

DO NOT SEND CASH

N. C. Department of Environment and Natural Resources
Division of Environmental Health

INSPECTION OF ENGINEERED SUBSURFACE WASTEWATER SYSTEM

Mecklenburg — Health Department
Name of Establishment
7745 A — Permit/Project No.

9100 Dorcas Lane — Location
residence — Type of Establishment
360 gpd — Design Flow

Sampson A.D. Croft, P.O. Box 19671, Charlotte, 28219 — Owner/Agent, Address, Phone

N/A — Operator, Address, Phone

Remarks III b

	Yes	No	REMARKS
1. ESTABLISHMENT:			
Type, size, and sewage flow in accordance with permit?	☑	☐	
2. COLLECTION SYSTEM:			
No evidence of leaks into or out from sewer lines/manholes?	☐	☐	
Free of blockages/solids buildup in lines or manholes?	☐	☐	
3. TANKAGE (Grease Traps/Lift Stations/Septic/Dosing Tanks):			
Tank risers accessible and surface water diverted?	☑	☐	
Tanks and access manholes structurally sound, watertight?	☑	☐	
Sanitary tee(s) in good working condition?	☐	☐	Recommended that septic tank be pumped out
Tanks pumped, cleaned out as needed?	☐	☐	
4. RAW SEWAGE LIFT STATION (if present):			
Required pumps present, operating, and cycling properly?	☐	☐	
High-water alarm present and operating properly?	☐	☐	
Floats/pipe/valves/disconnects in good working condition?	☐	☐	
Control panel enclosure/components in good condition?	☐	☐	
5. EFFLUENT DOSING SYSTEM:			
Effluent appears clear, free of excess solids?	☐	☐	
PUMP SYSTEMS:			
Required pumps present, operating, and cycling properly?	☑	☐	
High-water alarm present and operating properly?	☑	☐	
Floats/pipe/valves/disconnects in good working condition?	☑	☐	Piggy-back setup with Nema 4x alarm beside
Control panel enclosure/components in good condition?	☑	☐	
Elapsed time readings: _____ _____ _____			
SIPHON SYSTEMS:			
No evidence of overflow or siphon leakage?	☐	☐	
Siphon(s) appear to be working/alternating properly?	☐	☐	
Bells and vents free of debris and in good condition?	☐	☐	
6. GROUND ABSORPTION FIELDS:			
No evidence of effluent surfacing/reaching surface waters?	☑	☐	
Minimal ponding in subsurface trenches?	☑	☐	
Surface water being effectively diverted away?	☑	☐	
Diversions/ditches/swales/tile drains properly maintained?	☑	☐	
Line cover/vegetation adequate/maintained as needed?	☑	☐	
Protected from traffic, destructive uses?	☑	☐	
Distribution devices in good condition, working properly?	☑	☐	
Repair area properly reserved, maintained?	☑	☐	
LOW-PRESSURE PIPE DRAIN FIELDS:			
Turnups/cleanouts/valves intact and accessible?	☐	☐	
No effluent standing in lower laterals?	☐	☐	
Laterals free of excess solids, cleaned out as needed?	☐	☐	
Pressure head is properly adjusted?	☐	☐	

OVERALL CONDITION AND OPERATION OF SYSTEM: Looks Good! Evidence of leaking fixtures in house - made homeowner aware of this.

SUMMARY OF IMPROVEMENTS NEEDED:

Improvement	Repair Within (Days)

DATE: 6-17-99 SIGNED: Larry B. Thompson Jr. R.S. AGENT
Division of Environmental Health

DENR 3702 (Revised 3/98)
On-Site Wastewater Section (Review 12/98)

– over –

SUMMARY OF IMPROVEMENTS NEEDED (cont.)

Improvement	Repair Within (Days)

INTENT TO SUSPEND OR REVOKE PERMIT

This is to notify you of intent to suspend/revoke your operation permit/certificate of completion 60 days from this date for the following
(circle one) *(circle one)*

violations: _____
[Law or Rule(s)]

If suspended, the operation permit or certificate of completion remains suspended until violations are corrected. A hearing will be held prior to suspension or revocation if you file a petition for a hearing with the Office of Administrative Hearings, P. O. Drawer 27447, Raleigh, NC 27611-7447, in writing within the number of days specified above of your intent to attend the hearing. If you do not petition the Office of Administrative Hearings, the operation permit or certificate of completion will be suspended or revoked.

IMMEDIATE SUSPENSION OR REVOCATION OF PERMIT

This is to notify you of immediate suspension/revocation of your operation permit/certificate of completion for the following violations:
(circle one) *(circle one)*

_____
[Law or Rule(s)]

If suspended, the permit or certificate remains suspended until the violations are corrected. You will be notified of the day and location of a hearing on this suspension or revocation by a hearing officer from the Office of Administrative Hearings.

This the _____ day of _____, 19 _____.

_____ Agent
DIVISION OF ENVIRONMENTAL HEALTH

INSTRUCTIONS

Purpose: Article 11 of Chapter 130A requires the Commission for Health Services to adopt rules governing the design, construction, and operation of on-site wastewater systems. 15A NCAC 18A .1937 specifies that the local health department shall determine whether systems with an Operation Permit are operating properly at a frequency specified in Rule .1961, Table V(a), and that systems which exceed 3,000 gallons per day and other systems which are required to be designed by a professional engineer shall be reinspected annually. This form is developed to be used in making inspections of engineered subsurface wastewater systems.

Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for:

1. Original to be left with the responsible person.
2. Copy for the local health department.
3. Copy for the On-Site Wastewater Section, Division of Environmental Health.

In the event the permit is suspended or revoked, complete the portion above.

Disposition: This form may be destroyed in accordance with Standard 7, Inspection Records, of the *Records Disposition Schedule* published by the N.C. Division of Archives and History.

Additional forms may be ordered from: On-Site Wastewater Section
Division of Environmental Health
P. O. Box 29594
Raleigh, NC 27626-0594
(Courier 52-01-00)

MAINTENANCE INSPECTION STATEMENT

MECKLENBURG COUNTY HEALTH DEPARTMENT

Sampson A.D. & Nina P. Croft
P.O. Box 19671
Charlotte, NC 28219

Please Make Check Payable To

Mecklenburg County Health Department
700 N. Tryon Street, Ste 211
Charlotte, NC 28202

Note: THIS COMPLETED FORM MUST ACCOMPANY PAYMENT!

DESCRIPTION OF PROPERTY

Name	Site Address	Tax Parcel	File #	# Bedroom	System Type
Sampson & Nina Croft	9100 Dorcas Lane	141-121-42	7745A	3	IIIB

Total Amount Due: $85.00

Please use the space below, to make any corrections to property information.

Name _____

Site Address _____

_____

Bedrooms _____

BILL INFORMATION

Billing Date	Payment Due Date
4/29/99	5/31/99

Direct Questions Concerning This Bill To ..... (704) 336-5102

☐ *Please check if you have a well.*

Make Check Payable To Mecklenburg County Health Department
Your Canceled Check Is Your Receipt

DO NOT SEND CASH

Mecklenburg County
Health Department

April 29, 1999

Sampson A. D. and Nina P. Croft
P.O. Box 19671
Charlotte, NC 28219

RE: 9100 Dorcas Lane

Dear Mr. and Mrs. Croft:

This letter is being sent to all home/business owners in Mecklenburg County with septic tank systems that utilize pumps. In 1990 the North Carolina Administrative Code governing septic tank systems was amended to require routine maintenance and inspection of certain septic tank systems. Research conducted on septic tank systems has shown that properly maintained systems perform better and protect the home/business owner's investment. These State rule changes required local health departments to perform additional inspections without additional resources. During the 1998-99 budget hearings, the Mecklenburg County Board of County Commissioners (BOCC) approved user fees to offset costs and to allow the local health department to comply with mandatory enforcement requirements in the State regulations.

Since you have a pump system, these new rules and fee requirements affect you. The fee is $85.00 and is due upon receipt of this notice. We will visit your property and make assessments and recommendations for the continued efficient operation of your septic tank system. In addition, if you have a well, a bacterial sample will be collected to help assess the quality of your water supply source. The process, including fee assessment, will be repeated every five (5) years. The fee amount may change in the future.

We are excited about the interest and support demonstrated by the BOCC. Past performance in this area was more enforcement oriented rather than supportive. One of our goals is to establish our department as a resource to you to aid and assist you with this and related public health concerns. The inspection program and the water analysis are important to the health of you and your family. This is a very important initiative intended to protect the public's health while improving and preserving our groundwater resources.

Your prompt fee payment will activate our inspection process. Your comments and questions regarding this matter are encouraged and welcomed.

Sincerely,

Larry B. Thompson, Jr., R.S.

Larry B. Thompson, Jr., R.S., Coordinator
Managed Systems Program
Individual Water and Wastewater Systems

Enclosure

cc: Fiscal Services Manager, HMHCS

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7745A DATE: 11/19/91

TC: 14.211-42 ☐ L ☒ CRT

SERIAL № 13996

Name of Owner M.D. Sampson A.D. Croft Juris.:

Address of Property 9100 Dorcas Ln.

Inspection Data:

Tank Material PVC

Total Length of Drainfield 400'

Number of Lines 4 @ 100'

Cover Depth 24"

Water Supply Source Well (Neighbors)


Distance to Water Source 100'

Excavation Inspected 11/19/91

Tank(s) Inspected 11/19/91

Wash Line Inspected

High Water Alarm Inspected 11/19/91



Design: CTR#

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 3 bedroom home
Pump = Hydromatic 1/2 HP SP40

Judy J. Rice RS.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

APPLICATION FOR SOIL INVESTIGATION

$50.00
cash 2625
09/09/91

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 7745A

TC: 141-121-03

☑ PC ☐ REPT

Paid 9/9/91 $50.00 10247 Check

JOB LOCATION

① ADDRESS: Off Steele Creek Rd Dorcas Lane

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: _____ PAGE NO.: _____ PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: 141-121-03

OWNER


⑦ NAME: Sam A. Croft
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: P.O. Box 19671

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28219

⑫ PHONE: (WORK) 392.0668 (HOME) 392-7892

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Sam A Croft

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 9-9-91

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

Mecklenburg County
Health Department

September 12th, 1991

Sam A Croft
P. O. Box 19671
Charlotte, NC 28219

RE: Property located at Dorcas Lane
FILE: 7745A
PARCEL: 141-121-03

Dear Sir:

At your request a soils investigation was conducted on the property designated above. Results of this investigation showed the site to be classified as UNSUITABLE under criteria as set forth in Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Division of Health Services; Sanitary Engineering Section, Subchapter 10A, Sanitation. A copy of the Site Evaluation Report (Serial Number 19763) is enclosed.

The soil on this property is not suitable for use with any conventional, modified or alternative system of which I am aware. If you wish to exercise your right of appeal concerning the interpretation and enforcement of these rules you may do so in accordance with G.S. 150B and 10 NCAC 1B.

If I can be of assistance, please do not hesitate to call.

Very truly yours,

Philo S. Walker R.S. for G. Vaughan

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 19763

File: 7745 A Action 3

Parcel: 0141-121-03 ☐ PC

Location: Dorcas Lane

Subdivision:


Lot: Block: Acres: 1.0

Owner: Sam A. Crafts
Address: PO Box 19671
Charlotte, N.C. 28219

Comments: 100% Repair
1 Boring showed perched
water evidence @ 18"

Described by: William R. Marlin

Date: 9-12-91



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-8%	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S PS (U) 2-1 Clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Block	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 736" Water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S PS (U) 12-24"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 736"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U See Not-	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	Mecklenburg/ Enon					
Area Classification	S PS (U)	S PS U	S PS U	S PS U	S PS U	S PS U

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 19763

File: 7745 A Action 3

Parcel: 21141-121-03 ☐ PC

Location: Dorres Lane

Subdivision:


Lot: Block: Acres: 1.0

Owner: Ivan A. Crisp
Address: PO Box 19671
Charlotte, N.C. 28219

Comments: 100% Acres
1 Boring showed perched
water outlows @ 15"

Described by: William B. Marlin

Date: 7-12-91



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-3%	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S PS (U) 2-1 Clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 73' to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S PS (U) 12-22"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 73"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U See Addl-	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	Mecklenburg Enon					
Area Classification	S PS (U)	S PS U	S PS U	S PS U	S PS U	S PS U