Date Received July 28, 1978

APT No. 14387

T C. No. 193 - 282 - 30 32 33

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER SPARTAN FOOD SYSTEMS INC

2) ADDRESS OF OWNER (LAST) Box 3168 (FIRST) SPARTANBURG SC ZIP (MIDDLE) 29304

3) PHONE NO Home _____ Office (803) 579-1220

4) LOCATION OF PROPERTY US 74 near NC 51
STREET OR COUNTY ROAD


5) SUBDIVISION LOT NO ~~BLOCK NO~~

MAP BOOK NO PAGE NO 193-282-32

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and/or on site inspection of the property described for the purpose of determining if the lot is suitable for the installation of an individual sewage disposal system with subsurface soil absorption effluent discharge.

See plot plan attached



7) ACCURATELY DIAGRAM & DIMENSION LOT

Spartan Food Systems Inc

OWNER by D C Charles

FHD 5 76

Environmental Health Department's Copy

App. 14387

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: Spartan Food Systems Inc DATE REQUESTED: 28 July 78
ADDRESS: Box 2168 Spartanburg 29304 PLAT NO.:
COUNTY: Mach LOT SIZE: 2 19,100 sq ft P.O. 31,500 sq ft front
LOCATION OF SITE: (193 25-32) US 74 area NC 51

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2% PS U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S clay PS U (sandy clay)	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS (massive) (W)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS (MARIED) (D)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S PS saprolite (D)	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S (severe) PS (moderate) U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS (slow) (D)	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES	(Cecil Clay AREA)			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: [signature]

Title: Environmentalist Date: 2 Aug 78

DHS Form 2601 (2/77)
Sanitation

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SIR.NO. 14387
T. C.NO. 193-282-30-32-33
MAP DATE
DATE 8-3-78

NAME OF OWNER Spartan Food Systems, Inc.

ADDRESS OF OWNER Box 3168 Spartanburg, SC 29304

LOCATION OF LOT US 74 near NC 51

At your request and pursuant to Section. 1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive
Site Classification Unsuitable

Section 10 of the North Carolina Administrative Code 10A, .1910 of these regulations states "Sites originally classified as unsuitable may be used for soil absorption disposal systems, provided engineering, hydrogeologic, and soils studies indicate to the local agency that a suitable alternate system can reasonably be expected to function satisfactorily.

Section 10, North Carolina Administrative Code 10A, .1916 states that "The design, construction, and maintenance of ground absorption sewage systems, whether septic tank systems or alternate systems shall be the responsibility of the owner, developer. installer, and user of the system as applicable in the circumstances."

We would also advise you that according to Regulation 10, North Carolina Administrative Code 10A, . 1916(b), "Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect compliance with the provisions of this section shall in no way be taken as a guarantee that sewage disposal systems approved and permitted will function in a satisfactory manner for any given period of time or that such employees assume any liability for damages, consequential or direct, which are caused or which may be caused, by a malfunction of such system.

These regulations became effective July 1, 1977. Since that time the second sentence of Section .1910(c) has been found to be nugatory. For this reason, if you desire to file for permission to install an "alternate" system you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R. Adkisson, Environmentalist

EHD #584

Date Received July 28, 1978 SEE INSTRUCTIONS ON BACK

ICAR(S) Application No. 14387

T. C. No. 193-282-30 32 33


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ✓ Install a Construct 2 _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge.



3 PROPERTY ACCURATELY DIMENSIONED

Mobile Home ___Yes ✓No
Residence Yes ___ No
4) ~~No of bedrooms~~ 88 seats
5 Business Use Max No Employees 10
6 Washing Machine ___Yes ✓No
7 Garbage Disposal Yes ___ ✓No
8 Dishwasher ___Yes ___ ✓No
9 Water Supply
A Individual Well ✓
B Governmental System _____
C Community System
1 Well source _____
2 Governmental source _____
10 Sewage System
A Is property located within 200 feet of public sewer ___Yes ✓No
B Is property located within 200 feet of community sewer ___Yes ✓No
11 EnvA Case No _____
12 LA Case No _____

13 NAME OF OWNER SPARTAN FOOD SYSTEMS INC (Hendrix Mc Laughlin A)
LAST FIRST MIDDLE

14 ADDRESS OF OWNER P.O. BOX SPARTANBURG SC 29304

15 PHONE NO Home _____ Office (803) 579-1220

16 LOCATION OF SYSTEM W/S NC 51 ICAR
STREET OR COUNTY ROAD

17 SUBDIVISION _____ Lot No _____ Block No _____

Map Book No _____ Page No _____

18 DEED REFERENCE DEED BOOK _____ AT PAGE _____

19 ADJACENT PROPERTY OWNERS _____ TAX _____ DATE RUN

20 OTHER WELLS _____

193-282-32

The undersigned property owner agrees that he has read the foregoing application and that the contents of same are true and that any permit applied for herein shall be void and of no effect if any of the above facts are not true

July 28, 1978
DATE OF APPLICATION

Spartan Food Systems Inc
OWNER by DD Landrum

EHS 5 76

Environmental Health Department's Copy