Date Received 7-29-83

RECEIVED
JUL 29 1983
ENVIRONMENTAL HEALTH

SIR No. 19911

T. C. No. 03-222-46

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Parker (LAST) John & Louise (FIRST) 11433 William & Arthur (MIDDLE)

2) ADDRESS OF OWNER Rt. 14 Box 560-X Bozzelle Ferry Rd. ZIP 28214

3) PHONE NO. Home 399-3801 Office _____


4) LOCATION OF PROPERTY 11435 Bozzelle's Ferry Road (STREET OR COUNTY ROAD) Charlotte 28214

5) SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK 3790 PAGE NO. 0163

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Louise A. Parker
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 19011
T.C. NO. PO 031-222-46
DATE: 8-18-83

Mr. & Mrs. John Parker
Route 14, Box 560-X
Charlotte, NC 28214

Re: Property located at 11435 Rozzelles Ferry Road

Dear Mr. & Mrs. Parker:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19911

T.C. NO. PO 031-222-46

(Ground Absorption Sewage Disposal)

OWNER: John & Louise Parker
ADDRESS: Rt. 14 Box 560-J Charlotte, N.C. 28214

PLAT NO:
LOT SIZE: Acreage

LOCATION OF SITE: 11435 Reggelle's Ferry Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U — 6 - 10%	(S) PS U — 6-10%	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) — 2-1 Clay	S PS (U) — 2-1 Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S (PS) U — Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (U) — 15-24"	S PS (U) — 15-24"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS (U) — Saprolite L 36"	S PS (U) — Saprolite L 36"	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — >36" To ground water	S PS (U) — Perched Water Table	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U — Indicators @ 24"	S PS U	S PS U
8. SOIL GROUP	IVB	IVB		
9. SITE CLASSIFICATION	unsuitable	unsuitable		
10. SOIL SERIES	Enon Like	Helena Like		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: William R. Martin
Title: Soil Scientist

Date: 8-9-83

EHD 539 (Revised: 6/82)

9


Proposed House-site
Ewen Lake
Helena Lake
200'
Approx 500-600'
Existing House
Razzelle's Ferry Rd.