

9334 SNOW RIDGE LN

14111229

5/2/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

2430

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2942A DATE: 7/8/94

TC: 141-111-07 ☐ L ☒ CRT

SERIAL № 15987

Name of Owner: New Trend Homes Juris.:

Address of Property: 9334 Snow Ridge Lane

Inspection Data:

Tank Material: 1500

Total Length of Drainfield: 400

Number of Lines: 6 @ 67'

Cover Depth: 12"

Water Supply Source: Well

Distance to Water Source: 60' from neighbor, 75' from new

Excavation Inspected: 7/8/94

Tank(s) Inspected: 7/8/94

Wash Line Inspected: —

High Water Alarm Inspected: —

PLOT

Design: 1994, 1500ST, 1200 SQ. FT, 12"G, T, CCCIL-4LE CTR# 82

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Type II

P. Walker for
S. Daniel 7/20/94

Jane H. Powell, R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Mecklenburg County
Health Department

Copy 2.0.C.

TELECOPIER TRANSMITTAL COVER SHEET

⁂ NOTICE ⁂

THE INFORMATION CONTAINED IN THIS TELECOPY MAY BE PRIVILEGED AND/OR CONFIDENTIAL AND IS INTENDED ONLY FOR THE USE OF THE PERSON TO WHOM IT IS ADDRESSED. IF THE READER OF THIS MESSAGE IS NOT THE INTENDED RECIPIENT (OR SUCH RECIPIENT'S EMPLOYEE OR AGENT), YOU ARE HEREBY NOTIFIED NOT TO READ, DISTRIBUTE OR COPY THE MATERIALS ATTACHED HERETO WITHOUT THE PRIOR WRITTEN CONSENT OF THE SENDER. IF YOU HAVE RECEIVED THIS TELECOPY IN ERROR, PLEASE NOTIFY THE SENDER BY TELEPHONE CALL AND RETURN THE ORIGINAL TELECOPY TO US BY MAIL AND WE WILL REIMBURSE YOU FOR THE REQUIRED POSTAGE. THANK YOU.

TO: New Found Homes TELECOPIER # 366-1724

FROM: Lewis DATE 7/19/94

NUMBER OF PAGES TRANSMITTED: _____ (including cover sheet)

COMMENTS: per request

If you do not receive all pages, please call us as soon as possible at the following number: (704)336-5102.

[✓] Original will not follow [ ] Original will follow via:

[ ] U.S. Mail [ ] Hand Delivery [ ] _____

Environmental Health Division
700 North Tryon Street • Suite 211 • Charlotte, North Carolina 28202-2236

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2942A DATE: 6/27/94

TC: 141-111-07 ☐ L

SERIAL Nº 15977

Permission is hereby given to ✓ (Install) or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5-24-93. All work shall be completed on or before 5-24-97, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Liquid Capacity of Septic Tank 1500' gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 6

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well >75' feet

NAME OF OWNER NEW TREND HOMES, INC.

LOCATION OF PROPERTY 9334 Snowridge Lane

Comments: OPEN HOLE - STAY 20' WITH ANY LINES ABOVE 5' LINES BELOW.
LOT 21 - WINTERGLEN

Joni H Newell, RS for Sylvia Daniel
Division or Section Head

Don H Newell, R.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY