Date Received 8/21/79

APT No. 16098 A portion of

T. C. No. 039-192-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Queen City Sales Co, Inc
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 2101 Oakdale Rd. ZIP 28216

3) PHONE NO. Home 394-2852 Office 342-4778


4) LOCATION OF PROPERTY Touch-me-not Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Cedar Grove Brook Park LOT NO. 9 BLOCK NO. 1

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 2313 PAGE NO. 305

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Dorothy H. Lanier
OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16098

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # PO 039-192-01

(Ground Absorption Sewage Disposal)

OWNER: QUEEN CITY SALES CO. DATE REQUESTED: 8-21-79
ADDRESS: 2101 OAKDALE RD PLAT NO.:
COUNTY: CHARLOTTE 28216 LOT SIZE: 20,000 .48A
LOCATION OF SITE: TOUCH-ME-NOT-LANE
Lot 9 Block 1

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-10	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy clayey, Note 2:1 Clay)	S PS (U) 2-1 Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS (U) MASSIVE	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U <48	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS (U) Clays	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S PS (U) Very slow	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S ~~PS~~ (U) slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION:	UNSUITABLE			
SOIL SERIES	HELENA			

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

Recommendations/Comments: DRAINAGE IS SEVERE

Described By: Willard B. Ramsey
Title: Soil Scientist Date: 8-24-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

2


100
HELENA
2-10
200
Lot 9 - Block 1
TOUCH ME NOT LANE

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1300 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. No. 16098
T.C. No. pe 039-192-01
MAP DATE
DATE 8/29/78

NAME OF OWNER Queen City Sales Company, Inc.

ADDRESS OF OWNER 2101 Oakdale Road, Charlotte, NC 28216

LOCATION OF LOT Kouch-Ma-Not Lane, Cedar Grove Park subdivision LOT 9 BLK. 1

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system due to the following reasons:

Soil Structure Massive
Soil Permeability Unsuitable

John R. Atkisson

John R. Adkisson, Environmentalist