

7723 ELLENCROFT LN

10802160

1/8/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

FOR REGISTRATION JUDITH A. GIBSON
REGISTER OF DEEDS
MECKLENBURG COUNTY, NC
2004 APR 12 01:04 PM
BK:17028 PG:726-729 FEE:$20.00

INSTRUMENT # 2004081805

2004081805

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

WASTEWATER TREATMENT AND DISPOSAL SYSTEM DESIGN AGREEMENT: 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c); OR .1969

FILE # 5175B
PARCEL # 108-021-60

The undersigned, MANUEL D ALVARADO, owner of property located at 7723 ELLEN CROFT LANE, (the "site") and described in an instrument recorded in Book 14472 at Page 618, Mecklenburg Public Registry, hereby acknowledges that the undersigned applied to the Mecklenburg County Health Department (the "Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 15A NCAC 18A .1900 et seq.; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data, and other information which indicate to the Department that the septic tank system proposed by the undersigned is allowed by the rules; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is the responsibility of the designer, owner, developer, installer, or user of the system, as applicable, and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further acknowledges that the following conditions will apply to the site:

This instrument was prepared by: MANUEL D ALVARADO
Mail after recording to: 7723 ELLEN CROFT LN 28215
Charlotte NC 28215

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 5175B DATE: 9/24/03 gcw 11-19-03

TC: 108-021-60 ☐ L ☑ CRT

SERIAL 19449

Name of Owner MANUAL ALVARADO Juris.: _____

Address of Property 7723 ELLENCROFT ~~DRIVE~~ LN.

Inspection Data:

Tank Material PCC 1500

Total Length of Drainfield 400

Number of Lines 4 @ 100'

Cover Depth 12"

Water Supply Source WELL

Distance to Water Source 2100

Excavation Inspected 11-15-03

Tank(s) Inspected 11-15-03

Wash Line Inspected _____

High Water Alarm Inspected ✓

SEE INSTALLATION

PLOT

Design 1500 gal ST 1600 SFT INNOVATIVE, EZ FLOW CTR# RFID EUDY

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ ~~installed~~ or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☑ ~~Operation~~ Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: TYPE III-6 INNOVATIVE, EZ FLOW

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 5175B DATE: ~~9/15/03~~ 9/22/03

TC: 108 02160 ☒ L

SERIAL 19648

Permission is hereby given to _____ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 2-24-03. All work shall be completed on or before _____, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Trench Depth 30"

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Trench Walls Scored and Porous Y RC

Total Line Length 400 feet

Number of Lines 4

Depth of Stone NA inches

Distance from House 5' feet

Distance from Property Line 10 feet

Distance from Well 250 feet

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER MANUAL ALVARADO

LOCATION OF PROPERTY 7123 ELLENCROFT LN.

Comments: TYPE III-G INNOVATIVE

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

300 80 CC APP 012605

FEE: 300 **AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION** ACS 3/CA
DATE: 3/12 **VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE** DD

DATE: 3/10/03 PERMIT NO: 5175B

PARCEL NO: 108-021-60

JOB LOCATION ADDRESS: 1123 BLUENCROFT LANE

PROPERTY OWNER:

BUILDING CONTRACTOR: JEFF FRANCIS

SUBDIVISION NAME: BLUENCROFT, LOT #2

AUTHORIZATION ISSUED BY: [signature] DATE: 3/10/03

(DEHNR AUTHORIZED AGENT)

AUTHORIZATION CONDITIONS

1. WASTEWATER SYSTEM CONSTRUCTION AND INSTALLATION MUST MEET ALL CONDITIONS AND SPECIFICATIONS AS SET FORTH IN IMPROVEMENT PERMIT NO. 5175B, AND THE ATTACHED SITE PLAN WITH SYSTEM DETAILS. CONSTRUCTION AND INSTALLATION MUST ALSO MEET ALL REQUIREMENTS SET FORTH IN THE RULES GOVERNING SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL AND ANY OTHER APPLICABLE RULES AND LAWS.

2. AN INSTALLATION, CONSTRUCTION, ALTERATION AND/OR REPAIR APPROVAL MUST BE SECURED **PRIOR** TO INSTALLATION OF THE SEPTIC TANK SYSTEM. THE INSTALLER OF THE SYSTEM SHALL BE A REGISTERED SEPTIC TANK CONTRACTOR WITH MECKLENBURG COUNTY HEALTH DEPARTMENT.

3. ANY ALTERATION IN SITE OR SOIL CONDITIONS (INCLUDING LOCATION OF STRUCTURES AND APPURTENANCES) OR MODIFICATION IN USE, DESIGN WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS AS SPECIFIED IN THE ASSOCIATED IMPROVEMENT PERMIT AND APPLICATION, MAY SUBJECT THIS AUTHORIZATION AND ASSOCIATED PERMIT(S) TO REVOCATION.

4. OTHER CONDITIONS: (1) PANEL BLOCK REPAIR REQUIRED.

OWNER CERTIFICATION

I CERTIFY THAT THERE HAVE BEEN NO ALTERATIONS IN SITE OR SOIL CONDITIONS OR MODIFICATIONS TO FACILITY, WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS FROM THOSE SPECIFIED IN THE ORIGINAL APPLICATION OR ASSOCIATED IMPROVEMENT PERMIT UNLESS AUTHORIZED IN WRITING BY THE MECKLENBURG COUNTY HEALTH DEPARTMENT. I ALSO UNDERSTAND THAT ANY SUCH ALTERATIONS, MODIFICATIONS, OR FALSE INFORMATION ARE GROUNDS FOR REVOCATION OF PERMITS AND AUTHORIZATION TO CONSTRUCT.

[signature] 3/12/03

SIGNATURE OF OWNER/OWNER'S REPRESENTATIVE DATE

CONDITIONS OF IMPROVEMENT PERMIT

ermit Number: 5105B

Tax Number: 108-021-60

The IMPROVEMENT PERMIT is subject to revocation if site plans or the intended use change. There is to be NO grading, filling or disturbance of the soil in the area of the septic tank system or repair area.

CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is NOT transferable. Do not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.

Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement	___ Yes	X No	___ Partial Basement	
Type Primary Wastewater System Type (circle one): I II (III) IV V VI	___ Conventional ___ Prefabricated, permeable block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	X Innovative or Experimental: ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1	
.3 Long-term acceptance rate	480 Max gallons/day wastewater flow	1600 Absorption Area (sq ft)	9' Trench spacing (min. on centers)	
GBS Serviced by private well	1500 Gallon septic tank	400 Total trench length (ft)	30" Maximum trench depth (At least 12" of provisionally suitable soil must remain between trench bottom and unsuitable soil conditions)	
4 Bedrooms in residence	___ Gallon pump tank	NA Depth of stone		
Any surface waters present:	Type:	Minimum separation distance:		
Site modifications required:				
Additional Conditions: (1) INNOVATIVE INSTALLATION (2) PANEL BLOCK REPAIR.				
Repair Area System Type Type (circle one): I II (III) IV V VI	___ Conventional X Prefabricated, permeable block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimental: ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1	
1680 Absorption Area (Sq ft) 200 Total Trench Length (Ft)	NA Depth of Stone Trench	8' Trench spacing (min. on centers)	36 Maximum Trench Depth	
For existing system, enter the year originally installed:				

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules For Sewage, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Department.
- This Improvement permit is transferable.

DEHNR Authorized Agent — Date 3/10/03

Owner/Agent Signature — Date

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR.
SUITE 211
700 N. TRYON ST.
CHARLOTTE, N.C. 28202.
(704) 336-5102

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENTAL, HEALTH,
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 5175B

TC: 108-021-60

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.

PERMIT FOR 7723 ELLENCROFT LANE

SCALE 1" = 50'


(1) HOUSE TO BE LOCATED 80' FROM ROAD.

(2) LOCATE WELL @ BACK OF PROPERTY AND AT LEAST 50' FROM ALL SEPTIC TANK SYSTEMS.

(3) PERMIT DESIGN IS FOR AN INNOVATIVE DRAINFIELD, ALLOWING FOR 25% REDUCTION IN TOTAL LINEAR FEET, WITH REPAIR AREA BEING A PERMEABLE PANEL BLOCK, ALLOWING FOR 50% REDUCTION IN TOTAL LINEAR FEET.

(4) DRIVEWAY W/ CURB NEED TO BE INSTALLED ON EDGE OF (L) PROPERTY LINE & DRAINFIELD TO BE 20' FROM PROPERTY LINE, AS SHOWN -

(5) AGREEMENT FORMS ARE REQUIRED-



OWNER/AGENT SIGNATURE

DATE

APPROVAL DATE 3/10/03

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

MECKLENBURG COUNTY
LAND USE AND ENVIRONMENTAL SERVICES
Payment Receipt

Receipt Information

Date:	03/12/03	**Amount:**	300.00
Receipt #:	15219	**Tendered:**	300.00
Check / Auth #:	MC 012605	**Returned:**	0.00
Received By:	CRAIGGY		

Account Information

Account #: 200000
Contractor: FRANCES JEFF
Attn:
Address: 12163 DEERVIEW LANE
Address:
City/State/Zip: CHARLOTTE, NC 28269

Item	Description	Permit#	Quantity	Unit Price	Total Price
0734	Auth for Waste Wtr Sys Constr 7723 ELLENCROFT LANE/FILE 5175B		1	150.00	150.00
0703	Installation/Final Approval 7723 ELLENCROFT LN/FILE 5175B		1	150.00	150.00


----------Outstanding Balances----------

Month-To-Date	Prior Month	30 Days	60 Days	90 Days	Balance

THIS IS TO CERTIFY THAT ON THE_____DAY OF _____19____ I, SURVEYED THE PROPERTY SHOWN ON THIS PLAT. AND THAT THE TITLE LINES AND THE WALLS OF THE BUILDINGS IF ANY ARE SHOWN HEREON.

SIGNED_____
REGISTERED SURVEYOR

Self Engineering & Surveying
13538 Capriole Lane
Matthews, NC 28105
704-847-8610
Fax: 704-841-7660



VICINITY MAP NO SCALE

PLOT PLAN 12-05-02
REV. PLOT PLAN 12-13-02

FLOOD LOAD GARAGE

N.23°-32'-08"E
75.01'

LOT 2
0.664 AC.

55' REAR YARD

TAX PARCEL NO
108-021-60

10' SIDE YARD

208.94'

N.07.26"W

10' SIDE YARD

S.72°-28'-02"E

NORTH
MAP 23-193

LOT 3
BARRY T. HARPER, SR.
8240-917

LOT 1
WILLIAM S. McMULLEN AND WIFE
ANGELA P. McMULLEN
10096-803

N.52°-07'-97"W

22.0'
22.0'
5.33'
6.25'
3.25'
7'
7'
15.67'
78.0'
48.08'
#7723
24.89'
11.65'
22.0'
6.0'
7.17'
3.25'
6.67'
2.17'
4.5'
15'
3.08'
3.08'
15'
63.83'
78'
68.3'
255.96'
14.5'
22.33'
12'

R/W
R=25'
L=25'
CH.=23'
S.88°-23'

35' MIN. BLDG. SETBACK LINE

CHORD = 144.96'
S.36°-02'-14"W.

R/W

S.28°-51'-97"W

R = 225.00' L = 147.59'

ELLENCROFT LANE
40' PUBLIC R/W

PLOT PLAN OF LOT 2 OF ELLEN CROFT SUBDIVISION
CRABTREE TOWNSHIP, MECKLENBURG COUNTY, N.C.

PLAN #857-L

40 80
SCALE IN FEET
SCALE 1"=40'

THE PROPERTY OF LAWRENCE P. TYSZKA AND WIFE DORA A. TYSZKA

MAP RECORDED IN BOOK 23 AT PAGE 193 DEED RECORDED IN BOOK 6180 PAGE 14

NOT FOR RECORDATION, SALES OR CONVEYANCES

Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1
Property ID: 108-021-60
Lot #: 2
File #: 5175B
Code: 2

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Manuel D. Aldarado
Applicant: Jeffrey Francis
Address: 6929 Hillswick Avenue, Charlotte, N. C. 28215
Date Evaluated: 03/03/2003
Proposed Facility: Residence
Design Flow (.1949): 480gpd
Property Size: .69a
Location of Site: 7723 Ellencroft Lane
Property Recorded:
Water Supply: [ ] Public [x] Individual [x] Well [ ] Spring [ ] Other
Evaluation Method: [x] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [x] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	OTHER PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	LS, 10	0-6	DISTURBED		>49" TO SOILWETNESS	49"	N/A	NONE	PS, IV
		6-36	SBK/C	FI/SEXP/S/P					.3GPD/FT
		36-49	SBK/SCL	FR/SEXP/SS/SP					
2	"	0-6	GR/SCL	"	>48" TO SOIL WETNESS	48	"	"	"
		6-48	SBK/C	FI/SEXP/S/P					
3	"	0-5	GR/SCL	FR/SEXP/SS/SP	"	"	"	"	"
		5-48	SBK/C	FI/SEXP/S/P					
4	LS, 8	0-6	GR/SCL	FR/SEXP/SS/SP	"	"	"	"	"
		6-34	SBK/C	FI/SEXP/S/P					
		34-48	SBK/CL	FR/SEXP/SS/SP					
5	"	0-5	GR/SCL	"	"	"	"	"	"
		5-39	SBK/C	FI/SEXP/S/P					
		39-48	SBK/CL	FR/SEXP/SS/SP					


Description	Initial System	Repair System
Available Space (.1945)	PS	US
System Type(s)		
Site LTAR	.3GPD/FT^2	.3GPD/FT^2

Other Factors (.1946): _____
Site Classification (.1948): PROVISIONALLY SUITABLE
Evaluated By: W. R. Marlin, LSS, 3/7/2003, W. R. Marlin
Others Present:

COMMENTS: 100% Repair, use surface water diversion

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8		
S-SHOULDER SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE	NS-NON-STICKY
L-LINEAR SLOPE				FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 – 0.6	FI-FIRM	S-STICKY
N-NOSE SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE	III	SI-SILT-	0.6 – 0.3		SP-SLIGHTLY STICKY
CV-CONVEX SLOPE		SIL-SILT LOAM			P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			
		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 – 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE	MINERALOGY
SG-SINGLE GRAIN	SLIGHTLY EXPANSIVE
M-MASSIVE	
CR-CRUMB	EXPANSIVE
GR-GRANULAR	
SBK-SUBANGULAR BLOCKY	
ABK-ANGULAR BLOCKY	
PL-PLATY	
PR-PRISMATIC	



FEE: 240.00 DATE: 2/24/03

APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM

PAGE 1 OF 2

TYPE APPLICATION: X NEW SYSTEM ___ EXPANSION/ALTERATION OF EXISTING SYSTEM ___ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 57956

PROPERTY INFORMATION (FROM ENGINEERING BOND) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 108-021-60

STREET ADDRESS: 7723 Ellen Croft Lane

SUBDIVISION OR MOBILE HOME PARK NAME: Ellen Croft.

LOT NUMBER: 2

TYPE OF BUILDING (CHECK ONE):

___ SINGLE MOBILE HOME(S)
___ DOUBLE WIDE (D)
X HOUSE (H)
___ MODULAR HOME (M)
___ MULTIPLE FAMILY (U)
___ OTHER (O)

TOWNSHIP (CHECK ONE):

X 0 MECKLENBURG
___ 1 CHARLOTTE
___ 2 DAVIDSON
___ 3 CORNELIUS
___ 4 PINEVILLE
___ 5 MATTHEWS
___ 6 HUNTERSVILLE
___ 7 MINT HILL

HEATED SQUARE FOOTAGE: 3100

NUMBER OF BEDROOMS: 4 NUMBER OF OCCUPANTS: 5

CLOSING DATE June 30/03

FOUNDATION FOR RESIDENCE:

___ WITHOUT BASEMENT ON SLAB
X CRAWL SPACE
___ WITH BASEMENT /PLUMBING
___ WITH BASEMENT /NO PLUMBING

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: ___ YES X NO TYPE: _____

WATER SUPPLY: (CHECK ONE):

___ COMMUNITY (C)
___ MUNICIPAL (M)
X PRIVATE WELL (P)
___ SHARED WELL (S)
___ OTHER 'SPRINGS' (O)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES ___ YES X NO
EXISTING WASTEWATER SYSTEMS ___ YES X NO
EASEMENTS OR RIGHT-OF-WAYS ___ YES X NO
WELL, SPRINGS OR WATERLINES X YES ___ NO
DESIGNATED WETLANDS ___ YES X NO

PROPERTY OWNER:

NAME: (LAST) Alvarado (FIRST) Manuel (MI) D

ADDRESS: 6929 Hillswick Ave

CITY: Charlotte STATE: NC ZIP: 28215

DAYTIME PHONE: (704) 568-0557

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: (LAST) Francis (FIRST) Jeffrey (MI) Glenn

DAYTIME PHONE: (704) 622-3831

Odyssey Homes Inc

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? _____

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

SIGNED: Jeff Francis DATE: 2/24/03

MECKLENBURG COUNTY HEALTH DEPARTMENT

PROPOSED PLOT PLAN


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

TAX # 108-021-60

FILE: 5775B

TC: 108-021-60

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



OWNER/AGENT SIGNATURE

DATE 2/24/03

APPROVAL DATE _____

White - Health Department's Copy

Canary - E.H.S. Copy

Pink - Owner's Copy