MECKLENBURG COUNTY DEPARTMENT OF HEALTH
Date Received JUN 26 1978
ENVIRONMENTAL HEALTH

APT No. 14232
T. C. No. 05-261-04
Map Date 11-9-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER FESPERMAN, JAMES W. + MAXINE K.
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 4200 Rocky River Rd ZIP 28215

3) PHONE NO. Home 596-7969 Office 364-8100 (Mrs.)

4) LOCATION OF PROPERTY 4200 Rocky River Rd. Wayne
(STREET OR COUNTY ROAD)

5) SUBDIVISION CRABORCHARD LOT NO. _____ BLOCK NO. _____

MAP BOOK NO 3100 PAGE NO. 286

6) DEED REFERENCE DEED BOOK 3100 PAGE NO 286

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

CORNER OF ST. Rd. 2902-2826



7) ACCURATELY DIAGRAM & DIMENSION LOT

James W. Fesperman
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 14232

(Ground Absorption Sewage Disposal)

OWNER: James L. Marlin Fesperman
ADDRESS: 4200 Rocky River Road
COUNTY: Charlotte N.C. 28215
LOCATION OF SITE: 4200 Rocky River Road

DATE REQUESTED:
PLAT NO.: PO 105-061-04
LOT SIZE: 18,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2-10% PS U	(S) 2-8% PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2-1 PS clay (U)	S 2-1 PS clay (U)	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S Massive PS (U)	S Massive PS (U)	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) 48" PS U	(S) 48" PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) None PS U	(S) None PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) > 0 to ground PS water U	S Seasonal PS perched (U) water table	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S slow PS v. slow (U)	S v. slow PS (U)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable		
SOIL SERIES	Enon	Helena		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)

Recommendations/Comments:

Described By: William A. Marlin

Title: Soil Scientist Date: 2-6-79

dhs form 2601 (1/79)
Sanitation


Rd
120
150
150
120
Rocky River Rd
Beech Creek Rd

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 14232
T.C.NO. no 105-061-04
MAP DATE
DATE February 7, 1979

NAME OF OWNER Fesperman, James W. and Maxine K.

ADDRESS OF OWNER 4200 Rocky River Road, Charlotte, N.C. 28215

LOCATION OF LOT 4200 Rocky River Road

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive

Soil Permeability Unsuitable

Site Classification Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

Stephen Wood, Environmentalist

EHD 999 (1/79)

R