Date Received 6/7/77

APT No. 15982

T. C. No. 213-061-15

Map Date 5/23/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Hunter (LAST) Ruth (FIRST) Walters (MIDDLE)

2) ADDRESS OF OWNER 5101 Running Fox Rd. Mathews ZIP 28105

3) PHONE NO. Home 847 3707 Office Alexander Rd

4) LOCATION OF PROPERTY 6801 Providence Road (STREET OR COUNTY ROAD) Mathews

5) SUBDIVISION _____ LOT NO. 14.91 AC BLOCK NO. 15

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 1118-240 PAGE NO. 05

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Ruth W. Hunter
OWNER

EHD-5-76

Environmentalist's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

APT 15 982

(Ground Absorption Sewage Disposal)

OWNER: Ruth W. Hunter
DATE REQUESTED:
ADDRESS: 5101 Bounding Run Rd
PLAT NO.: PO 213-061-15, Site I
COUNTY: Matthews, NC 28105
LOT SIZE: 30,000
LOCATION OF SITE: Alexander Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S 2-8% PS U	S 2-8% PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2-1 PS Clay U	S 2-1 PS Clay U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS U Massive	S PS Massive U	S PS U	S PS U
4. SOIL DEPTH (In.)	S <48" PS U	S <48" PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S None PS U	S None PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S seasonal PS perched U water table	S >6' to PS ground water U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS U slow	S PS U slow	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable		
SOIL SERIES	Iredell	Mecklenburg		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: William A. Martin

Title: Soil Scientist Date: 7-23-79

DHS Form 2601 (2/77)
Sanitation


150'
200'
Iredell
200'
McKlenburg
Alexander Road
150

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR. NO. 15982
T.C. NO. no 213-061-15
MAP DATE 523/7&
DATE July 24, 1979

NAME OF OWNER Ruth W. Hunter

ADDRESS OF OWNER 5101 Rouding Run Road, Matthews

LOCATION OF LOT Alexander Road (portion of 6801 Providence Rd., facing on Alexander Road)

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive

Soil Permeability Unsuitable

Site Classification Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist

R