Date Received 6-18-82

LECK COUNTY DEPARTMENT OF
RECEIVED
JUN 18 1982

SIR No. 18802
T.C. No. P.O. 037-229-49

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Little (LAST) Pauline (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 4301 Victoria Ave. Charlotte, N. C. ZIP 28213

3) PHONE NO Home 596-1929 Office Brenda Kiser 365-2222

4) LOCATION OF PROPERTY Victoria Ave. Charlotte, N. C. Road #2631 (STREET OR COUNTY ROAD)


5) SUBDIVISION LOT NO 49 BLOCK NO 229

MAP BOOK NO 37 PAGE NO 22

6) DEED REFERENCE DEED BOOK #6 PAGE NO 839

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface absorption effluent discharge

Lots 67, 68, P.O. 69



7) ACCURATELY DIAGRAM & DIMENSION LOT

Pauline B. Little
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 4599

PTR No. 18802

Date Issued 7-2-82

T C No. PO 037-229-49

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Little, Pauline
LAST FIRST MIDDLE

ADDRESS OF OWNER 4901 Victoria Ave., Charlotte, NC ZIP 28213

LOCATION OF PROPERTY Victoria Avenue
STREET OR COUNTY ROAD 64

SUBDIVISION LOT NO 61,62,63 & PO BLOCK NO



This site was investigated by the Mecklenburg County Department of Environmental Health and the investigation was conducted on that date in accordance with the rules governing the sanitary disposal of sewage.

Provisionally Suitable

The permeability and depth to seasonal high water table of the soil is adequate for the installation of the above system. The soil is approved for the installation of a subsurface soil absorption system with a maximum trench bottom depth of 36 inches.

1. A permit must be obtained from the Mecklenburg County Department of Environmental Health before any system is installed.
2. The system must be installed by a person licensed by the Mecklenburg County Department of Environmental Health to install subsurface systems.
3. The location of the system must be as shown on the plot plan.
4. The owner must maintain the system in such a manner that it does not create a health hazard or nuisance.

This approval is granted subject to the laws of the State of North Carolina governing the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission at the time of construction and repair. However, in the future, should it be determined that the soil, water table or water supply conditions have changed such that this approval would not have been granted had the new conditions been in effect at the time of the issuance date, this approval will be withdrawn.

W. A. Kemsey
Soil Scientist

Mike Sikkon
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. NO. 18802
T.C. NO. PO 031-229-49

(Ground Absorption Sewage Disposal)

OWNER: Pauline Little
ADDRESS: 4901 Victoria Ave
COUNTY: 28213
LOCATION OF SITE: Victoria Ave
Lot 61, 62, 63 + Road 64

DATE REQUESTED: 6-18-82
PLAT NO:
LOT SIZE: .56

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-10 U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S (PS) Clayey U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 48 U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) None U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) Adequate U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation rate)	S (PS) Moderate U	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U

9. SITE CLASSIFICATION: √P, Suitable

10. SOIL SERIES: Cecil

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments:

Described By: W. B. Ramsey
Title: Soil Scientist
Date: 6-29-82

DHS Form 2601
Sanitation
EHD 539 (3/82)

✓


Victoria Ave
90
Cecil
2-10
277
269

RECEIVED
SEP 16 1983
ENVIRONMENTAL HEALTH

Date Received 9-16-83 SEE INSTRUCTIONS ON BACK

ICAR (S) Application No. 18802

T. C. No. 037-229-54


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) __4__ Install or Construct 2) __ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ✓ Yes __ No
Residence __ Yes __ No
4) No. of Bedrooms 2
5) Business Use — Max. No. Employees
6) Washing Machine ✓ Yes __ No
7) Garbage Disposal __ Yes ✓ No
8) Dishwasher ✓ Yes __ No
9) Water Supply
A) Individual well ✓
B) Governmental System
C) Community System
1) Well Shuttle
2) Governmental source
10) Sewage System
House located within 200 feet of public sewer __ Yes ✓ No
House located within 200 feet of community sewer __ Yes ✓ No
11) FHA Case No.
12) VA Case No.

13) NAME OF OWNER Brown Joseph Albert
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 5223 Skyforest Drive 28213

15) PHONE NO Home 527-2529 Office

16) LOCATION OF SYSTEM 5223 Skyforest Drive
STREET OR COUNTY ROAD

17) SUBDIVISION Lot No. 1, 2, 3 Block No.

Map Book No. 5 Page No. 356

18) DEED REFERENCE — DEED BOOK 5 AT PAGE 859

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES __ NO DATE RUN 7-2-82

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

9-14-83
DATE OF APPLICATION

Joseph Albert Brown
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 9-26-83

Serial No. 6654


ICAR(S) Permit No. 18802

T C No 037-229-54

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18802, dated 9-14-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 10-26-83, after which date this permit shall be null and void.



Permeability Rate 6 S.

Liquid Capacity of Tank 1500 gal

Tank Construction plc concrete

Absorption Area Requirement

Trench Length 200'

Number of Lines 3

Distance Between Lines 5'+

Depth of Trench Below Grade 10'+

Distance from Lake 50'+

Victoria Ave.

NAME OF OWNER Joseph A. Greene

LOCATION OF PROPERTY 5025 Victoria Ave.

The system shall meet all minimum construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable for use. The issuance of this permit does not in any way guarantee that the system will perform satisfactorily or meet any person now or hereafter owning, controlling or using such system, or property served by such system, to operate properly.

3- 67' X 3' X 12" stone trenches on 9' centers

Comments

Division or Section Head

Environmentalist ✓

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

AI 9-21 83

Date Issued 9-20-83

Serial No. 6783

SIR No. 18802

T. C. No. 037-229-54

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Greene, (LAST) Joseph (FIRST) Albert (MIDDLE)

ADDRESS OF OWNER 5323 Skycrest Dr., Charlotte, NC ZIP 28213

LOCATION OF LOT 5025 Victoria Avenue (STREET OR COUNTY RD.)

SUBDIVISION _____ LOT NO. 61,62,63 & PO 64 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation Construction, Alteration, and/or Repair Permit", number 18802 -- This approval is subject to the following terms and conditions.

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Randy C Poole RS
Environmentalist

Eric D. Hardister
Environmental Health Director, or Authorized Section Head

END-5-76

Environmental Health Department's Copy

BI 10-20-83
C of A (s) No. 18802

Serial 6217

T. C. No. 057-229-54

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

IMPROVEMENT PERMIT
CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Greene (LAST) Joseph (FIRST) A. (MIDDLE)

Location of Property 5025 Victoria Ave

Application Number 18802 Permit Number 18802

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material p/c Concrete

Total Length of Drain Tile 200' Number of Lines 3

Depth of Filter Material 12" Cover Depth 6" - 1½'

Water Supply Source well Distance from Water Source 50'+

Excavation Inspected — (DATE) Tank Inspected 10-18-83 (DATE)

Nitrification Field Inspected 10-18-83 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface soil absorption, effluent discharge as described above and it has been ✓ installed or constructed — altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit's in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

R. J. Kelly
Environmentalist

EHO-5-76

BE 10-30-83
C of A (s) No. 18802

Date Issued 10-18-83 Serial 6217 T. C. No. 037-229-54

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

IMPROVEMENT PERMIT
CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Greene (LAST) Joseph (FIRST) A. (MIDDLE)

Location of Property 5025 Victoria Ave

Application Number 18802 Permit Number 18802

Inspection Date:

Liquid Capacity of Tank 1500 gal Tank Material p/c Concrete

Total Length of Drain Tile 200' Number of Lines 3

Depth of Filter Material 12" Cover Depth 6" - 1½'

Water Supply Source well Distance from Water Source 50'+

Excavation Inspected ____ (DATE) Tank Inspected 10-18-83 (DATE)

Nitrification Field Inspected 10-18-83 (DATE)

Washing Machine Line Inspected If Applicable ____ (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface soil absorption, effluent discharge as described above and it has been ✓ installed or constructed ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

R P Kelly
Environmentalist

ENO-5-76

ENVIRONMENTAL [illegible]