Date Received 12.9.73

APT No 7306

T C. No 019-031-01

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER St. Philips Baptist Church
LAST FIRST MIDDLE

2) ADDRESS OF OWNER Box 366 — Huntersville, NC ZIP 28078

3) PHONE NO Home 875-6915 Office


4) LOCATION OF PROPERTY Cemetery St. - Huntersville, NC
STREET OR COUNTY ROAD

5) SUBDIVISION LOT NO. 1 BLOCK NO.

MAP BOOK NO 019 PAGE NO. 05

6) DEED REFERENCE DEED BOOK 1414 PAGE NO. 553

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and on on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

St. Philips Church
X Mayor Hellam Elmore
OWNER

FORM NO. E-1-8-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. 3- -74
2. _____
3. _____

SDR No. 7306
T.C. No. 019-081-01

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER St. Phillips [illegible]tist Church

ADDRESS OF OWNER Box 388, Huntersville, N.C. ZIP 28078

LOCATION OF LOT Cemetery Street

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	3-7-74	[illegible] min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Richard Hawkins
Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70

SEE INSTRUCTIONS ON BACK

Date Received 12-7-73

ICARUS Application No 7306

T C No 019-031-01

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) X Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No. of Bedrooms —

5) Estimated Water Use
Engineered —

6) Washing Machine — Yes — No

7) Garbage Disposal — Yes — No

8) Dishwasher — Yes — No

9) Water Supply
A) Individual Well —
B) Community System —
C) Community System
1) Well —
2) Community System —

Sewage Pump Required —

Effluent Pump Required — Yes — No

Public Water Available — Yes — No

Community System — Yes — No

10) FHA Case No. —

11) VA Case No. —

13) NAME OF OWNER St. Phillips Baptist Church
LAST FIRST MIDDLE

14) ADDRESS OF OWNER Box 366 - Huntersville, NC. 28078

15) PHONE NO Home 875-6915 Office

16) LOCATION OF SYSTEM County Street, Huntersville, NC
STREET OR COUNTY ROAD

17) SUBDIVISION — Lot No 1 Block No —

Map Book No 019 Page No. 08

18) DEED REFERENCE — DEED BOOK 1914 AT PAGE 533

19) HAS A PERCOLATION TEST BEEN RUN? — YES — NO DATE RUN —

20) PTR NUMBER (See Instructions) —

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

St. Phillips Baptist Church
Elder Jack Williamson
OWNER

DATE OF APPLICATION —

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY