Date Received 7-16-84

RECEIVED
JUL 16 1984
[illegible]

ICAR(S) Application No 21245

T C. No. 043-074-35

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ___ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge.

CALL
n 1
Brother
in law
and
Site
[illegible]



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No. of Bedrooms 3

5) Business Use — Max No Employees ___

6) Washing Machine ___ Yes ✓ No

7) Garbage Disposal ___ Yes ✓ No

8) Dishwasher ___ Yes ✓ No

9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___

10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ___ No

11) FHA Case No ___

12) VA Case No. ___

13) NAME OF OWNER [illegible] (LAST) [illegible] (FIRST) [illegible] (MIDDLE)

14) ADDRESS OF OWNER [illegible] Paw Creek

15) PHONE NO. Home [illegible] Business [illegible]-637665

16) LOCATION OF SYSTEM [illegible] (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

7-16-84
DATE OF APPLICATION

[illegible]
OWNER

EHD-S-76

Environmental Health Department's Copy

Serial No. 07424

ICAR(S) Permit No. 21245

Date Issued July 19 1984

T C No. 043-034-35

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ____ Install or Construct, V Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21245, dated 7-12-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before JULY 26th 1984, after which date this permit shall be null and void.



PLOT OF SYSTEM HOWARD ST.

Permeability Rate PS IVA

Liquid Capacity of Tank

Tank Construction Repair

Absorption and/or Nitrification Lines.

Total Line Length 120 LIN. FT.

Number of Lines SA

Distance from House 10 FT

Distance from Property Line 5 FT

Distance from Well 750 FT

NAME OF OWNER WINE COFF, NANCY

LOCATION OF PROPERTY 5420 HOWARD ST

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Two Beds to be 20FT x 9FT x 18 inches stone - hay or straw cover - grade Bds to into existing system - Call ENV HEALTH DEPT IF ANY Problem arises

Division or Section Head

Environmentalist Ralph Miller

check for sanitary tee & pump tank before starting

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department Copy

C of A (s) No. 21245

Date Issued 7-24-84 **Serial** 6823 T C No 043-034-35 L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner WINECOFF, NANCY
LAST FIRST MIDDLE

Location of Property 5420 Howard St

Application Number 21245 Permit Number 21245

Inspection Data:

Liquid Capacity of Tank Repair Tank Material Repair

Total Length of Drain Tile 120 lin FT Number of Lines Three

Depth of Filter Material 36" Cover Depth 2 FT

Water Supply Source Well Distance from Water Source 75 FT.

Excavation Inspected 7-24-84 DATE Tank Inspected 7-24-84 DATE

Nitrification Field Inspected 7-24-84 DATE

Washing Machine Line Inspected, If Applicable — DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed X altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permits in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Beds changed to one bed 20' x 9' x 36" stone due to only one outlet pipe from tank

Ralph Villa
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT