CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21714 DATE: 8-9-88
TC: 135-321-02-03 ☑ L ☐ CRT
SERIAL № 11323

Name of Owner Bob McLemore Co. Juris.:
Address of Property 10639 Idlewild Rd.

Inspection Data:

Tank Material PCC
Total Length of Drainfield 535
Number of Lines 5 @ 107'
Cover Depth 18"-21"
Water Supply Source Comm.
Distance to Water Source -
Excavation Inspected 8-9-88
Tank(s) Inspected 8-9-88
Wash Line Inspected
High Water Alarm Inspected 8-9-88

PLOT

Design: 1988, 1500ST, 1000DT, PI, CON, 1605FT, 12", cecil CTR# 113

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☑ installed or constructed ☐ altered or repaired
☑ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☐ Certificate of Completion ☑ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS.

B.A. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21714 DATE: 8-1-88

TC: 135-321-02,03 ☑ L

SERIAL № 12089

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 7-15-85. All work shall be completed on or before 9-1-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank 1000 gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 535 feet

Number of Lines Five

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10' feet

Distance from Well >100' Comm well feet

NAME OF OWNER Bob McLemore & Co. Inc.

LOCATION OF PROPERTY 10839 Idlewild Rd.

Comments: Five Trenches 107'x3'x12" Stone; lift station

[signature], RS
Division or Section Head

[signature]
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

Date Issued July 25, 1985 Serial No. 8762

SIR No. 21714

T. C. No. PO 135-321-02,03

Map Date L CLT 11-4-85

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

IMPROVEMENT PERMIT

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Bob McLemore & Co., Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER PO Box 25746 Charlotte, NC ZIP 28212

LOCATION OF LOT 10839 Idlewild Road
(STREET OR COUNTY ROAD)

SUBDIVISION Brandonwood LOT NO 2 BLOCK NO. BW

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number_____. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

B. R. Ferguson
Environmentalist

Eric D. Henderson Jr.
Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy

FILE # 21714
P.O 135-321-0203
BOB MCLEMORE CO. INC



10839 IDLEWILD RD LOT # 2 BW

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

APPLICATION FOR AN IMPROVEMENT PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

MECK COUNTY DEPARTMENT OF
RECEIVED
JUL 16 1985
ENVIRONMENTAL HEALTH

(OFFICE USE ONLY)

FILE: 21714

PO 135-321-02,03

JOB LOCATION

① ADDRESS: 10839 IDLEWILD ROAD (STREET NO / STREET) ② FILE: 21714

③ CITY: CHARLOTTE ④ TAX PARCEL NO.: PO 135-321-0203

⑤ SUBDIVISION: BRANDONWOOD ⑥ LOT: 2 ⑦ BLOCK: BW

OWNER

⑧ NAME: BOB McLEMORE & Co. INC. (FIRST) (MIDDLE) (LAST)

⑨ MAILING ADDRESS: PO BOX 25746

⑩ CITY: CHARLOTTE ⑪ STATE: NC ⑫ ZIP: 28212

⑬ PHONE: (WORK) 545-6111 ⑭ (HOME) ——

REQUEST

This request is for a(n):

⑮ ☒ New installation permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 4 ㉕ Type?

㉓ Maximum occupancy? ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

SEE ATTACHED

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☐ Individual well

B ☐ Municipal system

C ☒ Community well

D ☐ Community system

㉚ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: BOB McLEMORE & Co. INC. BY [signature]

Date: 7-15-85

㉘ Accurately dimensioned plot

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SIR. NO. 21714
T.C. NO. PO 135-321-02,03
DATE: 5-30-85

Bob McLemore Co., Inc.
P.O. Box 25746
Charlotte, NC 28212

RE: Property located at 10839 Idlewild Road

Dear Sirs:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure



File # 21714
PO 135-32-0203
Bob McLemore Co.

10837 Idlewild Rd LOT 2 BW

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21714

T.C. NO. PO 135-321-0203

(Ground Absorption Sewage Disposal)

OWNER: Bob McLennon Etc.
ADDRESS: PO Box 25746 Charlotte, NC 28212
PLAT NO: Lot 2
LOT SIZE: 1.6 A
LOCATION OF SITE: 10,934 Hillsville Ave

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-8% U	S PS — U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS Clay U	S PS — U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS — U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36"+ U	S PS — U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S >36" to PS Saprolite U	S PS — U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S >36" to PS U	S Depression PS U Lake Area	S PS U	S PS U
7. OTHER (Specify)	S Limited PS Area U	S PS U	S PS U	S PS U
8. SOIL GROUP	11 A	—		
9. SITE CLASSIFICATION	Provisionally Suitable	unsuitable		
10. SOIL SERIES	Cecil Lake	Depression & Lake Area		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Recommend plans be submitted for house system & well locations

Described by: William R. Marlin
Title: Soil Scientist

Date: 5-29-95

14



changed line location 11-7-85 after additional visit to lot. W Am

Idlewild Rd.

Date Received 12-27-84

MECK COUNTY DEPARTMENT OF
RECEIVED
DEC 27 1984
ENVIRONMENTAL HEALTH

SIR No. 21714

T. C. No. PO/35-321-0203

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER BOB McLEMORE Co INC
LAST FIRST MIDDLE

2) ADDRESS OF OWNER PO BOX 25746 CHARLOTTE ZIP 28211

3) PHONE NO. Home — Office 545-6111

4) LOCATION OF PROPERTY 10839 IDLEWILD ROAD
STREET OR COUNTY ROAD

5) SUBDIVISION BRANDONWOOD SECT #1 LOT NO. 2 BLOCK NO. BW

MAP BOOK NO 20 PAGE NO. 750

6) DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.

SEE ATTACHED



7) ACCURATELY DIAGRAM & DIMENSION LOT

BOB McLEMORE Co INC
OWNER

By [signature]

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY