Date Issued 9-12-79 Serial 3031

C of A (s) No. 7690

T C No 019-132-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE of COMPLIANCE

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Abernathy (LAST), Edwin (FIRST) P. (MIDDLE)

Location of Property Everette Keith Rd.

Application Number 7690 Permit Number 7690

Inspection Data:

Liquid Capacity of Tank 1500 gals Tank Material p/c conc.

Total Length of Drain Tile 455' Number of Lines 5

Depth of Filter Material 17" Cover Depth 15"-24"

Water Suppl. Source well Distance from Water Source not in yet

Excavation Inspected — Tank Inspected 9-7-79 (DATE)

Nitrification Field Inspected 9-7-79 (DATE)

Washing Machine Line Inspected If Applicable 9-7-79 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption effluent discharge as described above and it has been ✓ installed constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit as in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments pipe between tank & box replaced w/ PVC.

Michael T. Sexton
Environmentalist

EHD-5-76

Environmental Health Department's Copy