Job # 974

Date Received 12-23-83

MECK COUNTY DEPARTMENT OF
RECEIVED
DEC 23 1983
ENVIRONMENTAL HEALTH

SIR No. 20452
Pd
T. C. No. 223-201-17

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER William Trotter Company
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P. O. Box 35269, Charlotte, N. C. ZIP 28235

3) PHONE NO. Home _____ Office 333-8804


4) LOCATION OF PROPERTY 8232 Houston Ridge Road (Off Providence Road West)
(STREET OR COUNTY ROAD)

5) SUBDIVISION Providence West LOT NO. 3 BLOCK NO. 5

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER William Trotter Company

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20452

T.C. NO. PO 623-20117

(Ground Absorption Sewage Disposal)

OWNER: William Foster Co.
ADDRESS: PO Box 35269 Charlotte N.C. 28235
PLAT NO: 43-85
LOT SIZE: 65,900
LOCATION OF SITE: 6232 Weston Ridge Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS — U	S 8 to 15% PS U	S complex PS slopes U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS — U	S PS 2:1 clay U	S PS clay U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS — U	S PS Blocky U	S PS Blocky U	S PS U
4. SOIL DEPTH (inches)	S PS — U	S PS 30-40" U	S Depth PS variable U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS — U	S PS > 36" U	S < 36" PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S Drainage PS way U	S perched PS water U Table 30"-36"	S Eroded PS Areas channel U runoff	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	—	IVB	IVA	
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	
10. SOIL SERIES	Drainageway	Helena	Complex slopes	

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments: _____

Described by: William R. Martin
Title: Soil Scientist

Date: 1-9-84

EHD 539 (Revised: 6/82)

2H


170'
Drainageway
11+ plaza
240'
240'
Complex slopes
Houston Ridge

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SIR. NO. 20452
T.C. NO. P0 223-201-17
DATE: 1-11-84

William Trotter Company
P. O. Box 35269
Charlotte, NC 28235

RE: Property located at 8232 Houston Ridge Road, Lot 3, Blk. 5

Dear Sirs:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure