

7901 JOHNSON CREEK RD

10802110

1/2/2008

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

532-9604

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3202B DATE: 5/3/94

TC: 108-021-10 ☐ L ☐ CRT

SERIAL Nº 15744

Name of Owner Rodney BRAGG Juris.:

Address of Property 11901 ~~2001~~ JOHNSON CREEK ~~CIRCLE~~ ROAD

Mailing address 8002 [illegible]

Inspection Data:

Tank Material PUMP (SANITARY TEE) 1000 GAL.

Total Length of Drainfield 400

Number of Lines 4 @ 100'

Cover Depth 12"

Water Supply Source 50'

Distance to Water Source WELL

Excavation Inspected 5/3/94

Tank(s) Inspected 4/28/94

Wash Line Inspected —

High Water Alarm Inspected 5/3/94

PLOT

Design: 1994 REPAIR, 1000 PT., 1200 SQFT, 12", UNSUITABLE SOILS CTR# POTTERS RD. SEPTIC TANK

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of ~~15~~ 18 NCAC ~~10A~~ 18A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of ~~15~~ 18 NCAC ~~10A~~ 18A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 1958 SEPTIC TANK SYSTEM

→ MAINTAIN ALL WATER DIVERSION AWAY FROM TANKS.

→

James H. Newell, R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

(4600


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3202B DATE: 3/28/94

TC: 108-021-10 ☐ L

SERIAL Nº 15923

Permission is hereby given to _____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 3/28/94. All work shall be completed on or before 4/28/94, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Liquid Capacity of Septic Tank _____ gallons

Liquid Capacity of Dosing Tank 1000 gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400' feet

Number of Lines 4

Depth of Stone 12" inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well 50 feet

NAME OF OWNER Roberts Bragg

LOCATION OF PROPERTY 7851 Johnson Creek Circle Road

Comments: Disconnect existing ~~pump~~ septic tank to pump tank and run 2' supply line to (2) D boxes and system. 4@100'x12"x3' 20 GPM @ 11 TDH

Division or Section Head

Environmentalist Don W. Ewell, R.S.

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY