Date Received 11/14/19

NOV 14 1979

APT No 16317

T C No 015-161-14

Map Date

COPY TO

Cecil Saunders
PO 1410
Morganton 28655

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER LAST FIRST MIDDLE

2) ADDRESS OF OWNER ZIP

3) PHONE NO Home Office

4) LOCATION OF PROPERTY STREET OR COUNTY ROAD

5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinafter described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

North Mecklenburg Associates
By Peter Palmer
OWNER

EHO-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

APT 10317

PO 015-101-14

(Ground Absorption Sewage Disposal)

OWNER: North Mecklenburg Apartments DATE REQUESTED: _____
ADDRESS: 2601 Shaun Lane PLAT NO.: _____
COUNTY: Charlotte, N.C. 28655 LOT SIZE: 20,000
LOCATION OF SITE: Beatties Ford Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-6% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2:1 clay (U)	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) weak blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS 48" (U)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 70 to ground PS water U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS U.S low (U)	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable			
SOIL SERIES	Enon			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: _____

Described By: William A. Mullis

Title: Soil Scientist Date: 11-23-79

DHS Form 2601 (2/77)
Sanitation

2


Beattie Ford Road
200'
Emon
NO
100'
200'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 16317

T.C. # po 015-161-14

DATE Nov. 27, 1979

NAME OF OWNER North Mecklenburg Associates

ADDRESS OF OWNER 2601 Sharon Road, Charlotte, NC 28655

LOCATION OF LOT Beatties Ford Road near intersection of Keck Road

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Soil Depth Unsuitable
Soil Permeability Unsuitable
Site Classification Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist