Date Received 12/4/79

APT No. 16367

T. C. No. 197-154-1[illegible]

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Poore (LAST) Glen (FIRST) C (MIDDLE)

2) ADDRESS OF OWNER P.O. Box 23[illegible] Charlotte NC ZIP 28212

3) PHONE NO Home 545-4162 Office 545-6918


4) LOCATION OF PROPERTY Brief Road (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 1 & 2 BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Glen C Poore

OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16367

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 197154-12,13

(Ground Absorption Sewage Disposal)

OWNER: Wm. J. Poore
ADDRESS: Po Box 23057
COUNTY: Charlotte, NC 28212
LOCATION OF SITE: Brief Rd

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 43,560

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-10%	(S) PS U 2-10%	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy loamy clayey, Note 2:1 Clay)	S PS (U) 2:1 Clay	S PS (U) 2:1 Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S (PS) Blocky U	S (PS) Blocky U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS ✓ U ~48"	S PS (U) ~36"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (in.) (Impervious Strata Rock)	(S) None PS U	(S) None PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	(S) 24-72 ground water PS U	(S) 36-72 ground water PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S ✓ slow→ (U) v. slow PS U	S slow→ (U) v. slow PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable		
SOIL SERIES	Lignon	Goldston		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc.


Recommendations/Comments:

Described By: William R. Martin

Title: Soil Scientist Date: 12-10-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

✓


Bloydon Dr.
Boo F Rd
946
Lignum
916'
230'
Goldston
151

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 16367
T.C.NO 197-154-12,13
MAP DATE
DATE December 10, 1979

NAME OF OWNER Poore, Gene L.

ADDRESS OF OWNER PO Box 23057, Charlotte, NC 28212

LOCATION OF LOT Brief Road, Lots 1 and 2

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Depth Unsuitable (less than 48 inches)

Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A, 1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office

John R. Adkisson

John R. Adkisson, Environmentalist