Date Received 4 10 73

APT No. 5976

T. C No. 135-256-18

Map Date 5-9-74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Bob McLemore & Co., Inc.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 6129 Lebanon Road ZIP

3) PHONE NO. Home Office 545-4507


4) LOCATION OF PROPERTY Pine Lake Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Farmwood, # 11 LOT NO. 168 BLOCK NO.

MAP BOOK NO PAGE NO.

6) DEED REFERENCE: DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Serial No. [illegible]5

PTR No. 5976

Date Issued April 13, 1973

T C No. 135-[illegible]

Map Date 5-9-74 8-9-72

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Bob McLemore & Company, Inc.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 6129 Lebanon Road, Matthews, N.C. ZIP 28105

LOCATION OF PROPERTY Pine Lake Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Farmwood #11 LOT NO 16 BLOCK NO 4



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John M Robinson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 1-14-74

ICAR (S) Application No 5976

T C No 155-256-18 155-256-01

Map Date 8-9-72 5-9-74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ✓ Install or Construct 2) ____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms ____

5) Business Use Yes No
Employees ____

6) Washing Machine Yes ✓ No

7) Garbage Disposal Yes ✓ No

8) Dishwasher Yes ✓ No

9) Water Supply
A) Individual Well
B) Government
C) Community
Well
Spring
Stream
Private System
Public System
Shared System
Community Sewer Yes ✓ No

11) FHA Case No ____

12) VA Case No ____

13) NAME OF OWNER Bob McLemore & Co, Inc (LAST FIRST MIDDLE)

14) ADDRESS OF OWNER P.O. Box 25746, Charlotte, NC

15) PHONE NO Home ____ Office 545-6111

16) LOCATION OF SYSTEM 7500 Pine Lake Ln (STREET OR COUNTY ROAD)

17) SUBDIVISION Fairwood II Lot No. 16 Block No M

Map Book No ____ Page No. ____

18) DEED REFERENCE — DEED BOOK ____ AT PAGE ____

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ____ NO DATE RUN 4-12-73 IR#60

20) PTR NUMBER (See Instructions) 5976

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

1-11-74
DATE OF APPLICATION

Bob McLemore & Co, Inc, VP
OWNER

FORM NO E-4-8-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 3772

LA No. 5976

T C No. 135-

Date Issued January 14, 1974

Map Date 5-9-74

IMPROVEMENTS PERMIT

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Bob McLemore & Co., Inc. (LAST / FIRST / MIDDLE)

ADDRESS OF OWNER P.O. Box 25746 ZIP 28212

LOCATION OF LOT 7500 Pine Lake Lane (STREET OR COUNTY ROAD)

SUBDIVISION Farmwood 11 LOT NO 16 BLOCK NO M

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration and/or Repair Permit", number 5976. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

John R. Atkinson

Environmentalist

Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-8-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 5[illegible]3 ICAR(S) Permit No 5976

Date Issued 7-29-74 PO T C No 135-351-01

Map Date 8-9-72


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, Alter or Repair the individual septic tank waste water treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 5976, dated 1-11-74 and this permit shall be void and of no effect if the information provided in the application is not true and as represented. All work shall be completed on or before 8-29-74 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500

Tank Construction PC

Absorption and/or Nutrification Lines

Total Line Length 795'+200' W/M 4(10'X50'X17")

Number of Lines 6(15'X133'X17")

Distance from House 10'

Distance from Property Line 10'

Distance from Well Community

NAME OF OWNER Bill McLemore & Co., Inc.

LOCATION OF PROPERTY 7500 Pine Lake Lane (Lot 16 Block M)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments Shrink (construction)

Division or Section Head

V. J. Utterback
Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

Serial No. 5226

C of A (s) No. 5976

Date Issued 9-5-74

T C No. 135-351.01

Map Date 8-9-72

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner BOB McLENDORE INC. (FOR SALE)
LAST FIRST MIDDLE

Location of Property 7500 PINELAKE LN. (LOT 16 - M)

Application Number 5976 Permit Number 5976

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material PC

Total Length of Drain Tile ST 795 WM 200 Number of Lines ST 6 WM 4

Depth of Filter Material 17" Cover Depth* 18" - 36"

Water Supply Source COMM. Distance from Water Source —

Excavation Inspected 9-5-74 DATE Tank Inspected 9-5-74 DATE

Nitrification Field Inspected 9-5-74 DATE

Washing Machine Line Inspected If Applicable 9-5-74 DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been X installed or constructed, _____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit issued in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: PROVIDE UNIFORM COVER OVER LINES WHEN LANDSCAPING

J. R. Blackmon
Environmentalist

FORM NO. E-6-9-1-72

HEALTH DEPARTMENT'S COPY