

9235 DOGWOOD RIDGE DR

13925144

12/27/2007

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

FAXED 11/28/05

GWS - RES. APP 07/05

SEPTIC FEE: _____
DATE: _____
CRT [ ]

PERMIT APPLICATION FOR A RESIDENTIAL SITE IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION FOR ON-SITE WASTEWATER SYSTEM NEW WELL INSTALLATION OR REPAIR OF EXISTING WELL MECKLENBURG COUNTY GROUNDWATER & WASTEWATER SERVICES

WELL FEE: _____
DATE: _____
CRT [ ]

FILE # 22398

David

SEPTIC / TYPE APPLICATION: ☐ NONE ☐ NEW SYSTEM ☐ ALTERATION ☒ REPAIR ☐ MODIFY PLOT PLAN

WELL / TYPE APPLICATION: ☐ NONE ☐ NEW WELL ☐ MAJOR REPAIR ☐ ABANDONMENT

JOB LOCATION INFORMATION:

TAX/PARCEL #: 139-254-44
STREET ADDRESS: 9235 Dogwood Ridge Drive
CITY: Charlotte
STATE: NC ZIP: 28227
SUBDIVISION OR MOBILE HOME PARK NAME:
LOT #: 39 built 2001
TOWNSHIP:

☐ 0-MECKLENBURG ☐ 4-PINEVILLE
☐ 1-CHARLOTTE ☐ 5-MATTHEWS
☐ 2-DAVIDSON ☐ 6-HUNTERSVILLE
☐ 3-CORNELIUS ☒ 7-MINT HILL

BUILDING INFORMATION:

TYPE OF BUILDING:

☐ SINGLE MOBILE HOME (S) ☐ MODULAR HOME (M)
☐ DOUBLE WIDE (D) ☐ MULTIPLE FAMILY (U)
☒ HOUSE (H) ☐ OTHER

HEATED SQUARE FOOTAGE: 1691
NUMBER OF BEDROOMS: 3
NUMBER OF OCCUPANTS: 4

FOUNDATION FOR RESIDENCE:

☐ CONCRETE SLAB ☐ BASEMENT WITH PLUMBING
☒ CRAWLSPACE ☐ BASEMENT WITH NO PLUMBING

IF PLANNING TO EXPAND/ALTER THE EXISTING SYSTEM INDICATE THE FOLLOWING CHANGES:

NUMBER OF BEDROOMS TO BE ADDED: NUMBER OF ADDITIONAL OCCUPANTS IN THE RESIDENCE:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE? ☐ YES ☒ NO TYPE:

WATER SUPPLY:

☐ MUNICIPAL (M) ☐ PUBLIC (C) ☒ PRIVATE WELL (P) ☐ SHARED WELL (S) ☐ OTHER 'SPRINGS' (O)

PROPOSED USE OF WELL: ☐ N/A ☐ IRRIGATION ☐ POTABLE ☐ GEOTHERMAL ☐ OTHER

ARE ANY OF THE FOLLOWING LOCATED ON THE PROPERTY? IF SO, PLEASE SHOW LOCATION ON SITE PLAN/PLAT. TREES/R

BURIED CABLES, LANDFILLS, STUMPHOLES	☐ YES ☐ NO	WELLS, SPRINGS, OR WATER LINES	☐ YES ☐ NO
EXISTING WASTEWATER SYSTEMS	☐ YES ☐ NO	DESIGNATED WETLANDS	☐ YES ☐ NO
EASEMENTS OR RIGHT-OF-WAYS	☐ YES ☐ NO	GRADING/SOIL REMOVAL PERFORMED	☐ YES ☐ NO

PROPERTY OWNER:

NAME: Darin Miller
ADDRESS: 9235 Dogwood Ridge Drive
CITY: Charlotte
STATE: NC ZIP: 28227
HOME PHONE: 704-573-6715 WORK PHONE: 704-564-5844
MOBILE PHONE: 704-564-5844 FAX: 704-573-6691

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME:
ADDRESS:
CITY:
STATE: ZIP:
HOME PHONE: WORK PHONE:
MOBILE PHONE: FAX:

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED?

WHAT IS THE ANTICIPATED CLOSING DATE FOR THIS PROPERTY?

*An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

11/28/05
Owner's/Agent's Signature Date

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENT & NATURAL RESOURCES DIVISION
OF ENVIRONMENTAL HEALTH ON-SITE
WASTEWATER SECTION

*A Well Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

11/28/05
Owner's/Agent's Signature Date

MECKLENBURG COUNTY HEALTH DEPARTMENT
GROUNDWATER & WASTEWATER SERVICES
700 N. TRYON ST., SUITE 211
CHARLOTTE, NC 28202 704-336-5103 / FAX: 704-336-6994

FEE: 100.00 CK/CF 1623
DATE: 8/29/05
CRT [ ]

APPLICATION FOR APPROVAL TO USE AN EXISTING ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM
MECKLENBURG COUNTY - GROUNDWATER & WASTEWATER SERVICES
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

GWS – UES.APP 01/05

FILE # 32390

PF 144036

TYPE APPLCATION: Storage Building

- ☐ ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A / M)
- ☒ ADDITION - RENOVATION OR GARAGE WITH NO MAJOR CHANGES (X)
- ☐ EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
- ☐ COMMERCIAL OR INDUSTRIAL (N)

PERSON FILING APPLICATION:
NAME: Darin Miller
ADDRESS: 9235 Dogwood Ridge Drive
CITY: Charlotte
STATE: NC ZIP: 28227
PHONE: 704-573-6715
ALTERNATE PHONE: 704-564-5844

PROPERTY OWNER:
NAME: Darin Miller
ADDRESS: 9235 Dogwood Ridge Dr
CITY: Clt
STATE: NC ZIP: 28227
PHONE: 704-573-6715
ALTERNATE PHONE: 704-564-5844

JOB LOCATION INFORMATION
TAX/PARCEL #: 139-251-44
STREET ADDRESS: 9235 Dogwood Ridge Drive
CITY: Charlotte
STATE: NC ZIP: 28227
SUBDIVISION OR MOBILE HOME PARK NAME: Country Hills
LOT #: 39

TOWNSHIP:
- ☐ 0-MECKLENBURG
- ☐ 1-CHARLOTTE
- ☐ 2-DAVIDSON
- ☐ 3-CORNELIUS
- ☐ 4-PINEVILLE
- ☐ 5-MATTHEWS
- ☐ 6-HUNTERSVILLE
- ☒ 7-MINT HILL

print 139-251-30 2001

WATER SUPPLY:
☐ MUNICIPAL (M) ☐ COMMUNITY (C) ☒ PRIVATE WELL (P) ☐ SHARED WELL (S) ☐ OTHER 'SPRINGS' (O)

RESIDENTIAL PROPERTY TYPE:
☒ HOUSE (H) ☐ MODULAR HOME (M) ☐ MULTIPLE FAMILY (U)
☐ SINGLE MOBILE HOME (S) ☐ DOUBLE WIDE (D)
☐ OTHER (O)

NUMBER OF BEDROOMS: 3
NUMBER OF OCCUPANTS: 4

COMMERCIAL / INDUSTRIAL PROPERTY TYPE:
TYPE OF BUSINESS:
EMPLOYEES PER SHIFT:
OF SHIFTS:

INDUSTRIAL WASTES? ☐ YES ☐ NO
UNDERGROUND STORAGE TANKS? ☐ YES ☐ NO

ADDITION TYPE ATTACHED TO EXISTING STRUCTURE:
☐ BEDROOM ☐ BATHROOM ☐ KITCHEN ☐ DINING ROOM ☐ LIVING ROOM ☐ DEN
☐ GARAGE ☐ SUNROOM ☐ PORCH ☐ DECK ☐ OTHER

ADDITION TYPE DETACHED FROM EXISTING STRUCTURE:
☐ DETACHED GARAGE ☐ DETACHED GARAGE WITH PLUMBING ☐ POOL HOUSE ☐ SHOP ☐ BARN
☒ STORAGE SHED ☐ DETACHED PORCH / DECK ☐ OTHER

*The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature — Date: 8/29/05

*The undersigned, an authorized agent of the Mecklenburg County Health Department, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an installation, construction, alteration and/or repair approval is granted y this Department.
- This permit is not transferable.

☐ ADDITION / RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE
☐ MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE

8/31/05 OR TO USE EXISTING SYSTEM

EHS Signature — Date: 8/31/05


Mecklenburg County
Land Use & Environmental Service Agency
Groundwater & Wastewater Services
700 N. Tryon St., Suite 211
Charlotte, NC 28202
Phone: (704) 336-5103
Fax: (704) 336-6894

File # 22398
Date 8/29/05

COPY

PROPOSED PLOT PLAN

A map showing existing and proposed property lines and easements with dimensions, the location of the single family residence, non-single family residence, or other facility, and appurtenances, the site for the proposed well, and the location of existing or proposed sewer lines and/or sewage disposal systems, surface water bodies, aboveground or underground storage tanks. Name all roads adjoining the property. If this a repair indicate the type of repair.



Owner/Agent Signature
Date 8/29/05

Darin Miller

LBC 12/15/04

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 2239B DATE: 11-4-02

TC: 139-251-30 ☐ L ☐ CRT

SERIAL Nº 18984

Name of Owner CLAY HICKS Juris.:

Address of Property 9235 DOGWOOD RIDGE DRIVE

Inspection Data:

Tank Material PCC 1500

Total Length of Drainfield 29

Number of Lines 3 @ 99'

Cover Depth 12"

Water Supply Source WELL


Distance to Water Source NOT YET INSTALLED

Excavation Inspected 11-4-02

Tank(s) Inspected 11-4-02

Wash Line Inspected —

High Water Alarm Inspected —



Design 1500 SJ 1200 SFT INNOVATIVE [ENFILTRATOR] CTR# ROBBY McCARUFFE,

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☑ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☑ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: TYPE III-G

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 2239B DATE: 10-31-02

TC: 139-251-30 ☐ L

SERIAL 19160 X

Permission is hereby given to _____ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 10-13-97. All work shall be completed on or before _____, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction PCC

Trench Depth 30"

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Trench Walls Scored and Porous YES

Total Line Length 300 feet

Number of Lines 3

Depth of Stone NA inches

Distance from House 5' feet

Distance from Property Line 10' feet

Distance from Well >50' feet

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER CLAY TUCKS

LOCATION OF PROPERTY 9235 DOGWOOD RIDGE DRIVE

Comments: (1) THIS PERMIT HAS BEEN CHANGED TO A TYPE III-G INNOVATIVE INSTALLATION. 35% REDUCTION. CONTRACTOR WILL USE INFILTRATORS, PER HIS CHOICE - WARRANTY REQUIRED.

(2) REPAIR WILL REQUIRE A PUMP

Environmental Health Specialist

FOR REGISTRATION JUDITH A. GIBSON
REGISTER OF DEEDS
MECKLENBURG COUNTY, NC
2002 DEC 12 10:15 AM
BOOK:14529 PAGE:488-491 FEE:$20.00
INSTRUMENT # 2002246655

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

WASTEWATER TREATMENT AND DISPOSAL SYSTEM DESIGN AGREEMENT: 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c); OR .1969

FILE # 2239B
PARCEL # 139-251-30

The undersigned, Clay E. Hucks, owner of property located at 9235 Dogwood Ridge Dr. (the "site") and described in an instrument recorded in Book _____ at Page _____, Mecklenburg Public Registry, hereby acknowledges that the undersigned applied to the Mecklenburg County Health Department (the "Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 15A NCAC 18A .1900 et seq.; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data, and other information which indicate to the Department that the septic tank system proposed by the undersigned is allowed by the rules; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is the responsibility of the designer, owner, developer, installer, or user of the system, as applicable, and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further acknowledges that the following conditions will apply to the site:

This instrument was prepared by: Clay Hucks
Mail after recording to: Clay Hucks 1231 Forest Bluff Dr, Midland, NC 28107

or acct B42960 ACS

FEE: 150 **AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION**
DATE: 10/19/00 **VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE**

DATE: 10/18/00 PERMIT NO: 2239B
PARCEL NO: 139-251-30

JOB LOCATION ADDRESS: 9235 DOGWOOD RIDGE DRIVE
PROPERTY OWNER: CLAY HUCKS
BUILDING CONTRACTOR: "
SUBDIVISION NAME: DOGWOOD RIDGE, LOT #39
AUTHORIZATION ISSUED BY: [signature] DATE: 10/18/00
DEHNR AUTHORIZED AGENT

AUTHORIZATION CONDITIONS

1. WASTEWATER SYSTEM CONSTRUCTION AND INSTALLATION MUST MEET ALL CONDITIONS AND SPECIFICATIONS AS SET FORTH IN IMPROVEMENT PERMIT NO. 2239B, AND THE ATTACHED SITE PLAN WITH SYSTEM DETAILS. CONSTRUCTION AND INSTALLATION MUST ALSO MEET ALL REQUIREMENTS SET FORTH IN THE RULES GOVERNING SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL AND ANY OTHER APPLICABLE RULES AND LAWS.

2. AN INSTALLATION, CONSTRUCTION, ALTERATION AND/OR REPAIR APPROVAL MUST BE SECURED PRIOR TO INSTALLATION OF THE SEPTIC TANK SYSTEM. THE INSTALLER OF THE SYSTEM SHALL BE A REGISTERED SEPTIC TANK CONTRACTOR WITH MECKLENBURG COUNTY HEALTH DEPARTMENT.

3. ANY ALTERATION IN SITE OR SOIL CONDITIONS (INCLUDING LOCATION OF STRUCTURES AND APPURTENANCES) OR MODIFICATION IN USE, DESIGN WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS AS SPECIFIED IN THE ASSOCIATED IMPROVEMENT PERMIT AND APPLICATION, MAY SUBJECT THIS AUTHORIZATION AND ASSOCIATED PERMIT(S) TO REVOCATION.

4. OTHER CONDITIONS: ① SYSTEM IS III-B - SEE PLOT PLAN

OWNER CERTIFICATION

I CERTIFY THAT THERE HAVE BEEN NO ALTERATIONS IN SITE OR SOIL CONDITIONS OR MODIFICATIONS TO FACILITY, WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS FROM THOSE SPECIFIED IN THE ORIGINAL APPLICATION OR ASSOCIATED IMPROVEMENT PERMIT UNLESS AUTHORIZED IN WRITING BY THE MECKLENBURG COUNTY HEALTH DEPARTMENT. I ALSO UNDERSTAND THAT ANY SUCH ALTERATIONS, MODIFICATIONS, OR FALSE INFORMATION ARE GROUNDS FOR REVOCATION OF PERMITS AND AUTHORIZATION TO CONSTRUCT.

[signature] 10-19-00

SIGNATURE OF OWNER/OWNER'S REPRESENTATIVE DATE

MECKLENBURG COUNTY
ENGINEERING & BUILDING STANDARDS DEPARTMENT

Miscellaneous Fees

Requestor (Please print): Ray Hucks	Phone #:	Date Requested: 10/11/00	Date Filled:
Account Name: [illegible]	☐ Cash ☑ Charge		Account No.: 342360

I certify that I am authorized to charge this account for this service.

Signature: X [signature] Printed Name: X Ray Hucks Date: 10-17-00

Fee or Charge

T.C.	Qty.	Type	Unit Cost	Total Cost
021		Single Lot Grading Permit (Please list address below)		
112		Zoning Board of Adjustment ☐ Residential Variance Request ☐ Commercial Variance Request ☐ Residential Interpretation ☐ Commercial Interpretation		
113		Zoning Citation(s) # _____		
		☐ 117: Certificate of Compliance* ☐ 118: Certificate of Occupancy* (original is free)	$10.00 ea.	
119		Change of Contractor*	$10.00 ea.	
121		Letters of Certification/Verification	$10.00 ea.	
122		Monthly Statistical Reports	$10.00 ea.	
124		Research & Retrieval of Documents		
125		Temporary Utilities/Occupancy*	$30.00/insp.	
		Local License Card/Exam ☐ 128: Mechanical ☐ 129: Plumbing ☐ 132: Electrical		
		Development Activities Plan Review ☐ 002: Commercial Drainage ☐ 005: Erosion Control ☐ 016: Subdivision ☐ 006: Final Plat Review		
425		City of Charlotte Fire - Plan Review		
		Map Sales		
734	2	Other: Inst. to Construct	150.00	300
702	1	Other: Additional Site Inspections	100.00	100.00
Payment received by: [illegible]		Date: 10/11/00 By: JC	Total:	400.00

* Please list all permit numbers/addresses that relate to your request. A request for temporary utilities (gas and electric) would require two permit numbers.

1235 Dogwood Ave - T.I. 12398		
1215 Dogwood Ave - T.I. 22733		

B-216NS 8/95

WHITE – AUDIT CANARY – CUSTOMER PINK – DIVISION

Permit Number 0239B

Tax Number: 134-261-30

The IMPROVEMENT PERMIT is subject to revocation if site plans or the intended use change. There is to be NO grading, filling or disturbance of the soil in the area of the septic tank system or repair area.

CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is NOT transferable. Do not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.

Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement	___ Yes	X No	___ Partial Basement	
Type Primary Wastewater System Type (circle one): I II III IV V VI	___ Conventional ___ Prefabricated, permeable block panel system X Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimental: ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1	
3 Long-term acceptance rate	360 Max gallons/day wastewater flow	1200 Absorption Area (sq ft)	9' Trench spacing (min. on centers)	
YES Serviced by private well	1500 Gallon septic tank	400 Total trench length (ft)	30" Maximum trench depth (At least 12" of provisionally suitable soil must remain between trench bottom and unsuitable soil conditions)	
3 Bedrooms in residence	1000 Gallon pump tank	12" Depth of stone		
Any surface waters present:	Type:	Minimum separation distance:		
Site modifications required:				
Additional Conditions: ① INSTALL PRESSURE MANIFOLD AS A DISTRIBUTION DEVICE ② THIS IS A TYPE III-B SYSTEM WHICH IS REQUIRED BY N.C. STATE LAW TO BE INSPECTED AT LEAST ONCE EVERY 5 YEARS W/ HOMEOWNER RESPONSIBLE FOR ALL INSPECTION FEES.				
Repair Area System Type Type (circle one): I II III IV V VI	___ Conventional ___ Prefabricated, permeable block panel system X Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimental: ___ IWWS-93-1 ___ IWWS-93-2 ___ IWWS-94-1	
1200 Absorption Area (Sq ft) 400 Total Trench Length (Ft)	12" Depth of Stone Trench	9' Trench spacing (min. on centers)	30" Maximum Trench Depth	
For existing system, enter the year originally installed:				

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules For Sewage, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Department.
- This Improvement permit is transferable.

DEHNR Authorized Agent — Date: 10/18/00

Owner/Agent Signature — Date: 10-19-00

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR
SUITE 211
700 N. TRYON ST.
CHARLOTTE, N.C. 28202.
(704) 336-5102

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENTAL, HEALTH,
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

2239B
FILE: ~~139-251-3~~


TC: 139-25I-30

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.

SCALE 1" = 50'

PERMIT FOR:
9235 DOGWOOD RIDGE DRIVE
DOGWOOD RIDGE
LOT # 39

1. INSTALL ALL PARTS OF SEPTIC TANK SYSTEM 100' FROM ALL WELLS.
2. INSTALL PRESSURE MANIFOLD FOR A DISTRIBUTION DEVICE, TYPE ~~III~~ A-B
3. THIS SYSTEM REQUIRES A PUMP WHICH REQUIRES AN INSPECTION BY THE LOCAL HEALTH DEPT. BY EVERY 5 YEARS, AS REQUIRED BY STATE RULES, FOR WHICH THE HOMEOWNER IS RESPONSIBLE FOR ANY FEES AS SET BY THE MECK. CO. BOARD OF COMMISSIONERS.



9235 DOGWOOD RIDGE DRIVE

OWNER/AGENT SIGNATURE

DATE 10-19-00

APPROVAL DATE 10/18/00

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet: _____

Property ID: P0134-251-30

Lot #: 39

File #: 22398

AS #2

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Clay Hunter APPLICANT: _____

ADDRESS: 4231 Kendalton Meadow Dr, Charlotte DATE EVALUATED: 2-18-00

PROPOSED FACILITY: residence PROPOSED DESIGN FLOW (.1949) 360gpd PROPERTY SIZE: .91

LOCATION OF SITE: Dogwood Ridge Road PROPERTY RECORDED: _____

WATER SUPPLY: ~~Private~~ ☐Public ☐~~Well~~ ☐Spring ☐Other _____

EVALUATION METHOD: ~~☐Augur Boring~~ ☐Pit ☐Cut

TYPE OF WASTEWATER: ☐~~Sewage~~ ☐Industrial Process ☐Mixed

PROFILE #	Slopes 2-8% .1940 Landscape Position/ Slope %	Horizon Depth (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS &LTAR
1	LS	0-2"	gr/cl	Fr/SE XPl SS/SP	>40" TO soil wetness	40"	N/A	None	PS .391 Fr IV
		2-31"	SBK/c	Fi/SE XPl S/P					
		31-40"	SBK/cl	Fr/SE XPl SS/SP					
2	LS	0-3"	gr/cl	Fr/SE XPl SS/SP	>45" TO soil wetness	45"	N/A	None	PS .391 Fr IV
		3-30"	SBK/c	Fi/SE XPl S/P					
		30-45"	SBK/cl	Fr/SE XPl SS/SP					
3	~~LS~~ R	0-2"	gr/cl	Fr/SE XPl SS/SP	>47" TO soil wetness	47"	N/A	None	PS .391 Fr IV
		2-24"	SBK/c	Fi/SE XPl S/P					
		24-47	SBK/cl	Fr/SE XPl SS/SP					
4	~~LS~~ R	0-2"	gr/cl	Fr/SE XPl SS/SP	>44" TO soil wetness	44"	N/A	None	PS .391 Fr IV
		2-36"	SBK/c	Fi/SE XPl S/P					
		36-44"	SBK/cl	Fr/SE XPl SS/SP					
5	~~LS~~ R	0-4"	gr/cl	Fr/SE XPl SS/SP	>48" TO soil wetness	48"	N/A	None	PS .391 Fr IV
		4-40"	SBK/c	Fi/SE XPl S/P					
		40-48"	SBK/c	Fr/SE XPl SS/SP					
6	LS	0-3"	gr/cl	Fr/SE XPl SS/SP	>47" TO soil wetness	47"	N/A	None	PS .391 Fr IV
		3-39"	SBK/c	Fi/SE XPl S/P					
		39-47"	SBK/cl	Fr/SE XPl SS/SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	LS
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): Unsuitable

EVALUATED BY: W. A. Marlin LSS 2-21-00


OTHER(S) PRESENT: _____

FILE # 223903

COMMENTS 100% Repair

LANDSCAPE POSITION	GROUP	TEXTURE	.1955 LTAR	CONSISTENCE MOIST	CONSISTENCE WET
R-RIDGE	I	S-SAND	1.2-0.8		
S-SHOULDER SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE	NS-NON-STICKY
L-LINEAR SLOPE				FR-FRIABLE	SS-SLIGHTLYSTICKY
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8-0.6	FI-FIRM	S-STICKY
N-NOSE SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE	III	SI-SILT	0.6-0.3		SP-SLIGHTLYSTICKY
CV-CONVEX SLOPE		SICL-SILTY CLAY LOAM			P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAIN		SCL-SANDY CLAY LOAM			
	IV	SC-SANDY CLAY	0.4-0.1		
		SIC-SILTY CLAY			
		O-ORGANIC			

STRUCTURE	MINERALOGY
SG-SINGLE GRAIN	SLIGHTLY EXPANSIVE
M-MASSIVE	
CR-CRUMB	EXPANSIVE
GR-GRANULAR	
SBK-SUBANGULAR BLOCKY	
ABK-ANGULAR BLOCKY	
PL-PLATY	
PR-PRISMATIC	



Dogwood Ridge
Dr.

Call Clay 516-3748

PROPOSED PLOT PLAN


pd 100.00 + sent 2/28/00 SC

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 22390

TC: 00 139-251-30

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



OWNER/AGENT SIGNATURE

DATE 2-4-2000

APPROVAL DATE _____

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

MECKLENBURG COUNTY
ENGINEERING & BUILDING STANDARDS DEPARTMENT

Miscellaneous Fees

Requestor (Please print): Clayton Hucks	Phone #:	Date Requested: 2/24/00	Date Filled: 2/28/00
Account Name: Hucks Clayton E	☐ Cash ☒ Charge		Account No.: B42960
I certify that I am authorized to charge this account for this service.			
Signature: Per telephone w/B. Martin	Printed Name:		Date:

Fee or Charge

T.C.	Qty.	Type	Unit Cost	Total Cost
021		Single Lot Grading Permit (Please list address below)		
112		Zoning Board of Adjustment ☐ Residential Variance Request ☐ Commercial Variance Request ☐ Residential Interpretation ☐ Commercial Interpretation		
113		Zoning Citation(s) # _____		
		☐ 117: Certificate of Compliance* ☐ 118: Certificate of Occupancy* (original is free)	$10.00 ea.	
119		Change of Contractor*	$10.00 ea.	
121		Letters of Certification/Verification	$10.00 ea.	
122		Monthly Statistical Reports	$10.00 ea.	
124		Research & Retrieval of Documents		
125		Temporary Utilities/Occupancy*	$30.00/insp.	
		Local License Card/Exam ☐ 128: Mechanical ☐ 129: Plumbing ☐ 132: Electrical		
		Development Activities Plan Review ☐ 002: Commercial Drainage ☐ 005: Erosion Control ☐ 016: Subdivision ☐ 006: Final Plat Review		
425		City of Charlotte Fire - Plan Review		
		Map Sales		
0702	2	Other: Additional site evaluation, pit	100	200
		Other:		
Payment received by: Gwendolyn Craig		Date: 2/28/00 By: GC	Total:	200

* Please list all permit numbers/addresses that relate to your request. A request for temporary utilities (gas and electric) would require two permit numbers.

File 2271B 2273B (combine) 2274B		
(Dogwood Ridge lots 10, 12, 11)		

B-216NS 8/95

WHITE – AUDIT CANARY – CUSTOMER PINK – DIVISION

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: 490

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

22390
PO 139-251-30
L12

OWNER: Clay Hucks APPLICANT:
ADDRESS: 14231 Revelation Mendon Ch APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY: residence PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: .99
LOCATION OF SITE: Dogwood Ridge Dr PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	Slope-S 3-8% .1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	LS	0-3"	gr/cl	Fr/SEXP/SS/SP	2.5Y 7/1 @ 34"	39"	N/A	None	US IV
		3-39"	SBK/C	F:/SEXP/SP					
2	LS	0-3"	gr/cl	Fr/SEXP/SS/SP	>45" TO soil wetness	45"	N/A	None	PS .39/PZ IV
		3-30"	SBK/c	F:/SEXP/SP					
		30-45"	SBK/CL						
3	R	0-4"	gr/cl	Fr/SEXP/SS/SP	>48" TO soil wetness	48"	N/A	None	PS .39/PZ IV
		4-40"	SBK/c	F:/SEXP/SP					
		40-48"	SBK/CL	Fr/SEXP/SS/SP					
4	R	0-4"	gr/cl	Fr/SEXP/SS/SP	>43" TO soil wetness	43"	N/A	None	PS .39/PZ IV
		4-37"	SBK/C	F:/SEXP/SP					
		37-43"	SBK/CL	Fr/SEXP/SS/SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): Provisionally Suitable
EVALUATED BY: W. R. Merlin 11-39-1
OTHER(S) PRESENT: LSS

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

22393

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAI
5	R	0-4"	gr/c/	FI/SEXPI/SS/SP	> 48" TO soil wetness	48"	N/A	None	PS 39/F2 IV
		4-48"	SBK/c	FI/SEXPIS/P					
6	R	0-3"	gr/c/	FR/SEXPISS/SP	> 48" TO soil wetness	48"	N/A	None	PS 39/F2 IV
		3-45"	SBK/C	FI/SEXPI S/P					
		45-48"	SBK/C/	FI/SEXPI SS/SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: 100% Repair

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL 1955 LTAR	LPP 1957 LTAR	MINERALOGY/ CONSISTENCE	STRUCTURE
C (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive)	G (Single Grain)
V (Convex Slope)		LS (Loamy Sand)			SEXP (Slightly Expansive)	M (Massive)
(Drainage Way)					EXP (Expansive)	CR (Crumb)
S (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
P (Flood Plain)		L (Loam)				SBK (Subangular Blocky)
S (Foot Slope)						ABK (Angular Blocky)
(Head Slope)	III	SI (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
(Linear Slope)		SICL (Silty Clay Loam)				PR (Prismatic)
(Nose Slope)		CL (Clay Loam)				
(Ridge)		SCL (Sandy Clay Loam)			MOIST	WET
(Shoulder Slope)		SLC (Silt Loam Clay)				
(Terrace)					VFR (Very Friable)	NS (Non-sticky)
	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SIC (Silty Clay)			FI (Firm)	S (Sticky)
					VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None		EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)


OTES

ORIZON DEPTH	In inches below natural soil surface
EPTH OF FILL	In inches from land surface
ESTRICTIVE HORIZON	Thickness and depth from land surface
APROLITE	S(suitable) or U(unsuitable)
OIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designatic
LASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

valuation of saprolite shall be by pits.
ong-term Acceptance Rate (LTAR): gal/day/ft²

Show profile locations and other site features (dimensions, reference or benchmark, and North).

2 2390



Dogwood Ridge

2

FEE: 100.00 CK# 3763
DATE: 10/13/97

APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM

[ ] CRT

TYPE APPLICATION: ✓ NEW SYSTEM __ EXPANSION/ ALTERATION OF EXISTING SYSTEM __ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 2239B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 139-251-30 PT

STREET ADDRESS: [redacted] DOGWOOD RIDGE

SUBDIVISION OR MOBILE HOME PARK NAME:

LOT NUMBER: (30) - LOT 12

TOWNSHIP (CHECK ONE):

__ 0 MECKLENBURG
__ 1 CHARLOTTE
__ 2 DAVIDSON
__ 3 CORNELIUS
__ 4 PINEVILLE
__ 5 MATTHEWS
__ 6 HUNTERSVILLE
__ 7 MINT HILL

CLOSING DATE _____

TYPE OF BUILDING (CHECK ONE):

__ SINGLE MOBILE HOME(S)
__ DOUBLE WIDE (D)
✓ HOUSE (H)
__ MODULAR HOME (M)
__ MULTIPLE FAMILY (U)
__ OTHER (O)

HEATED SQUARE FOOTAGE: 1400

NUMBER OF BEDROOMS: 3 NUMBER OF OCCUPANTS: 2

FOUNDATION FOR RESIDENCE:

__ WITHOUT BASEMENT
__ ON SLAB
✓ CRAWL SPACE
__ WITH BASEMENT /PLUMBING
__ WITH BASEMENT /NO PLUMBING

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: __ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):
__ COMMUNITY (C)
__ MUNICIPAL (M)
✓ PRIVATE WELL (P)
__ SHARED WELL (S)
__ OTHER 'SPRINGS' (O)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES __ YES ✓ NO
EXISTING WASTEWATER SYSTEMS __ YES ✓ NO
EASTMENTS OR RIGHT-OF-WAYS __ YES ✓ NO
WELL, SPRINGS OR WATERLINES __ YES ✓ NO
DESIGNATED WETLANDS __ YES ✓ NO

PROPERTY OWNER: Clay Hucks

NAME: Hucks (LAST) Clay (FIRST) F (MI)

ADDRESS: 14231 Kendalton Meadow Dr.

CITY: Charlotte STATE: NC ZIP: 28277

DAYTIME PHONE: 704 545-0167

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: (LAST) (FIRST) (MI)

DAYTIME PHONE: ( ) —

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? 10-30-97

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

SIGNED: Clay Hucks DATE: 10-13-97

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 2239B

TC: 139-251-30 PP

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



OWNER/AGENT SIGNATURE

DATE 10-13-97

APPROVAL DATE _____

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

FEE: 35.00 CHK # 3738

DATE: 9-18-97

APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM

[ ] CRT

TYPE APPLICATION: ___ NEW SYSTEM ___ EXPANSION/ ALTERATION OF EXISTING SYSTEM ___ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Consultation

FILE #: 22358

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 139-251-30

STREET ADDRESS: 9225 DOGWOOD RIDGE DR

SUBDIVISION OR MOBILE HOME PARK NAME:

LOT NUMBER:

TYPE OF BUILDING (CHECK ONE):

___ SINGLE MOBILE HOME(S)
___ DOUBLE WIDE (D)
✓ HOUSE (H)
___ MODULAR HOME (M)
___ MULTIPLE FAMILY (U)
___ OTHER (O)

HEATED SQUARE FOOTAGE:

NUMBER OF BEDROOMS:

NUMBER OF OCCUPANTS:

FOUNDATION FOR RESIDENCE:

___ WITHOUT BASEMENT
___ ON SLAB
✓ CRAWL SPACE
___ WITH BASEMENT /PLUMBING
___ WITH BASEMENT /NO PLUMBING

TOWNSHIP (CHECK ONE):

✓ 0 MECKLENBURG
___ 1 CHARLOTTE
___ 2 DAVIDSON
___ 3 CORNELIUS
___ 4 PINEVILLE
___ 5 MATTHEWS
___ 6 HUNTERSVILLE
___ 7 MINT HILL

CLOSING DATE_____

Consultation Made 9-29-97
Clay Hucks present
W. B. Mullis 9-29-97

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: ___ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):

___ COMMUNITY (C)
___ SHARED WELL (S)
___ MUNICIPAL (M)
___ OTHER 'SPRINGS' (O)
✓ PRIVATE WELL (P)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES ___ YES ✓ NO
EXISTING WASTEWATER SYSTEMS ___ YES ✓ NO
EASTMENTS OR RIGHT-OF-WAYS ___ YES ✓ NO
WELL, SPRINGS OR WATERLINES ___ YES ✓ NO
DESIGNATED WETLANDS ___ YES ✓ NO

PROPERTY OWNER: N.B. Hathcock

NAME: Hathcock Blein B
(LAST) (FIRST) (MI)

ADDRESS: 2125 Island Forest Dr

CITY: Davidson STATE: ZIP: 28036

DAYTIME PHONE: ( ) ---

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: Hucks Clay
(LAST) (FIRST) (MI)

DAYTIME PHONE: ( ) - 545-0167

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? _____

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

SIGNED: Clay Hucks DATE: 9-18-97

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 2239B

TC: 139-251-30

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



OWNER/AGENT SIGNATURE

DATE 9-18-97

APPROVAL DATE _____

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

AUTHORIZATION

I, N.B. Hathcock, owner of the property located on Dogwood Ridge Drive in Country Hills Subdivision, identified as 9340 Dogwood Ridge Drive, approximately 13.99 Acres, parcel #139-251-28; 9225 Dogwood Ridge Drive, approximately 6.7 Acres, parcel #139-251-30 and 9200 Dogwood Ridge Drive, approximately 21.87 Acres, parcel #139-251-19 ,grant to Clayton E. Hucks, employees of environmental health or any other agency, firm or individual requested for services to enter upon the above properties for the purpose of soil/lot evaluations, planning and bringing equipment onto said land for the purpose of cutting paths or making lines. It is expressly agreed that no grading or clearing of this property will take place until the transfer of title. Only clearing necessary for access and lot/soil determination will be allowed.

N.B. Hathcock By: Beverly A. Hathcock
Authorized agent.
545-1996

N.B. Hathcock
September 17, 1997
704/596-3145

INFILTRATOR® SYSTEMS INC

Environmental Onsite Wastewater Solutions℠

North Carolina
Five Year Limited Warranty
Approved Effective April 24, 2002

Infiltrator Systems Inc. (hereinafter "the Company") hereby extends, for a period of FIVE (5) YEARS, the following Limited Warranty to the system owner who acquires through an authorized Infiltrator Systems installer a new infiltrator nitrification trench system including each chamber, endplate, wedge, and other accessories manufactured by Infiltrator (herein after collectively the Units) located in the State of North Carolina. The Units are warranted to be free from defective materials and workmanship and to perform in accordance with the state performance requirements (15A NCAC 18A Section.1900) in effect on the date of installation. This Limited Warranty applies only to those Units with a trench length modification greater than a 25% reduction as compared to the sizing standard for a conventional gravel trench as permitted by the State of North Carolina. This Limited Warranty is subject to the terms and conditions stated below.

I. WARRANTY ELIGIBILITY

The system owner is eligible for this Limited Warranty provided all of the terms and conditions of this Limited Warranty are strictly followed. The terms of this warranty shall transfer from the original system owner to subsequent system owners for the duration of this limited warranty. This Limited Warranty covers only the performance of the Units as manufactured and installed in accordance with the manufacturer's design specifications and current state regulatory approval.

II. CONDITIONS OF LIMITED WARRANTY

This Limited Warranty shall only apply if the Units are installed for use with domestic strength effluent and located in the State of North Carolina and all of the following terms and conditions are satisfied:

(i) The design and installation of the Units is according to all applicable plumbing and building codes, ordinances, requirements and regulations.
(ii) The design and installation of the Units is strictly according to the rules and regulations of the North Carolina state agency or state-authorized agency that is responsible for inspection and approval.
(iii) The design and installation of the Units is strictly according to all applicable permitting procedures for the Units adopted by the North Carolina state agency or state authorized agency that is responsible for inspection and approval.
(iv) The Units are subject to use permitted by the applicable North Carolina rules and regulations for on-site systems.
(v) Only an authorized Infiltrator installer shall perform the installation of the Units.

III. WHAT IS WARRANTED AND FOR HOW LONG

The Units are warranted for FIVE (5) YEARS from the date of issuance of the Certificate of Occupancy, or date of issuance of the Operation Permit, which ever is later.

If the Units fail within the five (5) year period of this Limited Warranty and all of the terms, conditions and requirements of this Limited Warranty have been met, the Company shall provide all materials and labor that may be necessary to provide a fully functional wastewater system at no cost to the Owner. This section shall not be construed to require that a manufacturer warrant an innovative wastewater system that is not properly sized to meet the design load required for a particular use, that is improperly installed, or that is improperly operated and maintained, in accordance with 15A NCAC 18A .1900 et. seq. Warranty repairs such as full replacement of the nitrification system , extension of the nitrification system or other repairs shall be completed pursuant to a repair Authorization to Construct to be issued by the local health department in accordance with Rule .1961(1).

A system failure is defined by North Carolina 15A NCAC 18A.1900 rules.

IV. WHAT IS NOT COVERED BY THIS LIMITED WARRANTY

1. The septic tank and all septic tank filters, unless required to make the system fully functional.
2. Effluent distribution box(es) and headers, unless required to make the system fully functional.
3. Improper installation.
4. Failure due to excessive use or improper use as defined by state rules for on-site wastewater systems, including, but not limited to, excessive water usage, improper grease disposal, or failure to remove septic tank solids (digested sludge).
5. Landscaping costs other than those specified by rule.
6. Failure due to improper sizing as defined by state rules.
7. Repair work performed prior to a claim or which is done without the Company's authorization.
8. This Limited Warranty does not extend to incidental, consequential, special, indirect or punitive damages.
9. Drain fields repaired or modified by an unauthorized Infiltrator installer.

V. THE COMPANY'S OBLIGATIONS:

No representative of the company has the authority to change this warranty in any manner whatsoever, or to extend this warranty. No warranty applies to any party other than the original system owner or subsequent system owner.

VI. OWNER'S OBLIGATION:

1. Must have signed and dated Operation Permit from the duly authorized representative of the North Carolina state agency or state authorized agency that is responsible for inspection and approval of the Units.
2. Must have a Warranty Certificate from an authorized Infiltrator installer.
3. The system owner must notify the company in writing at its corporate headquarters with 90 days of being notified by an authorized agent of the state that the system has failed. Notice shall be sent to Infiltrator Systems Inc., 6 Business Park Road, P.O. Box 768, Old Saybrook, CT 06475.
4. The system owner must have the septic tank solids (digested sludge) properly removed in accordance with state rules for on-site systems.

VII. DISCLAIMER AND LIMITATION ON IMPLIED WARRANTIES

ALL WARRANTIES AND REMEDIES CONTAINED HEREIN ARE EXCLUSIVE AND THERE ARE NO OTHER WARRANTIES. ANY IMPLIED WARRANTIES OF MECHANTABILITY AND OE FITNESS FOR A PARTICULAR PURPOSE, IMPOSED ON THE SALE OF THE UNITS TO THE NORTH CAROLINA SYSTEM OWNER, ARE, BY LAW, LIMITED TO FIVE (5) YEAR DURATION FOR THE UNITS AND THEIR CONSTITUENT PARTS, AND ARE SUBJECT TO THE TERMS AND CONDITIONS OF THIS LIMITED WARRANTY. THIS WARRANTY DOES NOT EXTEND TO INCIDENTAL, CONSEQUENTIAL, SPECIAL, DIRECT OR INDIRECT DAMAGES, WHETHER ARISING IN CONTRACT OR TORT. THE COMPANY SHALL NOT BE LIABLE FOR LOSS OR DAMAGE TO PERSONAL PROPERTY, PENALTIES OR LIQUIDATED DAMAGES, LOSS OF PRODUCTION AND PROFITS, OVEHEAD COSTS, OR OTHER LOSS OR EXPENSE. SPECIFICALLY EXCLUDED ARE DAMAGE DUE TO WATER DAMAGE, ORDINARY WEAR AND TEAR, ALTERATION, ACCIDENT, MISUSE, ABUSE, OR NEGLECT; THE UNITS BE SUBJECTED TO STRESSES OR VEHICULAR TRAFFIC GREATER THAN THOSE PRESCRIBED IN THE INSTALLATION INSTRUCTIONS OR OPERATION INSTRUCTIONS; FAILURE TO MAINTAIN THE MINIMUM GROUND COVERS SET FORTH IN THE OPERATION INSTRUCTIONS; THE; SYSTEM FAILURES DETERMINED TO BE DUE TO NONCOMPLIANCE WITH THE ON-SITE WASTEWATER LAW OR RULES (130A-133, et.seq.; 15A NCAC 18A Section .1900) INCLUDING BUT NOT LIMITED TO IMPROPER SITING, EXCESSIVE WATER USAGE, IMPROPER GREASE DISPOSAL, PLACEMENT OF IMPROPER MATERIALS INTO THE SYSTEM, IMPROPER OPERATION OR IMPROPER MAINTANENCE; OR ANY OTHER EVENT NOT CAUSED BY THE COMPANY. THIS PERMIT SHALL BE VOID IF THE SYSTEM OWNER FAILS TO COMPLY WITH ALL OF THE TERMS SET FORTH IN SECTION II AND IV OF THIS WARRANTY.

FURTHERMORE, IN NO EVENT SHALL THE COMPANY BE RESPONSIBLE FOR ANY LOSS OR DAMAGE TO THE ORIGINAL OR SUBSEQUENT SYSTEM OWNER(S), THE UNITS, OR ANY THIRD PARTY RESULTING FROM SHIPMENT OF THE UNITS, OR FROM ANY PRODUCT LIABILITY CLAIMS OF THE ORIGINAL OR SUBSEQUENT SYSTEM OWNER(S) OR ANY THIRD PARTY.

THIS LIMITED WARRANTY GIVES YOU SPECIFIC LEGAL RIGHTS, NORTH CAROLINA LAW MAY GIVE YOU CERTAIN SPECIFIC OTHER RIGHTS WHICH ARE NOT MENTIONED HEREIN.

VIII. TRANSFER OF WARRANTY

This warranty extends to the original system owner and each subsequent owner of the system during the term of this limited warranty.

IX. INSTALLER CERTIFICATION

"I acknowledge to the company and the system owner that the wastewater system and the Infiltrator have been installed in accordance with the installation instructions of the company, state wastewater laws and rules, the innovative wastewater system approval, the improvement permit and authorization to construct, and any conditions on the permit or authorization to construct, and other applicable laws and rules."

Lot #39 9235 Dogwood Ridge
Physical Address of System Installation or Lot Number

Bldr. Clay Hacker
Charlotte, NC 28212

Mc Carver Septic Tanks
Business Name of Installer

Bobby McCarver
Name of Person Signing (Print)

Bobby McCarver 11-1-02
Signature Date

6 Business Park Road • P.O. Box 768 • Old Saybrook, CT 06475 • 800-221-4436 • 860-577-7000 • Fax 860-577-7001 • www.infiltratorsystems.com

White Copy: Department of Health Yellow Copy: System Owner Pink Copy: Infiltrator Systems