

8615 WALKERS FERRY RD

11313311

7/18/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

113-132 11 15189
1952

Mecklenburg County
Health Department

December 31, 1991

William Gordon Stewart, Jr.
8615 Walkers Ferry Road
Charlotte, N.C. 28214

Dear Mr. Stewart:

At your realtors request, an investigation was made of the septic tank system and a well water sample was collected on the property located at 8615 Walkers Ferry Road, Charlotte, North Carolina on December 16, 1991.

At the time of the investigation there was no effluent apparent on the surface of the ground; however, a straight pipe for the washing machine was found which discharged effluent to the surface of the ground. You were advised of this by a letter dated December 26, 1991.

At your request, I revisited the site on December 30, 1991 to observe the removal of the plumbing connections and straight pipe for the washing machine. You had requested this option rather than install a separate nitrification field for the washing machine.

The current septic system is inadequate to accept the effluent from a washing machine. Use of a washing machine is prohibited. If facilities are desired in the future, and prior to the placement of a washing machine in the residence, this office must be contacted to secure a permit for the installation of a drainfield to accomodate the washing machine wastewater.

The laboratory analysis of the well water sample was reported to be negative for coliform bacteria.

I was unable to conduct an evaluation of the well structure as the well house was inaccessible at the time of my visit.

If you have any questions concerning this matter, please contact me at 336-5571.

Sincerely,

Judy J. Kiser R.S.

Judy J. Kiser, R.S.
Individual Water and Wastewater Systems

JK:lw

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603