Date Received 10-23-73

MECK COUNTY HEALTH DEPT.
RECEIVED
OCT 23 1973
ENVIRONMENTAL HEALTH Division

APT No. 7121

T. C. No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Waco Realty Company
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 1008 East Blvd. Charlotte, N. C. 28203 ZIP

3) PHONE NO. Home _____ Office 333-8477


4) LOCATION OF PROPERTY 8901 Powell Drive
(STREET OR COUNTY ROAD)

5) SUBDIVISION White Forest LOT NO. 50 BLOCK NO. _____

MAP BOOK NO. 7 PAGE NO. 695

6) DEED REFERENCE: DEED BOOK 3111 PAGE NO. 155

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mike Cochrane
OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Date Received 10-18-73

MECK COUNTY HEALTH DEPT.
RECEIVED
OCT 17 1973

ICAR(S) Application No. 7124

T. C. No.

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1) X Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms four

5) Business Use — Max No Employees

6) Washing Machine X Yes No

7) Garbage Disposal X Yes No

8) Dishwasher X Yes No

9) Water Supply:
A) Individual Well Yes
B) Governmental System
C) Community System:
1. Well source
2. Governmental source

10) Sewage System:
House located within 200 feet of public sewer Yes X No
House located within 200 feet of community sewer Yes X No

11) FHA Case No.

12) VA Case No.

13) NAME OF OWNER Waco Realty Company (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER 1008 East Blvd. Charlotte, N. C.

15) PHONE NO. Home _____ Office 333-8477

16) LOCATION OF SYSTEM 8901 Powell Drive (STREET OR COUNTY ROAD)

17) SUBDIVISION White Forest Lot No. 50 Block No.

Map Book No. 7 Page No. 695

18) DEED REFERENCE — DEED BOOK 3544 AT PAGE 237

19) HAS A PERCOLATION TEST BEEN RUN? _____ YES X NO DATE RUN

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

OCTOBER 15, 1973
DATE OF APPLICATION

Mike Cochran
OWNER

FORM NO. E-4-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 1/12/77

APT No. 7124

T. C. No. 109-083-01

Map Date 1-3-76

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Brumble (LAST) William (FIRST) Bruce (MIDDLE)

2) ADDRESS OF OWNER 2115 Laburnum Ave Charlotte ZIP 28215

3) PHONE NO. Home 377-1456 Office 535-6000


4) LOCATION OF PROPERTY Powell Road (STREET OR COUNTY ROAD)

5) SUBDIVISION Whitegate LOT NO. 50 BLOCK NO.

MAP BOOK NO. 7 PAGE NO. 695

6) DEED REFERENCE: DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Robinson Church Rd

OWNER W. B. Brumble

EHD-S-76

Environmental Health Department's Copy

SOIL INVESTIGATION REPORT

Date of Investigation January 12, 1977 APT NO. 7124

Owner W. B. Brumble

Location of Property Powell Road lot No. 50 Tax Code No. 108-083-01

Soil Suitability Ratings

Soil Properties	Soil 1	Soil 2	Soil 3	Soil 4
1. Soil Series	ENON			
2. Soil Slope	Suitable 3-8%			
3. Soil Depth	unsuitable <40"			
4. Soil Texture	unsuitable 2:1 Expanding clay			
5. Soil Structure	unsuitable massive			
6. Restrictive Horizons	—			
7. Soil Drainage	unsuitable perched high water table and intermittent water present			
8. Soil Permeability (Percolation Rate)	unsuitable very slow >120 min/in			
9. Other				
10. Overall Rating	unsuitable			


Recommendations Based on this investigation, the lot is not recommended for approval for installation of a septic tank system.

See diagram on back

W. Edward Cusavitt
Soil Scientist

3/18/75
ESD 539

DIAGRAM OF PROPERTY



3/18/75

339

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

DATE ISSUED
1. 1/18/77
2. _____
3. _____

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR NO. 7324
T.C. NO. 108-088-01
MAP DATE 1-30-76

NAME OF OWNER Brumble, William Bruce, Jr.

ADDRESS OF OWNER 2116 Laburnum Avenue, Charlotte, N. C. 28208

LOCATION OF LOT Pssell Road, Lot 50 White Forest Subdivision

The lot described above is not recommended for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

Soil permeability unsuitable

Percolation rate in excess of 200 min./in.

John R. Atkisson, Environmentalist
On Premises Waste Disposal Section

JRA:jjk

(Stencil No.)
EHD 398
8/74

FORM NO.
E-13-8-21-74

Date Received_____ APT No._____

T. C. No._____

Map Date_____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Computerized Apartment Locators Inc.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 1025 South Tryon St. Charlotte, N. C. ZIP 28203

3) PHONE NO. Home 334-1336 Office 377-3611 or 376-5531


4) LOCATION OF PROPERTY Powell Drive
(STREET OR COUNTY ROAD)

5) SUBDIVISION White Forest LOT NO. 50 BLOCK NO._____

MAP BOOK NO. 7 PAGE NO. 695

6) DEED REFERENCE: DEED BOOK 3985 PAGE NO. 421

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mike Cockinos
OWNER Mike Cockinos

EHB-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 7124
T.C. NO. 108-083-01
MAP DATE 1-30-76
DATE 1-11-78

NAME OF OWNER Computerized Apartment Locators, Inc.

ADDRESS OF OWNER 1025 South Tryon Street, Charlotte, NC 28203

LOCATION OF LOT Powell Drive, Lot 50, White Forest Subdivision

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive.
Soil Permeability Unsuitable.

John R. Atkisson
John R. Atkisson, Environmentalist
On Premises Waste Disposal Section

JRA:glr

END 398
7/77

17