Date Received 1-29-79

1

APT No. 15067

T. C. No. 227-227-15

Map Date 8/9/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER NORTH CAROLINA NATIONAL BANK (LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER REAL EST. DEPT. CHARLOTTE, N.C. ZIP

3) PHONE NO. Home 847-4953 (PUSS ISIDOR) Office 374-5935 (BILL PITMAN)


4) LOCATION OF PROPERTY FRIENDSHIP DRIVE (STREET OR COUNTY ROAD)

5) SUBDIVISION EASTWOOD FOREST LOT NO 8 BLOCK NO. 227

MAP BOOK NO 227 PAGE NO. 22

6) DEED REFERENCE DEED BOOK 3784 PAGE NO 0957

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

North Carolina National Bank
for Bill PITMAN - Tel 374-5935
OWNER

copy To

R. L. ISBER
1600 Fox Lake Drive
Matthews, NC

EHO-S-76

Environmental Health Department's Copy

15067

227-227-15

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: North Carolina National Bank
ADDRESS: Real Estate Dept. Charlotte
COUNTY: Mecklenburg
LOCATION OF SITE: Lot 5 Block 227 Friendship Drive

DATE REQUESTED: 1-29-79
PLAT NO.:
LOT SIZE: 20,000 square feet

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 0-2% U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2:1 clay (U)	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS massive (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S (PS) none U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S seasonal perched watertable PS (U)	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS slow (U)	S PS U	S PS U	S PS U
8. OTHER (Specify)	S adequate area (PS) U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	U			
SOIL SERIES				

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: Michael G. Sexton
Title: Sanitarian II Date: February 2, 1979

DHS Form 2601 (2/77)
Sanitation

100'
creek
200'
200'
U
100'
Friendship Drive

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15067
T.C.NO. 227-227-15
MAP DATE 9/9/78
DATE February 5, 1979

NAME OF OWNER North Carolina National Bank

ADDRESS OF OWNER Real Estate Department

LOCATION OF LOT Friendship Drive, Eastwood Forest, Lot 8, Block 227

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive
Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R. Adkisson, Environmentalist

EHD 999 (1/79)

R