Date Received 3/8/83

MECK COUNTY DEPARTMENT OF
RECEIVED
MAR - 8 1983
ENVIRONMENTAL HEALTH

SIR No. 19418
T. C. No. 053-093-01
Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Locate (LAST) Ann (FIRST) L (MIDDLE)

2) ADDRESS OF OWNER 2220 Roswell Ave ZIP 28207

3) PHONE NO. Home 375-9543 Office


4) LOCATION OF PROPERTY Hawfield Rd SR 1604
(STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO. 647 BLOCK NO.

MAP BOOK NO. PAGE NO.

6) DEED REFERENCE: DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.




7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 4961

PTR No. 19418

T. C. No. PO 053-093-01

Date Issued 4-18-83

Map Date


# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## SOIL INVESTIGATION REPORT

NAME OF OWNER Locatis, (LAST) Ron (FIRST) R. (MIDDLE)

ADDRESS OF OWNER 2220 Roswell Ave., Charlotte, NC ZIP 28207

LOCATION OF PROPERTY Hawfield Road (STREET OR COUNTY ROAD)

SUBDIVISION 150' LOT NO. 6 & 7 BLOCK NO.




PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or the wastewater treatment system on the said lot.
2. The size of the septic tank and wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building or number of bedrooms.
3. This approval is valid only for the system installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable. For installation, construction, alteration, and repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William R. Marlin
Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

EHD-S-76

**Environmental Health Department's Copy**

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 1948

T.C. NO. PO 053-07301

(Ground Absorption Sewage Disposal)

OWNER: Ron R Lentis
ADDRESS: 2220 Roswell Ave
Charlotte, NC 28209
LOCATION OF SITE: Pamphrey Road

PLAT NO: 6617
LOT SIZE: Approx 82,500 sq.

| FACTORS | AREA 1 | AREA 2 | AREA 3 | AREA 4 |
|---|---|---|---|---|
| 1. SLOPE (%) | S (PS) U 6-12% | S PS U | S PS U | S PS U |
| 2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay) | S (PS) U Clay | S PS U | S PS U | S PS U |
| 3. SOIL STRUCTURE (12-36 inches) | S (PS) U Blocky | S PS U | S PS U | S PS U |
| 4. SOIL DEPTH (inches) | S (PS) U 36-40" | S PS U | S PS U | S PS U |
| 5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock) | S (PS) U Saprolite 36" | S PS U | S PS U | S PS U |
| 6. SOIL DRAINAGE/GROUNDWATER (external and internal) | (S) PS U >46" to ground water | S PS U | S PS U | S PS U |
| 7. OTHER (Specify) | S PS U old terraces present | S PS U | S PS U | S PS U |
| 8. SOIL GROUP | IVA | | | |
| 9. SITE CLASSIFICATION | Provisionally Suitable | | | |
| 10. SOIL SERIES | Cecil Like | | | |

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: No house site spotted

Described by: William R. Martin
Title: Soil Scientist

Date: 4/15/83

EHD 539 (Revised: 6/82)




New Field Rd