Date Received 6-8-83

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN 8 1983
ENVIRONMENTAL HEALTH

SIR No. 19754

T.L. No. 015-121-07

Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER BARNETTE (LAST) Steve (FIRST) Eugene (MIDDLE)

2) ADDRESS OF OWNER Po Box 642 Davidson, NC. ZIP 28036

3) PHONE NO. Home 892-3537 Office


4) LOCATION OF PROPERTY 8627 HAMBRIGHT (STREET OR COUNTY ROAD) Rd

5) SUBDIVISION LOT NO BLOCK NO.

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge




7) ACCURATELY DIAGRAM & DIMENSION LOT

Steve E. Barnette
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 5085

SIR No. 19754

Date Issued 6-24-83

T C No. PO 015-121-07

Map Date


# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## SOIL INVESTIGATION REPORT

NAME OF OWNER Barnette, Stevie E.
(LAST) (FIRST) (MIDDLE)

ADDRESS OF OWNER PO Box 642 Davidson, NC ZIP 28036

LOCATION OF PROPERTY 8627 Hambright Road
(STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and onsite investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. Said investigation was conducted on that portion of the lot as indicated on the above plot. **Provisionally Suitable**

The permeability rate determined by the investigation was . The said lot is approved for the installation of an individual septic tank aerobic treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install a system after a repair the septic system may be issued from the Mecklenburg County Department of Environmental Health prior to the beginning of any system installation or the wastewater treatment system on the said lot.
2. The size of the septic tank/aerobic treatment system which must be installed is determined by the Mecklenburg County Department of Environmental Health prior to the issuance of the permit. The rate obtained above and the size and type of building is restricted thereto.
3. This approval is valid only for the system installed in the immediate area staked as acceptable for system installation on the above plot.
4. This approval is void if any alteration, addition, change, or repair is performed on the system which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable. This includes any construction altering the original design of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

EHD-5-76 **Soil Scientist**

Environmental Health Director or Authorized Section Head

Environmental Health Department Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 14754

T.C. NO. PO 015-121-07

(Ground Absorption Sewage Disposal)

OWNER: Mark Harnell
ADDRESS: P.O. Box 642 Davidson, N.C. 28036
PLAT NO:
LOT SIZE: About 50,000 sq.ft.
LOCATION OF SITE: 6627 Homewood Road

| FACTORS | AREA 1 | AREA 2 | AREA 3 | AREA 4 |
|---|---|---|---|---|
| 1. SLOPE (%) | S (PS) U — 3 to 6% | S (PS) U — 2-8% | S PS U | S PS U |
| 2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay) | S (PS) U — clay | S (PS) U — 2-1 clay | S PS U | S PS U |
| 3. SOIL STRUCTURE (12-36 inches) | S (PS) U — Blocky | S (PS) U — Blocky | S PS U | S PS U |
| 4. SOIL DEPTH (inches) | S (PS) U — 36-48" | S (PS) U — 36-48" | S PS U | S PS U |
| 5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock) | S (PS) U — >36" | S (PS) U — >36" | S PS U | S PS U |
| 6. SOIL DRAINAGE/GROUNDWATER (external and internal) | S (PS) U — >36" to ground water | S PS (U) — Slight Depression | S PS U | S PS U |
| 7. OTHER (Specify) | S PS U | S PS U | S PS U | S PS U |
| 8. SOIL GROUP | IC F | IV B | | |
| 9. SITE CLASSIFICATION | Provisionally Suitable | unsuitable | | |
| 10. SOIL SERIES | Cecil Lk | Vance Lk | | |


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William R. Marion
Title: Soil Scientist
Date: 6-21-83

EHD 539 (Revised: 6/82)


Trailer location

Date Received 6-8-83

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH RECEIVED JUN 8 1983

ICAR (S) Application No. 19754

T Rec. 015-121-07


Map Date _____

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**Application for an**
**Installation, Construction, Alteration, and/or Repair Permit**
**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge




3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ✓ Yes ___ No
Residence ___ Yes ___ No

4) No of Bedrooms 2
5) Business Use -- Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ___ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER BARNETTE (LAST), STEVIE (FIRST) EUGENE (MIDDLE)

14) ADDRESS OF OWNER P.O. Box 242 DAVIDSON, NC. 28036

15) PHONE NO. Home 892-3537 Office ___

16) LOCATION OF SYSTEM 8627 HAMBRIGHT Rd. (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

6-8-83
DATE OF APPLICATION

Stevie E. Barnette
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Mecklenburg County

Department Of Building Standards
And Code Enforcement

P. O. Box 31037

Charlotte, North Carolina 28231

6/8/83

To: ENVIRONMENTAL HEALTH DEPARTMENT
BLYTH BLVD.
MECKLENBURG COUNTY
CHARLOTTE, N.C.

Reference: MOBILE HOME PLACEMENT

Dear MR. SEXTON,

The parcel of land located at 8627 Hambright Rd (0)
and further identified by tax parcel number 015-121-07 (Portion of)
is zoned RU ( RURAL ).

Permitted uses in this district include:
Mobile homes on individual lots

If this office can be of further assistance, please contact us.

Very truly yours,

John F Evans

Zoning Inspector


Date Issued 6-23-83 Serial No. 6387 ICAR(S) Permit No. 19754

PO T C No 015-121-07

Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
### (Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct. ____Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19754, dated 6-8-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 7-23-83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate P 5

Liquid Capacity of Tank 1500 gal

Tank Construction R/C Concrete

Absorption and/or Nitrification Lines

Total Line Length 200'

Number of Lines 3

Distance from House >5'

Distance from Property Line >10'

Distance to Well >50'

NAME OF OWNER Highbright Rd. Stevie E. Barnette

LOCATION OF PROPERTY 8627 Hamlright Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

3-67 ft lengths 3 ft wide x 12" stone

Comments:

Division or Section Head

Environmentalist E.F. Hodges

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

BF 6-29-83

Serial No. 6554

SIR No. 19754

Date Issued 6-28-83

T. C. No. PO 015-121-07

Map Date _____

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**TO THE BUILDING INSPECTION DEPARTMENT**

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Barnette, (LAST) Stevie (FIRST) Eugene (MIDDLE)

ADDRESS OF OWNER P. O. Box 642, Davidson, NC ZIP 28036

LOCATION OF LOT 8627 Hambright Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19754. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist R P Phelps

Environmental Health Director, or Authorized Section Head Eric D. Hardister

EHD-5-76

**Environmental Health Department's Copy**

6-28-83

C of A (s) No. 19754

Date Issued 6-27-83 Serial 5947 P.C. No. 015-121-07

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## CERTIFICATE OF APPROVAL

**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

Name of Owner Barnette (LAST) Stevie (FIRST) E (MIDDLE)

Location of Property 8627 Hambright Rd

Application Number 19754 Permit Number 19754

**Inspection Data:**

Liquid Capacity of Tank 1500 gal Tank Material plc concrete

Total Length of Drain Tile 225' Number of Lines 3

Depth of Filter Material 12" Cover Depth 1'

Water Supply Source well Distance from Water Source 75' not in yet

Excavation Inspected — (DATE) Tank Inspected 6-27-83 (DATE)

Nitrification Field Inspected 6-27-83 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system

Comments

Environmentalist

EHO-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

# APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 19754

TP 015-121-07 L

RECEIVED
MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

**JOB LOCATION**

① ADDRESS: 8627 (STREET NO.) Hambright Road (STREET) ② FILE: 19754

③ CITY: Huntersville ④ TAX PARCEL NO.: PO 015-121-07

⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

**OWNER**

⑧ NAME: Stevie (FIRST) Eugene (MIDDLE) Barnette (LAST)

⑨ MAILING ADDRESS: Route 3, Box 760

⑩ CITY: Huntersville ⑪ STATE: NC ⑫ ZIP: 28078

⑬ PHONE: (WORK) 875-1361, x-241 (Anita Barnette) ⑭ (HOME) (704) 875-6390

**REQUEST**

This request is for a(n):

⑮ ☐ New installation permit

⑯ ☒ Repair or alteration permit — Extra BDR w/dss

⑰ ☒ Authorization for mobile home exchange — also

⑱ ☐ Other (specify)

**DESIGN CRITERIA**

System will serve:

⑲ ■ Residence ⑳ ☐ Mobile home

㉒ Number of bedrooms? 3

㉓ Maximum occupancy? 4


㉔ Basement? ☐ yes ■ no

㉑ ☐ Business or place of public assembly

㉕ Type?

㉖ Maximum number of employees?

㉗ Maximum number of seats?




㉘ Accurately dimensioned plot

**WATER SUPPLY**

㉙ Water supply from (present or proposed):

A ■ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉚ The undersigned, owner of the property described above as "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Stevie E. Barnette

Date: 9-26-85

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Date Issued 10-3-85

Serial No. 8957

SIR No. 19754

T. C. No. PO 015-121-07

Map Date L (?RT

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**TO THE BUILDING INSPECTION DEPARTMENT**

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Barnette, (LAST) Stevie (FIRST) E. (MIDDLE)

ADDRESS OF OWNER P.O. Box 642, Davidson, NC ZIP 28036

LOCATION OF LOT 8627 Hambright Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO._____ BLOCK NO._____

MAP BOOK NO._____ PAGE NO._____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19754. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

*** USE EXISTING SYSTEM ***

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy