

5907 FOX CROSSING DR

03516222

6/11/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 6116A DATE: 5/18/90

TC: 035 16 209 ☐ L ☐ CRT

SERIAL № 11685

Name of Owner DAVID A. JOHNSON Juris.:

Address of Property 5907 Fox Crossing

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 5 @ 80'

Cover Depth 12"

Water Supply Source CMUD

Distance to Water Source >50

Excavation Inspected Y

Tank(s) Inspected Y

Wash Line Inspected —

High Water Alarm Inspected —

PLOT

Design: 1500 ST, CDN, 1200SFT, 12"G, CECIL like CTR# 87

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☑ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 3 bedrm - (5) 3'x80'x12", Straw.

Tim Wheeler, R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 6116A DATE: 5/18/90

TC: 035 16 209 ☐ L ☐ CRT

SERIAL № 11685

Name of Owner DAVID A. JOHNSON Juris.:

Address of Property 5907 Fox Crossing

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 5 @ 80'

Cover Depth 12"

Water Supply Source CMUD

Distance to Water Source >50

Excavation Inspected Y

Tank(s) Inspected Y

Wash Line Inspected —

High Water Alarm Inspected —

PLOT

Design: 1500 ST, CDN, 1200 SFT, 12" G, CECIL like CTR# 87

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☑ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 3 bdrm - (5) 3'x80'x12", Straw.

Jim Wakefield, R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 6116A DATE: 4/30/90

TC: 035 16 209 A L

SERIAL Nº 13236

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 9/28/89. All work shall be completed on or before 5/30/90, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Total Line Length 400' feet

Number of Lines 5 or 6

Depth of Stone 12" inches

Distance from House 10 feet

Distance from Property Line 10 feet

Distance from Well CMUD feet

NAME OF OWNER David A. Johnson

LOCATION OF PROPERTY 5907 Fox Crossing Dr.

Comments: 3 bedrm. (5) 3'x80'x12"G or (6) 3'x67'x12" STRAW ditches. * Install within time frame OR OWNERS REQUEST.

Division or Section Head

Tim Whittaker B.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

September 19th, 1989

Ronald Dwight Henry
7225 Pleasant Grove Road
Charlotte, NC 28216

RE: Property located at Fox Crossing Drive
FILE: 6116A
Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 16421) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Very truly yours,

Gene Vaughan, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 16421

File: 6116A

Action 4

Parcel: 03516209

☐ PC

Location: Fox Crossing Drive

Subdivision:


Lot: Block: Acres: .79

Owner:
Address: Ronald Dwight Henry
7225 Pleasant Grove Road
Charlotte, NC 28216

Comments:

Described by: W. B. Ramsey

Date: 9-18-89



***** EVALUATION KEY *****

S = *Suitable* U = *Unsuitable*
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-6	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 40-45	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIa Cecil					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

9-13-89

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: LO 116A

TC: 035-062-09

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 5907 Fox Crossing Drive, Charlotte, N.C. 28216

② SUBDIVISION: Fox Crossing ③ LOT: 5 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: Map Book 22 PAGE NO.: 92h PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Ronald (FIRST) Dwight (MIDDLE) Henry (LAST)

⑧ MAILING ADDRESS: 7225 Pleasant Grove Road

⑨ CITY: Charlotte, N.C. ⑩ STATE: N.C. ⑪ ZIP: 28216

⑫ PHONE: (WORK) 394-0311 (HOME) 392-5590

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: _____

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 9-6-89

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 6116 A

TC: 035 16 209

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Approved 10/17/89
P. Walker

Signed: [signature]

Date: 10/17/89

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 10/2/89

Name/Company: Hunter & Son Construction

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: UNP - new
5909 Tar/Cypress Dr

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
OCT 2 1989

Fee: $ 200.00

CK # 11317
$200.00

NOTICE:

A processing fee of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512.

Completed by _____

Collected by _____

BILLING — WHITE CUSTOMER COPY — YELLOW

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 9/8/89

Name/Company: R.O. Henry

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Soil
Cell 6A
Inac

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
SEP 8 1989

Fee $ 40.00

Ck # 844
$40.00

NOTICE:

A processing fee of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512

Completed by

Collected by

BILLING — WHITE CUSTOMER COPY — YELLOW

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

RECEIVED
MECKLENBURG COUNTY
HEALTH DEPT.
SEP 1989
ENVIRONMENTAL HEALTH
DIVISION

FILE: 6116A

TC: 035-062-09

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 5907 Fox Crossing Drive, Charlotte, N.C. 28216

② SUBDIVISION: Fox Crossing ③ LOT: 5 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: Map Book 22 PAGE NO.: 92L PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Ronald (FIRST) Dwight (MIDDLE) Henry (LAST)

⑧ MAILING ADDRESS: 7225 Pleasant Grove Road

⑨ CITY: Charlotte, N.C. ⑩ STATE: N.C. ⑪ ZIP: 28216

⑫ PHONE: (WORK) 394-0311 (HOME) 392-5590

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: _____

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 9-6-89

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

RECEIVED
MECKLENBURG COUNTY
HEALTH DEPT.
OCT 1989
ENVIRONMENTAL HEALTH
DIVISION

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 6116A
TC:
SERIAL: № 10974
☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 5907 (STREET NO.) FOX CROSSING DR (STREET) ② FILE: 6116A
③ JURISDICTION: CHARL ④ TAX PARCEL NO.: 035-16 209
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: DAVID (FIRST) ALFRED (MIDDLE) JOHNSON (LAST)
⑨ MAILING ADDRESS: 7131 PLEASANT GROVE RD
⑩ CITY: CHARLOTTE ⑪ STATE: N.C ⑫ ZIP: 28216
⑬ PHONE: (WORK) ⑭ (HOME) 392-5567

REQUEST

This request is for a(n):

⑮ ☑ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home
㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3
㉕ Type?
㉓ Maximum occupancy? 5
㉖ Maximum number of employees?
㉔ Basement? ☑ yes ☐ no (DEPENDS ON GRADE)
㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well
B ☒ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: David Alfred Johnson
Date: Sept 28/89

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:


. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Philo S. Walker, 10/10/89
Environmentalist — Date

10-11-89
Director or Authorized Section Head — Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.


63
DITCH
15
PROPOSED SITE
DRAIN FIELD
75
FOX CROSSING DR
140
.79 ACRE
PIPE
244'
DITCH
HIPP RD.

OAKDALE RD
FOX CROSSING
HIPP RD