Date Received 1/17/80

APT No. 16430

T C No 231-061-03

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Davis (LAST) Helen (FIRST) H. (MIDDLE)

2) ADDRESS OF OWNER c/o Wellworth Realty Co., Rt. 1, Box 390, Davidson, N.C. ZIP 28036

3) PHONE NO Home _____ Office _____


4) LOCATION OF PROPERTY Davis Drive (Off McKee Rd., Matthews)
(STREET OR COUNTY ROAD)

5) SUBDIVISION East Providence Estates LOT NO 13 BLOCK NO 3

MAP BOOK NO 9 PAGE NO 357

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Helen H. Davis
OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16430

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 231-061-03

(Ground Absorption Sewage Disposal)

OWNER HELEN M. DAVIS % WELLWORTH REALTY
ADDRESS R-1 Box 390
COUNTY DAVIDSON, N.C. 28036
LOCATION OF SITE: DAVIS Drive, Lot 13

DATE REQUESTED: 1-17-80
PLAT NO.: 38707
LOT SIZE: EAST PROVIDENCE ESTATE

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-10	S PS (U) — 0-2	S PS U	S PS U *
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy clayey, Note 2:1 Clay)	S (PS) U — Sandy Loam	S (PS) U — Sandy To Clayey	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) U — GRANULAR TO BLOCKY	S (PS) U — GRANULAR TO MASSIVE	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U — 48>	S PS (U) — <48	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S (PS) U — NONE	S PS (U) — Hard Pan	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S (PS) U — Adequate	S PS (U) — Underwater	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U — Moderate	S PS (U) — Slow	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	P. Suitable	Unsuitable		
SOIL SERIES	Appling	WEHADEE (swamp)		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments: PROVISIONELLY Suitable Soil IS VERY Limited

Described By: Willard B. Ramsey
Title: Soil Scientist Date: 1-30-80

2

DHS Form 2601
Sanitation
END 539 (3/79)


152
WEHADKEE
0 – 2
260
254
Appling
150 2-10
DAVIS DRIVE

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 16430

T.C. # 231-061-03

DATE February 7, 1980

NAME OF OWNER Helen Davis

ADDRESS OF OWNER c/o Wellworth Realty, Rt 1, Box 390, Davidson, NC

LOCATION OF LOT Davis Drive, Lot 13, East Providence Estates

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Limited area of provisionally suitable soils for the installation of ground absorption sewage disposal system in accordance with N.C. Dept. of Human Resources specifications.

Please submit plot plans of proposed residence and system location.

John R. Adkisson, Environmentalist