Date Received 6/24/77

APT No. 12752

T. C. No. 37-071-58

Map Date 1-30-76

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Batey (LAST) Elmer (FIRST) R. (MIDDLE)

2) ADDRESS OF OWNER 3411 Boulevard Colonial Heights, Virginia ZIP 23834

3) PHONE NO Home 526-2710 Office 526-4333


4) LOCATION OF PROPERTY Willhill Road (STREET OR COUNTY ROAD)

5) SUBDIVISION Wilson Woods LOT NO 10 BLOCK NO. C

MAP BOOK NO 9 PAGE NO 241

6) DEED REFERENCE DEED BOOK 2446 PAGE NO. 146

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Elmer R. Batey

OWNER Agent for Elmer R. Batey

EHD-5-76

Environmental Health Department's Copy

Date Received 11/5/79

APT No. 12752

T. C. No 32-071-58

Map Date 9/4/79

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Batey (LAST) Elmer (FIRST) R (MIDDLE)

2) ADDRESS OF OWNER RFD 1 Box 164-C-2 Prince George, VA ZIP 23875

3) PHONE NO Home 804-541-3342 Office 804-732-6413


4) LOCATION OF PROPERTY W. Hill Road # 3248 (STREET OR COUNTY ROAD)

5) SUBDIVISION Wilson Woods LOT NO 58 BLOCK NO 71

MAP BOOK NO 137 PAGE NO 67

6) DEED REFERENCE DEED BOOK 2446 PAGE NO 146

Application is hereb, made to the Mecklenburg Count. Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Elmer R. Batey
OWNER

EHD 5-76

Environmental Health Department's Copy

S. I. P. No. 12752

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION
(Ground Absorption Sewage Disposal)

T. C. P. 137-071-58

OWNER ELMER & BAILEY
ADDRESS R-1 Box 164-DJ
COUNTY PRINCE GEORGE VA 23875
LOCATION OF SITE: Will Hill ROAD LOT #10

DATE REQUESTED 11 5 79
PLAT NO.
LOT SIZE 28670

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2 - 10	S (PS) U — 0 - 2	S (PS) U — 2 - 10	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy loamy clayey, Note 2:1 Clay)	S PS U — CLAYEY 2-1	S PS U — CLAYEY 2:1	S PS U — Clays 2:1	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS U — Massive	S PS U — TEND TO BE Massive	S PS U — Blocky to Massive	S PS U
4. SOIL DEPTH (In.)	S PS U — <48	S PS U — <48	S PS U — <48	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata Rock)	S PS U — Clay	S PS U — Clays	S PS U — Clays	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S PS U — Slow	S PS U — Slow	S PS U — Slow	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS U — SLOW	S PS U — SLOW	S PS U — SLOW	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	UNSUITABLE	Unsuitable	Unsuitable	
SOIL SERIES	HELENA	MADNACAN	~~Reed~~ Helena	

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include Soil areas property lines roads streams gullies wet areas fill areas wells water bodies slope patterns etc.)


Recommendations/Comments

Described By: W. B. RAMSEY

Title: Soil SCIENTIST Date: 11-20-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

2


WILL HILL RD
90
Helena
2-10
MONACAN
0-2
235
HELENA
115

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 12752

T.C. #137-071-58

DATE 11-21-79

NAME OF OWNER Batey, Elmer R.

ADDRESS OF OWNER RFD 1, Box 164 D 7, Prince George, Va. 23875

LOCATION OF LOT Willhill Road, Lot 10, Block C

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Soil Structure Massive

Soil Permeability Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section