Date Received 9-12-73

APT No. 6976 45

T C No 195-015-A0

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Dellinger Madison & Assoc., Inc.
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 411 S. Sharon Amity ZIP 28211

3) PHONE NO Home ____ Office 364-7155


4) LOCATION OF PROPERTY Idlefield Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Idlewood LOT NO 33 BLOCK NO C

MAP BOOK NO — PAGE NO —

6) DEED REFERENCE DEED BOOK — PAGE NO —

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER Michael L Rodman
Vice President

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Date Received 12-10-73

APT No. 6976

T. C No 195-015-45

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

RECEIVED
DEC 1973
ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER DELLINGER MADISON & ASSOC., INC.
(LAST) (FIRST)

2) ADDRESS OF OWNER 411 S. Sharon Amity Rd. Charlotte, N.C. ZIP 28211

3) PHONE NO Home -- Office 364-7155


4) LOCATION OF PROPERTY Idlefield
(STREET OR COUNTY ROAD)

5) SUBDIVISION Idlewood LOT NO 33 BLOCK NO C

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK -- PAGE NO --

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

M C Rodman, Vice Pres
OWNER

FORM NO E-1-B-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
INTER-OFFICE COMMUNICATION

DATE: December 12, 1973

TO: Tom Ward
Environmentalist

FROM: W. Everette Lynn, Jr. WEL
Soil Scientist

SUBJECT: APT #6976 (Dellinger Madison, Inc.)
Lot No. 33-C Idlefield Lane
11-23-73

The lot was found to be composed of soils of the Helena series and fill material. The Helena soils have plastic and sticky clay subsoils which contain swelling clay minerals. They may also have a perched high water table during periods of high rainfall. The area of fill material is composed of highly compacted clayey soils. These factors result in inadequately slow permeability and percolation.

Based on this investigation, it is recommended that the lot be disapproved for installation of a septic tank system.

WEL:jdg

MECKLENBURG COUNTY

Department of Public Health

1200 Blythe Boulevard — Telephone 374-2113

Charlotte, North Carolina 28203

Date Issued
1. December 12, 1973
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 6976
T.C. No. 195-015-45
12-14-73

NAME OF OWNER Dellinger Madison & Assoc., Inc.

ADDRESS OF OWNER 411 S. Sharon Amity Road ZIP 28211

LOCATION OF LOT Idlefield Lane, Lot 33-C

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
____	1.	_____	_____ min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

X ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) 11-23-73 - The lot was found to be composed of soils of the Helena series and fill material. The Helena soils have plastic and sticky clay subsoils which contain swelling clay minerals. They may also have a perched high water table during periods of high rainfall. The area of fill material is composed of highly compacted clayey soils. These factors result in inadequately slow permeability and percolation rate.

W. Courtlandt Lyons, Jr. — Soil Scientist

John R. Johnson — Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70

MECK COUNTY DEPARTMENT OF
Date Received

APT No. 6976

T. C. No.

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER The Madison Co.
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 337 Rea Farm Dr. Matthews, N.C. ZIP 28105

3) PHONE NO. Home 847-4187 Office 882-1193


4) LOCATION OF PROPERTY Idlewild Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Idlewild LOT NO 33 BLOCK NO. C

MAP BOOK NO 17 PAGE NO 97

6) DEED REFERENCE DEED BOOK 3515 PAGE NO 204

Applicotion is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

The Madison Co.
By C. Dwight Mitchell Jr. Pres.
OWNER

EHD-5 76

Environmental Health Department's Copy

Date Received 12-10-73

APT No. 4309

T. C No 195-015-44

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

MECKLENBURG COUNTY HEALTH DEPT.
RECEIVED
DEC 1973
ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER DELLINGER MADISON & ASSOC., INC.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 411 S. Sharon Amity Rd. Charlotte, N.C. ZIP 28211

3) PHONE NO Home -- Office 364-7155


4) LOCATION OF PROPERTY Idlefield
(STREET OR COUNTY ROAD)

5) SUBDIVISION Idlewood LOT NO 34 BLOCK NO C

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK -- PAGE NO --

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER M L Robinson

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
INTER-OFFICE COMMUNICATION

DATE: December 12, 1973

TO: Tom Ward
Environmentalist

FROM: W. Everette Lynn, Jr. WEL
Soil Scientist

SUBJECT: APT ~~#7309~~ 7310 (Dellinger Madison, Inc.)
Lot No. 34-C Idlefield Lane
11-23-73

Soils were found to be of the Helena and Enon series. These soils have plastic and sticky clay subsoils which contain swelling clay minerals. In addition, the Helena soils may have a perched high water table during periods of high rainfall. These factors result in inadequately slow permeability and percolation rate.

Based on this investigation, it is recommended that the lot be disapproved for installation of a septic tank system.

WEL/jdg

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. December 12, 1973 SITE DISAPPROVAL REPORT
2. _____ INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
3. _____ SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. ~~7300~~ 6976
T.C. No. 195-015-44
~~9-5-73~~
12-14-73

NAME OF OWNER Dellinger Madison & Assoc., Inc.

ADDRESS OF OWNER 411 S. Sharon Amity Road ZIP 28211

LOCATION OF LOT Idlefield Lane, Lot 34-C

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
____	1.	_____	_____ min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

X ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) 11-23-73 - Soils were found to be of the Helena and Enon series. These soils have plastic and sticky clay subsoils which contain swelling clay minerals. In addition, the Helena soils may have a perched high water table during periods of high rainfall. These factors result in inadequately slow permeability and percolation rate.

W. Everette Lyon Jr. John R. Adkisson
Soil Scientist Environmentalist

(Stencil No.)
HHD 398
8/70

FORM NO.
H-19-8-14-70

MECK COUNTY DEPARTMENT OF
Date Received
MAR 1 1976

APT No. 6976 9359

T. C. No.

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER The Madison Co.
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 327 Red Bank Dr. Matthews, N.C. ZIP 28105

3) PHONE NO Home 847-4159 Office 882-1193


4) LOCATION OF PROPERTY Idlefield Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Idlewild LOT NO 34 BLOCK NO C

MAP BOOK NO 17 PAGE NO 27

6) DEED REFERENCE DEED BOOK 3575 PAGE NO 204

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge




7) ACCURATELY DIAGRAM & DIMENSION LOT

The Madison Co
By: C. Scott Madison Pres.
OWNER

EHD-5-76

Environmental Health Department's Copy




SECTION A-A

HOLDING & TREATMENT TANK TO BE 1500 gal. CAPACITY MANUFACTURED BY COUNTY SEPTIC TANK CO. OR EQUAL.

PROPERTY OF
THE MADISON COMPANY

Drawn [illegible] CO.
DATE [illegible]

6976



SHEET 1 OF 2

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

SEPTIC TANK AGREEMENT

The undersigned, The Madison Company, owner of property located at Lots 33 & Part of 34 Block C, Idlewild, S/D ("the site") and described in instrument recorded in Book 17 at Page 97, Mecklenburg Public Registry, hereby acknowledges that he applied to the Department of Environmental Health for a permit to install a septic tank sewage disposal system on the site; the Department evaluated the site for suitability for such a system in accord with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1900 et seq; that the Department classified the site as Unsuitable and an appropriate permit was issued by the Department.

The undersigned further acknowledges that the proper design, construction and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time, or that the Department, its officials, employees or agents assume any liability for damages, consequential or direct, which are caused, or which may be caused, by a malfunction of such syst

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the names or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

And the undersigned further agrees for himself, his heirs and assigns, that he shall indemnify and hold harmless the Department and its successors, as well as Mecklenburg County, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure, of said septic tank system.

And the undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately, in any respect, he will take whatever measures are required to correct same; or if such is impossib he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This 2 day of May, 1978. The Madison Company

By C. Hoyle Madison, Pres. (Seal)

Attest: Sandra N. Madison, Sec (Seal)

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, COPY, a Notary Public for said County and State, do hereby certify that , personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this day of 19 .

Notary Public

My Commission Expires: 19

PRESENTED FOR REGISTRATION
MAY 4 PM
MECKLENBURG REGISTER OF DEEDS N.C.

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, Beth A. Broadway (Scoggins), a Notary Public for said County and State, do hereby certify that Sandra N. Madison personally came before me this day and acknowledged that she is Secretary of The Madison Company, and that by authority duly given and as the act and deed of said corporation, the foregoing instrument was signed in its name by its President, sealed with its corporate seal and attested by Sandra N. Madison as its Secretary.

WITNESS my hand and notarial seal, this 2nd day of May, 1978.

Beth A. Broadway (Scoggins)

SEE INSTRUCTIONS ON BACK

Date Received 5/8/78

ICAR (S) Application No 6976

T & C No 195 015 47

195 015 48


Map Date 12 AC

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) X Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home Yes X No
Residence X Yes No
4) No of Bedrooms 3
5) Business Use Max No Employees
6) Washing Machine X Yes No
7) Garbage Disposal X Yes No
8) Dishwasher X Yes No
9) Water Supply
A Individual Well
B Governmental System
C Community System
1 Well source X
2 Governmental source
10) Sewage System
House located within 200 feet of public sewer Yes X No
House located within 200 feet of community sewer Yes X No
11) FHA Case No
12) VA Case No

13) NAME OF OWNER Tom Madison Company
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 327 Red Bud Trail, Matthews, N.C. 28105

15) PHONE NO Home 847-4187 Office 882-1193

16) LOCATION OF SYSTEM Interlaken Lane
STREET OR COUNTY ROAD

17) SUBDIVISION Idlewood Lot No 33 Section 36 Block No C

Map Book No 17 Page No. 97

18) DEED REFERENCE – DEED BOOK 3575 AT PAGE 204

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES NO DATE RUN

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true

5/8/78
DATE OF APPLICATION

THE MADISON COMPANY
By C. Dewey Mask
OWNER

EHD-5-76

Environmental Health Department's Copy

6976

LA No. P.O. 195-015-44 & 45

Serial No. 1809

Date Issued 5/9/78

T. C. No. 12-14-73

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER The Madison Company
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 327 Red Barn Trail, Matthews, N. C. ZIP 28105

LOCATION OF LOT Idlefield Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Idlewood LOT NO 33 & Part of 34 BLOCK NO C

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 6976
This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information pointed in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit *AGREEMENT CARD SIGNED AND RECORDED ON May 4, 1978

Environmentalist

John R Adkisson
Environmental Health Director, or Authorized Section Head

EHD 5-76

Environmental Health Department's Copy