Date Received 10/16/79

MECK COUNTY DEPARTMENT OF
RECEIVED
OCT 16 1979
ENVIRONMENTAL HEALTH

APT No 16244

T C N 2041-124-10

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER [illegible] (LAST) [illegible] (FIRST) P. (MIDDLE)

2) ADDRESS OF OWNER [illegible] ZIP 28075

3) PHONE NO Home 537-5764 Office 537-5764 - Home only

4) LOCATION OF PROPERTY [illegible] Charlotte, NC.
STREET OR COUNTY ROAD

5) SUBDIVISION Secrest Park LOT NO 312-314 BLOCK NO [illegible]


MAP BOOK NO 4 PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Tax account # 041-124-10-C,

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and observation of the property described for the purpose of determining if the lot is suitable for the installation of a conventional septic tank wastewater treatment system with subsurface soil absorption effluent discharge.

plan for [illegible] Lot # 312 - 314.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Myrtle Bennett Neely
OWNER

EHD-5-76

Environmental Health Department's Copy

S.I.R. NO. 16244

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

T.C. # PO 041-12410

(Ground Absorption Sewage Disposal)

OWNER: Myrtle B Mills
ADDRESS: Rt 1, Box 204
COUNTY: Hendersville, N.C.
LOCATION OF SITE: Sunset Blvd

DATE REQUESTED:
PLAT NO.: Lots 315, 316
LOT SIZE: 12,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-6% U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S (PS) Clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) 40" PS U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Needs (PS) Surface water U diversion	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) Moderate U	S PS U	S PS U	S PS U
8. OTHER (Specify)	S Lot Less PS than (U) 24,000 sq ft	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES ✓	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)


Recommendations/Comments:

Described By: William A. Marlin

Title: Soil Scientist Date: 10-19-79

DHS Form 2604 (2/77)
Sanitation

2


100'
Cecil
2-6-3
170'
170'
Sunset Blvd
100'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 16244

T.C. # po 041-124-10

DATE Oct. 19, 1979

NAME OF OWNER Neely, Myrtle

ADDRESS OF OWNER Route 1, Box 284, Huntersville, NC 28078

LOCATION OF LOT Sunset Boulevard, Lots 315 and 316

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Inadequate area available for installation of ground absorption sewage disposal system in accordance with North Carolina Department of Human Resources specifications.

Please submit plans and plot plans of proposed construction for consideration.

John R Adkisson

John R. Adkisson, Environmentalist