Date Received 5-20-83

SIR No. 19698

T. C. No. 035-081-01

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Sanders (LAST) James - Paul (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 915 Oakedale RD Charlotte ZIP 28216

3) PHONE NO. Home 399-7995 Office _____


4) LOCATION OF PROPERTY 901 Dale Ave (STREET OR COUNTY ROAD) _____

5) SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP-BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

J. P. Sanders
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 19698
T.C. NO. 035-081-01
DATE: 6-2-83

Mr. James P. Sanders
915 Oakdale Road
Charlotte, NC 28216

RE: Property located at 901 Dale Avenue

Dear Mr. Sanders:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, please submit your proposals, in the form of plans and specifications, to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreement Form" provided by this office.

If I may be assistance, please feel free to call.

Sincerely,

John R. McKisson

John R. McKisson
Consumer Services Programs Manager

JRA:kbg

Enclosure

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19698
T.C. NO. 035-081-01

(Ground Absorption Sewage Disposal)

OWNER: James Sanders
ADDRESS: 915 Oakdale Rd 28216
LOCATION OF SITE: 901 Delaine

PLAT NO:
LOT SIZE: 20,000 1.458A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-4	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) — 2-1 Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS (U) — Light Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (U) — 12"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS (U) — Clay	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS (U) — Adequate	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IV.L			
9. SITE CLASSIFICATION	Unsuitable			
10. SOIL SERIES	Wilkes			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: W. B. Ramsey
Title: Sanitarian

Date: 5-31-83

EHD 539 (Revised: 6/82)

2


Dale Avenue
Dist Rd
100
Wilkes
2-4
260
Plank Rd

Date Received 3/25/85

RECEIVED
SEE INSTRUCTIONS ON BACK
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 19698

T. C. No. 035-081-01


Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___X___ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes____No
Residence ____Yes____No

4) No of Bedrooms 3
5) Business Use — Max No Employees _____
6) Washing Machine X Yes ____No
7) Garbage Disposal ____Yes X No
8) Dishwasher X Yes ____No
9) Water Supply:
A) Individual Well X
B) Governmental System _____
C) Community System:
1 Well source _____
2 Governmental source _____
10) Sewage System:
House located within 200 feet of public sewer ____Yes X No
House located within 200 feet of community sewer ____Yes X No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER DEDRICK (LAST) GLENN (FIRST) ARTHUR (MIDDLE)

14) ADDRESS OF OWNER ROUTE 14, BOX 309 WILDLIFE ROAD CHARLOTTE N.C.

15) PHONE NO. Home 704-393-7725 Office 704-394-7121 EXT. 206

16) LOCATION OF SYSTEM 901 DALE AVENUE (STREET OR COUNTY ROAD) CHARLOTTE N.C.

17) SUBDIVISION _____ Lot No. 6 Block No. 2

Map Book No. 35 Page No. 8

18) DEED REFERENCE — DEED BOOK 4808 AT PAGE 491

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES _____ NO DATE RUN 06-02-83

20) PTR NUMBER (See Instructions) 19698

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

MARCH 22, 1985
DATE OF APPLICATION

OWNER Karen B. Dedrick

EHD-S-76

Health Department's Copy