Date Received 9 May 1984

SIR No. 20975

T. C. No. 031-013-02

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER _____ (LAST) _____ (FIRST) _____ (MIDDLE)

2) ADDRESS OF OWNER _____ ZIP _____

3) PHONE NO Home _____ Office _____


4) LOCATION OF PROPERTY _____ (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 2 BLOCK NO _____

MAP BOOK NO 3 PAGE NO 32

6) DEED REFERENCE DEED BOOK 3077 PAGE NO 559

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Owner Rilla Lovett Greene

by Rozzie Greene Jarrett
Power of Attorney

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20975

T.C. NO. 031-013-02

(Ground Absorption Sewage Disposal)

OWNER: Kathleen Greene
ADDRESS: 7236 Mt. Holly Rd 28110
LOCATION OF SITE: Mt. Holly Rd

PLAT NO:
LOT SIZE: 31,227 -.72-

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-6	S (PS) U 2-6	S (PS) U 2-4	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) 2-1 clay	S PS (U) mixed clay	S (PS) U Blocky clayey	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Weak Blocky	S PS (U) weak Blocky	S (PS) U Blocky	S PS U
4. SOIL DEPTH (inches)	S PS (U) 0-8	S PS (U) 72-30	S PS (U) 15-20	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U None	S (PS) U None	S (PS) U None	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U Adequate	S PS (U) Slow	S PS U Adequate	S (PS) U
7. OTHER (Specify)	S PS U	S PS U Restrict. Hor. (U)	S PS U	S PS U
8. SOIL GROUP	IVe	IIIw	IVe	
9. SITE CLASSIFICATION	Unsuitable	Unsuitable	Unsuitable	
10. SOIL SERIES	Wilkes	Helena	Shallow depth of Cecil	

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 6-14-84

2W


Wall
Wall
Wall set Back
Cecil
2-4
Helena
Wilkes
Mt Holly
75
Rd

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20975
T.C. NO. 031-013-02
DATE: 6-15-84

Rethia L. Greene
7930 Mt. Holly Road
Charlotte, NC 28214

RE: Property located at Mt. Holly Road

Dear Ms. Greene:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure