Date Received 5-19-82

RECEIVED
MAY 19 1982
ENVIRONMENTAL HEALTH

CAR(S) Application No. 18758

T. Q.N.6 027-072-05


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ___ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3 PLOT PLAN ACCURATELY DIMENSIONED

Mobile Home ✓ Yes ___ No
Residence ___ Yes ___ No

4) No of Bedrooms 3

5) Business Use — Max No Employees ___

6 Washing Machine ✓ Yes ___ No

7) Garbage Disposal ___ Yes ✓ No

8 Dishwasher ___ Yes ✓ No

9) Water Supply
A) Individual We ___
B Governmental System ___
C Community System
1 Well source ✓
2 Governmental source ___

10 Sewage System
House located w/in 200 feet of public sewer ___ Yes ✓ No
House located w/in 200 feet of community sewer ✓ Yes ___ No

11 FHA Case No ___

12 VA Case No ___

13) NAME OF OWNER E. P. Nisbet Co.
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 10 E Hoyt St.

15) PHONE NO Home 333-2113 Office 333-7755

16) LOCATION OF SYSTEM E. Hoyt St. N. Ext.
STREET OR COUNTY ROAD

17) SUBDIVISION Sharon Hill Lot No 45 Block No. ___

Map Book No ___ Page No ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

5-19-82
DATE OF APPLICATION

James J. White
OWNER

EHD-S-76 ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 6-1-82

Serial No. 5485


ICAR(S) Permit No. 18758

P.O. T.C No. 027-072-08

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18758, dated 5-19-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 6-15-82, after which date this permit shall be null and void



PLOT OF SYSTEM

Permeability Rate —

Liquid Capacity of Tank existing

Tank Construction —

Absorption and or Nitrification Lines

Total Line Length 100'

Number of Lines 2

Distance from House >10'

Distance from Property Line >10'

Distance from Well >100'

NAME OF OWNER E. R. Nisbet Inc

LOCATION OF PROPERTY lot 43 Forest Park Mobile Home Park

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Test pit for new Tap - first install 100' of drainfield 6" wide 20" deep 34 stone

Division or Section Head

Environmentalist Mike Sexton

* If this permit is for the installation or construction of a new system it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHO-S-76

FILE COPY - HEALTH DEPARTMENT COPY

C of A (s) No. 18758

Date Issued 6-16-82 Serial 5185 P.O. - T. C. No. 027-072-08

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner C.P. Nisbet Co. (LAST / FIRST)

Location of Property 6101 Prosperity Church Rd. (MIDDLE) lot 45

Application Number 18758 Permit Number 18758

Inspection Date:

Liquid Capacity of Tank — Tank Material —

Total Length of Drain Tile 125' Number of Lines 2

Depth of Filter Material 34" Cover Depth 3'-4'

Water Supply Source Community well Distance from Water Source > 100'

Excavation Inspected — (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 6-16-82 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

M. Sexton
Environmentalist

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT COPY

15

Serial No. 6081

ICAR(S) Permit No. 18758


* Date Issued 3-9-83

PT C No. 027-072-08

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18758, dated 3-5-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 4-9-83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate Repair

Liquid Capacity of Tank

Tank Construction

Absorption Area Type

Total Line Length 100'

Number of Lines 1

Distance from House >10'

Distance from Property Line >10'

Distance from Well >100'

NAME OF OWNER E. F. Nisbet Co

LOCATION OF PROPERTY 6101 Property Church Rd Lot 45

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or be used. The issuance of this permit does not in any way guarantee that the system anticipated to be installed will operate properly, or relieve any person now or hereafter owning, controlling, or using such system from any and all responsibility from the failure of the system to operate properly.

Repair bed 3 ft. wide x 30 ft long x 6 ft Stone

Comments

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

C of A (s) No. 18758

Date Issued 4-21-83 Serial 5713 P. C. No. 027-072-01

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner E.P. Nisbet Co (LAST / FIRST / MIDDLE)

Location of Property 6101 Prosperity Ch. Rd Lot 45

Application Number 18758 Permit Number 18758

Inspection Data:

Liquid Capacity of Tank — Repair Tank Material —

Total Length of Drain Tile 100' Number of Lines 1

Depth of Filter Material 9' Cover Depth 2'

Water Supply Source Comm well Distance from Water Source 7100'

Excavation Inspected — (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 4-21-83 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the individual Septic Tank System with subsurface soil absorption, effluent discharge as described above and it has been ✓ installed or constructed ___ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit as well as in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Lot 45

Environmentalist

EHD-S-76

ENVIRONMENTAL FILE - DO NOT REMOVE