12-15-83

Date Issued 12-12-83

Serial No. 7049

SIR No. 20205

T. C. No. PO 005-131-15

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Washam, (LAST) Ernest (FIRST) Wayne (MIDDLE)

ADDRESS OF OWNER P.O. Box 2153, Davidson, NC ZIP 28036

LOCATION OF LOT 20224 Highway 73 (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 20205. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

R. Phelps
Environmentalist

Bill D. Hardister
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 10-21-83

RECEIVED
OCT 21 1983
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 20206

T. C. No. 011-19-13


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) ✓ Alter or Repair on individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No
4) No of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well yes
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No. ___
12) VA Case No. ___

13) NAME OF OWNER McCormick Sr. (LAST) Jack (FIRST) Smith (MIDDLE)

14) ADDRESS OF OWNER Rt 2 - Box 236 Huntersville, N.C 28078

15) PHONE NO. Home 875-1794 Office 372-2630

16) LOCATION OF SYSTEM Hooper Road (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ✓ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

10/24/83
DATE OF APPLICATION

Jack S McCormick Jr.
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 10-25-83

Serial No. 6725


ICAR(S) Permit No. 20206

T. C No. 611-191-13

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 20206, dated 10-24-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11-25-83 after which date this permit shall be null and void.



FLOW OF SYSTEM

Permeability Rate

Liquid Capacity of Tank Repair

Tank Construction

Absorption and/or Nitrification Lines

Total Line Length 125'

Number of Lines 2

Distance from House 10'+

Distance from Property Line 10'+

Distance from Well 50'+

NAME OF OWNER Hagen Rd Jack S. McCormick, Jr.

LOCATION OF PROPERTY Hagen Rd

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Work repair from existing D-Box - cut off existing field and install 2 - 6.3' x 3' x 12" stone trenches - Keep 10' from proposed pool

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT COPY