

GREYLAND HILLS LOT 45

5/10/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3798A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Greyland Hills, Phase II, off Grey Road.

② SUBDIVISION: Greyland Hills ③ LOT: 45 ④ BLOCK: _____
Part of 003-131-01

⑤ PARCEL REFERENCE: BOOK NO.: 03 PAGE NO.: 13 PARCEL NO.: 01

⑥ DEED REFERENCE: BOOK NO.: 3664 PAGE NO.: 949

OWNER


⑦ NAME: Bobby (FIRST) B (MIDDLE) Knox (LAST)

⑧ MAILING ADDRESS: PO Box 4

⑨ CITY: Davidson ⑩ STATE: NC ⑪ ZIP: 28036

⑫ PHONE: (WORK) 892-0196 (HOME) 892-0248

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 11 1987
ENVIRONMENTAL HEALTH

Signed: Bobby B. Knox

Date: 3/25/87

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY

Department of Environmental Health

September 24th, 1987

Bobby B. Knox
P.O. Box 4
Davidson, NC 28036

RE: Property located at Charden Road Extension 45
FILE: 3798A
PARCEL: 00313101PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 14506) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 14506

File: 3798A Action 4

Parcel: P000313101 ☐ PC

Location: Charden Road Extension

Subdivision:


Lot: 45 Block: Acres: 1.4

Owner: Bobby B. Knox
Address: P.O. Box 4
Davidson, NC 28036

Comments: _____

Described by: William A. Marlin

Date: 9-23-97



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS (U) complex slopes	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 7.36" To water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 7.36"	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 7.36"	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U —	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	10A Cecil-Like	Complex Slopes				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U