MECKLENBURG COUNTY HEALTH DEPARTMENT

INTER-OFFICE COMMUNICATION

DATE: August 10, 1973

TO: Randy Reynolds
Environmentalist

FROM: W. Everette Lynn, Jr. WEL
Soil Scientist

SUBJECT: William Wiley Drive, Lot 8-B
APT #6292 (Allred, R. M.)

8-8-73 Soils were found to be of the Wilkes series on the North side of the lot and imperfectly drained alluvial soils on the South side of the lot. The Wilkes soils are shallow to impervious rock material. The alluvial soils have a seasonally high water table. These factors result in inadequately slow perc and permeability. Based on these observations, lot is recommended for disapproval.

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203
Telephone 374-2113

Date Issued
1. July 17, 1973
2. Nov. 19, 1973
3. _____

SDR No. 6292
T.C. No. ~~105-133-09~~ 4-27-73

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Allred, Robert Miller

ADDRESS OF OWNER 1304 Downs Avenue ZIP 28205

LOCATION OF LOT Williams Wiley Drive, Lot 8-B

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	7-13-73	Infinity min/in
X	2.	11-16-73	300 min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

R. M. Reynolds
Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70

R

Date Received 5-15-73

APT No 6292

T. C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER ALLRED (LAST) ROBERT (FIRST) MILLER (MIDDLE)

2) ADDRESS OF OWNER 1304 DOUGLAS AVE. ZIP 28205

3) PHONE NO. Home 3335947 Office 376-3077


4) LOCATION OF PROPERTY Tara Lynda Estates Williams Wilson Dr. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 8 BLOCK NO. B

MAP BOOK NO. 9 PAGE NO. 409

6) DEED REFERENCE DEED BOOK 2806 PAGE NO. 289

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Robert M. Allred
OWNER

FORM NO. E-1-8-1-72

HEALTH DEPARTMENT'S COPY